



PROJECT

ACGS - VIKING CAFE & PREP SCHOOL GLAs

DOCUMENT

ELECTRICAL SERVICES SPECIFICATION

SITE ADDRESS

**OAKLANDS PARADE
EAST BRISBANE QLD 4151**

PROJECT MANAGER

**BSPN ARCHITECTURE
116 BROOKES STREET
FORTITUDE VALLEY QLD, 4006**

DESCRIPTION

**REVISION: C3
DATE: 24 JUNE 2020**

[illegible]

ELECTRICAL DESIGN GROUP BRISBANE PTY LTD ACN 092 710 793
TRADING AS - ELECTRICAL DESIGN GROUP ABN 96 092 710 793

1.0 EXTENT OF WORKS

1.1 SCOPE

The electrical services sub-contract includes but is not limited to the following:

- Supply and installation of all components forming part of the electrical services.
- Attendance at a handover meeting.
- Co-ordination.
- Authorities' approvals.
- Approvals.
- Shop drawings.
- Installation drawings.
- Work-as-executed drawings.
- Inspections.
- Testing and commissioning.
- Maintenance.
- Programming.
- Manuals.
- Cabling, cable support systems and access.
- Samples.
- Spare conduits, wall boxes and draw wires for future use and use by other trades.
- Quality assurance.
- Power distribution.
- Lighting.
- Communication cabling.
- Intruder detection
- Access control.
- PA school bell system.
- Fire Alarm System.
- BMS.
- All minor components and incidental works not specifically referred to, however necessary to complete the electrical services installation such that it is handed over complete, operational and fit for the intended use.
- Include the following provisional additional items which will be positioned on site prior to fitoff: If the value of the following items is not confirmed with the tender it will be agreed by all parties that the value is \$25,000.00.

Quantity	Description
20	Single GPOs on existing circuits.
20	Double GPOs on existing circuits.
10	20-amp RCD protected 1 phase circuit with 50m of 2.5mm ² TPS cable.
10	20-amp 1 phase circuit with 50m of 2.5mm ² cable and an IP56 isolator connected to the equipment.
10	20-amp 3 phase circuit with 50m of 2.5mm ² cable and an IP56 isolator connected to the equipment.
24	Communications outlet.

With the tender response provide a copy of the Electrical Sub Contractors licence. Include a copy of all of the above licence in the maintenance manual.

Accept full responsibility for liaising, arranging and co-ordination all works that have an effect on or will be affected by the electrical services.

Should the Electrical Sub Contractor not provide the information required to be submitted by this specification within two weeks of being requested to do so or as agreed to in writing, the Electrical Sub Contractor is to agree to a variation credit of \$2,000.00 to the contract in lieu of the provision of such information.

Should the Electrical Sub Contractor not provide the Work-As-Executed drawings within two weeks of practical completion or as agreed to in writing, the Electrical Sub Contractor is to agree to a variation credit of \$2,000.00 to the contract in lieu of the provision of the Work-As-Executed drawings.

Should the Electrical Sub Contractor not provide the Operation and Maintenance Manual within two weeks of practical completion or as agreed to in writing, the Electrical Sub Contractor is to agree to a variation credit of \$2,000.00 to the contract in lieu of the provision of the Operation and Maintenance Manual.

All dollar amounts nominated within the electrical documents including credit variations, rates and provisional sums do not include Goods and Services Tax (GST).

1.2 ASSOCIATED WORKS

Co-ordinate with the relevant bodies for the following works associated with but excluded from the electrical services sub-contract. The electrical sub-contractor is responsible for coordinating the interface of the electrical services with the following services:

Service	Responsibility
Mechanical Services	Mechanical services sub-contractor.
Hydraulic Services	Hydraulic services sub-contractor.
Audio Visual Services	Specialist Audio Visual Contractor
Access panels	Contractor
Build in sleeves, supports, hangers, fixings, anchorages and the like	Contractor
Make good after the installation of electrical services provided it is in the normal construction sequence	Contractor
Trimmed openings in ceilings where necessary for recessed fluorescent lights; untrimmed openings in ceilings for other recessed lights. As part of the electrical works, confirm the size required for all openings	Contractor
Electric Strikes	Contractor
Signs on doors.	Contractor
Provision of insitu cast in penetrations through floors and walls. The electrical contractor to provide fire rating to penetrations after cables are installed if required.	Contractor
Anti-termite treatments	Contractor
Fixed equipment such as HWS and cooking equipment.	Dependant on the equipment either the contractor, other sub-contractor, specialist contractor or proprietor.
Plug in equipment such as fax machines.	Dependant on the equipment either the contractor, other sub-contractor, specialist contractor or proprietor.
Active telecommunications equipment including router, network switches, servers, PCs and monitors.	Client.

Telephone exchange lines and services.	Proprietor.
Telecommunications equipment fly leads.	Specialist telecommunications contractor.

1.3 CONTRACT DRAWINGS

The electrical service's document schedule C2083a-0001.xls details the electrical drawings, details, schedules and associated documents that form part of the electrical service's sub-contract. The electrical service's documents are diagrammatic only and the Electrical Sub Contractor must familiarise themselves with all other services documents and the architectural documents to establish the scope to be allowed for.

The current architectural drawings form part of the electrical sub-contract and as such information which appears on the architectural drawings which affects the electrical services will not be accepted as the basis of a cost variation. The electrical installation must be installed in accordance with the architectural drawings issued for construction.

1.4 SITE CONDITIONS

As part of the tender, the tenderer is required to familiarise themselves with all site conditions and allow for such conditions within the tender. Changes or additions due to site conditions or requirements which could have been established during a tender period site inspection will not be accepted as the basis of a cost variation.

1.5 DEFINITIONS

Refer to the section A of the specification for the definitions to be read into the electrical services documents

1.6 PRELIMINARIES

Carry out all of the electrical services works in accordance with the Builder's program and the preliminaries defined in section A of the specification.

1.7 CORROSION AND UV PROTECTION

Ensure that all metal surfaces are suitably protected against corrosion, and that all plastic materials are UV stabilised. Repair to new condition or replace any components showing any signs of corrosion during the defect's liability period.

Ensure that all metal surfaces are suitably protected against corrosion likely to be experienced during the life of the installation. Cover all electrical terminations including terminal screws and exposed raw metal including exposed conductors with clear synthetic resin based insulating enamel before fixing the terminal covers in place. Provide all fixings exposed to the weather and those in potentially corrosive environments as stainless steel. Do not use materials that will react with or cause galvanic reactions with adjacent materials or surfaces.

Use only plastic materials, paints, insulation materials and coatings that are UV stabilised and will not break down with the normal exposure to ultra violet radiation during the life of the installation. Provide written evidence for approval that all such materials are UV stabilised. Do not install PVC in locations it will be exposed to direct sunlight.

1.8 WORKMANSHIP

Ensure that the work is performed by the holder of a current Electrical Sub Contractor license. Provide a copy of the license before commencing work onsite and include a copy in the operating and maintenance manual.

Ensure the installation and all components, fixtures, fittings, outlets and cables are supplied and installed to a high standard throughout, and installed in a neat and tradesman like manner, to the current industry

standards. Ensure all materials and components of a similar type are of the same manufacturer and installed in a uniform manner.

It is the Electrical Sub Contractor's responsibility to ensure that the installation is fit for purpose and is provided as a complete working installation. It is the Electrical Sub Contractors' responsibility to provide all components, fittings, fixtures, systems, programming etc irrespective of the level detailed in the documents such that the installation is provided as a complete working installation.

Irrespective of the information documented it is the Electrical Sub Contractors' responsibility to ensure all aspects of the installation comply with and meet the requirements of all relevant authorities and the relevant current Australian Standards.

Provide all materials as new, and of the highest class available for their respective types.

It is the electrical sub contractor's responsibility to ensure all conduits are not damaged during concrete pours.

Within the tender allow to conceal all wiring and conduits. Exposed cabling or conduits are generally not acceptable. For extreme circumstances a written request to allow the running of an exposed service in a specific location may be considered. In such circumstances the Electrical Sub Contractor is to agree to a variation credit of \$1,000.00 to the contract for each exposed service.

Provide all circuits and outlets required by any control or communications equipment supplied as part of this contract, irrespective of whether these outlets and circuits are shown on the drawings. Such outlets may include, but are not limited to, the following:

- Amplifiers.
- Control panels.
- Communication and intruder detection equipment.

During the course of the building being painted, remove flush plates, light fittings and other equipment that is likely to be marred by painting and mask/cover other equipment such as switchboards and the like. On completion of the painting replace all equipment; remove masking/covers and the like. Clean off any paint marks and return the finish to as new condition.

Install components and equipment in accordance with the manufactures recommendations and ensure such components and equipment are not operated outside of the limits specified by the manufacturer.

Irrespective of the extent of information or the accuracy of such information it is the Electrical Sub Contractor's responsibility to confirm the location of all existing services on site. The cost of repairing and of disruption to service due to damage to existing services is to be met by the Electrical Sub Contractor.

Ensure all components, equipment and materials supplied are new, unused, designed and selected to ensure satisfactory operation under varying atmosphere, climatic, humid tropical conditions without distortion and deterioration in any part affecting efficiency and reliability of the systems. Design and select all equipment to provide the necessary safety to human life and property during operation and maintenance with particular attention given to electrical safety and segregation precautions.

Check the finished paintwork around the area of each installation and touch up all damaged parts and finishes after the installation of the electrical services.

Within the tender response provide a list of sub-contractors that will be engaged by the electrical sub-contractor including the postal address, fax number, telephone number and e-mail address. Within two weeks of being awarded the contract provide the names and contact phone numbers of the electrical sub contractor's supervisor and site foreman as well as the supervisor and site foreman of each of the sub-contractors that are to be engaged by the electrical sub-contractor.

Provide an electronic digital photograph for approval of all works that are carried out that will not be visible after installation, within five working days after the respective work has been completed. Each photograph is to electronically stamped with the time and date and be either named with descriptive name that allows the location to be simply identified or accompanied with a tabulated description. Include a copy of the photos in the operating and maintenance manual.

1.9 PROGRAM

Carry out all of the electrical services works in accordance with the Builder's program. Within ten working days of the contract being awarded to the contractor the contractor is responsible for providing an electrical services program and procurement schedule for the ordering and delivery of all components forming part of the electrical installation. The electrical services program is to include the start and finish dates for each of the following:

- Engage Electrical Sub Contractor.
- Shop drawings for approval.
- Commence electrical demolition.
- Conduit installation within each major structural component.
- Rough-in of each major area.
- Fitoff of each major area.
- Samples ready for approval.
- Factory inspections.
- Switchboard delivered to site.
- Power to be energised.
- Testing.
- Commissioning.
- Practical completion.

Where a component or document is noted as requiring to be submitted for approval, it is the electrical sub contractor's responsibility to obtain in writing the approval of such from the client, the project manager, the engineer and from a senior member of the electrical sub-contractors' firm. The electrical sub-contractor must give each of the approving parties' one weeks' notice of the pending requirement for the approval and give each approving party a minimum of two working days to respond. Should an approval not be given it is the electrical sub contractor's responsibility to revise the material being submitted for approval and resubmit such material. The re-submission of material for approval does not constitute grounds for an extension of time.

1.10 ACCESS

Allow to provide all necessary access to install and complete the electrical services irrespective of the electrical services access provisions detailed on the drawings. The electrical services access provisions detailed on the drawings are not intended to be comprehensive or provide all of the access requirements necessary to complete the electrical installation. This includes though is not limited to the following:

- Conduits.
- Blockouts.
- Ducts.
- Risers.
- Hat sections.
- Covers.
- Cable trays and ladders.
- Chasing.
- Cutouts.
- Pits and trenching.

1.11 ALTERNATIVES

Alternative components and design will be considered with the cost of the consideration being borne by the Electrical Sub Contractor. Any alternative may be rejected without a reason being provided. Alternatives which are used without written approval must be removed from the installation and replaced with the complying item at the electrical sub contractor's cost.

1.12 DEFECTS

Should more than two defect inspections due to poor workmanship, be required to be performed by the electrical engineer the cost of such inspections will be passed on the electrical sub-contractor. The approval of the contract payment will be dependent upon the rectification of such defects and the settlement of the respective inspection costs.

When advice of a defect is received by the electrical sub-contractor provide written advice within 24 hours of the date the defect will be rectified.

The expiration of the warranty period does not exclude the contractor or the electrical sub-contractor from the responsibility of latent defects discovered after the warranty has expired.

1.13 ANOMALIES

It is a requirement that the tenderer allow for within the tender, the most expensive solution to address anomalies which may exist between any of the drawings, the drawings and the specification or between any of the contract documents and an authority requirement or a relevant Australian Standard. The Electrical Sub Contractor is to identify any anomalies and request in writing a direction on which option to proceed with. Any such direction will not constitute grounds for a variation or an extension of time.

1.14 APPROVALS

Where information has been nominated as requiring to be submitted for approval or the information must be approved, apply the following definition:

Each request for approval must be made in writing, accompanied with all necessary supporting information to allow for the prompt assessment of the request. Each request must be first approved by a senior member of the contracting firm prior to being submitted. For the approval to be valid the following parties must each grant an individual approval:

- A senior member of the contracting firm.
- The engineer.
- The project manager.
- The client.

Each request for approval must include the following information:

- Project name.
- Approval name.
- Approval submitted date.
- Approval required date.
- Description of what approval is required and how the approved information / items will be used.
- Facility for each of the approving parties to date and acknowledge their approval.

A typical request for approval is available from the Electrical Design Group web site www.edg.net.au.

It is the Electrical Sub Contractor's responsibility to seek approvals and do so in a timely manner with the understanding that approvals may not be given and the request for approval may have to be modified and resubmitted. Delays in submitting requests for approval and resubmitting revised requests for approval will not constitute grounds for an extension of time. Unless advised otherwise the Electrical Sub Contractor must allow one working week for the approval to be given by the engineer, the project manager and the client.

1.15 CUSTOMER ACCEPTANCE

At the conclusion of the installation a preliminary walkthrough with the installation contractor and the customer's representative will be performed to check for installation quality, accurate performance of the work, and to verify the accuracy of work-as-executed documents. Complete any modifications to the documentation or the installation that may be required within a 2-week period from the walkthrough. Customer Acceptance will be given following a final walkthrough with the installation contractor and the customer's representative if all previously identified issues have been addressed.

If the Electrical Sub Contractor has advised that the previously identified issues have been addressed and it is found they have not been, the Electrical Sub Contractor is responsible for meeting the costs of subsequent customer acceptance inspections at the rate of \$200.00 per hour plus GST plus disbursements. The walk through will be scheduled within 3 weeks of the completion of the installation in order to turn the project and documentation over to the end user. Please note that "Customer Acceptance" does not release the Contractor from repairing any cabling errors or improperly labelled circuits, caused by the Contractor that may be discovered at a later date.

1.16 HANDOVER

Within two weeks of the contract being awarded, the contractors site foreman and the Electrical Sub Contractor's site foreman are both required to attend an electrical services handover meeting for a duration that will not exceed three hours. The time and location will be confirmed by the Electrical Design Group. The contractors site foreman and the Electrical Sub Contractor's site foreman are both required to confirm in writing to the Electrical Design Group that they will be attending the handover meeting. The intention of the handover meeting is to review the following information, answer any questions and identify any potential issues:

- How the electrical services design is documented and the purpose of each document.
- The services available on the Electrical Design Groups web site.
- The communication process and channels used by the Electrical Design Group.
- The relationship between the electrical services documents and the other discipline documents.
- The client's expectations of the electrical services.
- An overview of the contractual arrangements.
- A summary of the unusual contractual requirements within the electrical services.
- Identify any areas and items that may be subject to further design development or change.
- Identify any electrical services authority requirements.
- Summarise the major risks and or difficulties within the electrical services.
- Review the design of each system within the electrical services identifying the design critical components and components within the design that are open to the contractors input.
- Review the layout of each system within the electrical services identifying the design critical areas and layouts that are open to the contractors input.
- Summarise the major areas of coordination and the coordination requirements.

Prior to the hand over meeting the contractors site foreman and the Electrical Sub Contractor's site foreman are both required to have reviewed the electrical services documents. The contractor's site foreman is required to bring a full size set of the current electrical services documents to the handover meeting. Other's such as the Client, Architect, Contractors supervisor and Electrical Sub Contractor's supervisor are encouraged to attend the handover meeting, though not considered essential. If the contractors site foreman or the Electrical Sub Contractor's site foreman do not attend the full duration of the handover meeting the contractor agrees to a credit variation of \$1,000.00 to cover the costs of the aborted handover meeting and the handover meeting is to be rescheduled.

2.0 QUALITY REQUIREMENTS

2.1 STANDARDS

Irrespective of information contained in the electrical service's documents or in instructions, it is the electrical sub contractor's responsibility to ensure all electrical services works are be installed in accordance with the requirements of the following. Refer any discrepancies between the requirements of the following and/or the electrical services documents and instructions to the Architect for clarification prior to the placing of orders, fabrication or installation of the items/methods in discrepancy.

- Building Code of Australia.
- Electricity Act.
- Electrical Safety Act.
- Workplace Health and Safety Act.
- Telecommunications Act.

Unless specifically detailed within this specification, undertake all works to the requirements of the relevant standards included in the Standards Schedule C2083a-0003.xls. Refer any discrepancies between the following standards and or the specification to the Architect for clarification prior to the placing of orders, fabrication or installation of the items/methods in discrepancy.

It is the electrical sub contractor's responsibility to obtain from all equipment and component suppliers confirmation that the equipment and components supplied as part of the electrical service's installation comply with all of the following relevant standards and codes. Specific specification of equipment or a component does not alleviate the electrical sub-contractor of the aforementioned requirement.

Keep on the site a copy of AS3000, AS3008, AS22293.1 and AS2293.2.

2.2 AUTHORITIES

Jurisdiction over the site including but not limited to the following authorities, codes, standards and regulations:

- ACMA.
- Local Council.
- Local Supply Authority.
- State Government Department of Environment and Heritage.
- Queensland Department of Justice and Attorney-General, Workplace Health and Safety Queensland
- Queensland Health
- Queensland Department of Justice and Attorney-General, Industrial Relations
- Building Regulations 2006
- Fire and Rescue Services Act 1990
- Building Fire Safety Regulation 2008
- Queensland Electricity Act
- Queensland Electricity Regulation
- Queensland Electrical Safety Act
- Queensland Electrical Safety Regulation
- Queensland Development Code
- Queensland Fire and Rescue Service (QFRS)
- Queensland Electricity Connection and Metering Manual
- SAA Communications Cabling Manual
- AS/NZS 3000 SAA Wiring Rules
- The building certifier.
- Queensland Sustainable Planning Act and Regulation 2009
- Queensland Building Act 1975
- National Construction Code (NCC) Building Code of Australia (BCA).

If any of the responsible Authorities, pursuant to the statutory powers vested in them, elect to perform, supply, inspect or test wholly or part of the works, make all necessary arrangements and co-ordinate with the Authorities.

Provide "for approval" copies of all Authorities' Approvals.

Pay all relevant authority fees and charges necessary to complete the electrical services installation to leave it in operating condition meeting all of the authority requirements.

2.3 CONTRACTOR DOCUMENTS

2.3.1 SHOP DRAWINGS

Before commencing fabrication or erection of the nominated item, submit an AutoCAD 2000 format electronic copy of detailed shop drawings via compact disc or via e-mail to brisbane@edg.net.au for approval. Prepare all drawings as A3 or A1 size to AS1100, AS1102, AS1103 and AS3702 with information detailed at the following minimum scales:

- Layout Drawings: 1:100
- Site Plans: 1:500
- Equipment Assemblies: 1:50

Ensure the shop drawings include the following information:

- General arrangement of all equipment: Include layout and clearances around equipment.
- Mounting details, structural details and calculations verifying the structural efficiency of load-bearing slabs, etc., footings and the like, supporting electrical equipment mounting structures, poles, lighting masts, etc.
- Supports: Details of equipment and cable support brackets and fixings including mountings.
- Physical cable layouts: Showing arrangement, location and identification of interconnecting wiring and cabling. All cable penetrations, connections and terminations details. Include all forms of conductors such as Bus Bars and Busducts.
- Labelling: Details of labelling and engraving.
- Earthing.
- The type, rating and capacity of all equipment and components.
- Comprehensive schematic diagrams showing the configuration and operation of all components.
- Co-ordination details with all other services.
- Plant Room Layouts.

2.3.2 WORK-AS-EXECUTED DRAWINGS

Prior to practical completion, provide for approval the following Work-as-Executed Drawings:

- Reticulation Drawings.
- Layout Drawings.
- Schematic Drawings.

Ensure the Work-as-Executed Drawings include the following information:

- All information required by the shop drawings.
- Comprehensive details on the reticulation for all of the Electrical Services including:
 - Support types and locations.
 - Conduit types and locations.
 - Junction Boxes.
 - All cable locations.
 - All lighting transformers and drivers.
 - Circuiting.
- Comprehensive details on the layout of all outlets, fittings and equipment of all of the Electrical Services including:
 - Outlet types and locations.
 - Equipment types and locations.
 - Mounting Detailing.
- Cross reference to the onsite labelling and numbering of all components and outlets.

Submit an AutoCAD 2000 format electronic copy of the work-as-executed drawings via compact disc or via e-mail to brisbane@edg.net.au for approval.

2.4 MAINTENANCE / BUILDING TUNING

Undertake all necessary maintenance of the electrical installation during the Defects Liability Period for a period of 12 months.

Carry out periodic inspections and perform maintenance work at the frequencies and following the procedures recommended by the manufacturers of the supplied equipment with at least one visit each three months. Promptly rectify all faults. Replace faulty materials and equipment, including luminaire lamps, and accessories.

In addition to the above maintenance requirements repeat the complete commissioning process three months, six months, nine months and twelve months from the date of practical completion.

The defects and liability period will not end until such certification has been approved.

2.5 OPERATION AND MAINTENANCE MANUAL

Within ten working days prior to practical completion, provide an electronic copy of combined operation and maintenance technical manuals for approval, written in clear concise English, containing the following data in the following format:

Within ten working days of receiving approval of the combined operation and maintenance technical manuals, provide the two copies of each of the approved combined operation and maintenance technical manuals.

Within ten working days of practical completion, provide the two copies of a combined operation and maintenance technical manuals, written in clear concise English, containing the following data in the following format: A typical combined operation and maintenance technical manual is available for download and editing from the Electrical Design Group web site www.edg.net.au.

- Contents.
- Project details.
 - Description of the project and the electrical services sub-contract.
 - Description of the major components of the electrical services sub-contract.
 - Description of the manual and its intended use.
 - Contact details of the electrical sub-contractor and each of the major suppliers.
- Licences and certificates.
 - Copies of all licences, certificates and statements of compliance as required by the specification.
- Operating instructions.
 - Provide an overall description of the operation of the electrical installation.
 - Describe the safe working procedures of the electrical installation.
 - Detail the environment that must be maintained for the safe and satisfactory operation of the electrical installation.
 - Detail the specific operating requirements for each component of the electrical installation.
 - Include a reference to the following government website for Electrical Safety at Work information. <http://www.justice.qld.gov.au/fair-and-safe-work/electrical-safety/business-and-industry/electrical-safety-at-work#cords>
 - Include a copy of relevant first aid hints.
- Maintenance instructions.
 - Include a description of the general maintenance requirements for the electrical installation.
 - Include a description of the safe working procedures for the maintenance of the electrical installation.
 - Detail the specific maintenance requirements for each component of the electrical installation.
- Lighting.
 - Provide a detailed description of the lighting installation.

Include any information associated with the lighting installation required to be provided by the specification such as programming and aiming details.

Provide a schedule of each light fitting, the fitting manufacturer, catalogue number and lamp type.

- General electrical components.
Provide a schedule of each general electrical component, the component manufacturer and catalogue number. This schedule does not include light fittings or the power distribution components.
- Power distribution.
Provide a detailed description of the power installation.
Include any information associated with the power installation required to be provided by the specification such as programming and aiming details.
Provide a schedule of each component of the power installation, the component manufacturer and catalogue number. This schedule is to include switchgear.
Provide a copy of each switchboard schedule.
- Work-as-executed drawings.
Provide a hard copy and an electronic copy on CD ROM in AutoCAD 2000 format. For all A1 and B1 drawings provide an A3 set as well as the full-size set.
- Emergency lighting.
Describe the emergency light installation and the statutory operation and maintenance requirements.
Detail the individual manual test features of each emergency light fitting.
Detail the AS2293 group test feature.
Provide a copy of an emergency lighting maintenance log book similar to the GLS publication available from Caribou Sales Phone (07) 3891 1112. Complete the entries in the emergency light maintenance log book.
- Test results.
Include all test results required to be provided by the specification.
- Communications cabling.
Describe the communications cabling installation and the operation and maintenance requirements. Provide a copy of the schematic layout of the communications cabling detailing the catalogue number of each component and how each component is connected.
- Security.
Describe the security installation and the operation and maintenance requirements. Provide a copy of the schematic layout of the security system detailing the catalogue number of each component and how each component is connected. Include details of power supply and how the system is programmed / configured.
- PA School Bell.
Describe the PA School Bell installation and the operation and maintenance requirements. Provide a copy of the schematic layout of the PA School Bell. System detailing the catalogue number of each component and how each component is connected. Include details of power supply and how the system is programmed / configured.
- Fire Alarm.
Describe the Fire Alarm installation and the operation and maintenance requirements. Provide a copy of the schematic layout of the Fire Alarm system detailing the catalogue number of each component and how each component is connected. Include details of power supply and how the system is programmed / configured.

Provide the manuals as A4 size, machine printed or typed on durable printing paper, with each page consecutively numbered, and neatly bound in a permanently labelled durable white vinyl covered ring binder folder. Securely fix a labelled CD containing all of the information in the manual including Auto cad files of all drawings.

2.6 LAYING OUT

The positions of outlets, switches, and equipment shown on drawings are diagrammatic only. Check on site for positions and verify locations and mounting heights with the architect. When any relocating is required to conform to the above, undertake such relocation without additional costs. Verify locations of all outlets, switches, and equipment to ensure: -

- The work of any other trade does not interfere with the electrical installation.
- They are not shrouded by door swings and tracks, furniture or equipment.
- They conform to any pattern formed by ceilings, panels, tiles, beams, and the like.
- They are not located in restricted zones as defined by AS3000. It is the Electrical Sub Contractor's responsibility to check the volume of all sinks, tubs and basins.

Promptly report any anomalies, for consideration and instructions. Work proceeding without obtaining approval, will not be accepted as basis for a variation.

Locate all adjacent outlets at the same height and ensure power and non-power outlets are segregated by 150mm.

2.7 OPERATING PARAMETERS

Ensure the electrical service's installation is installed in accordance with the following operating parameters and service conditions:

- Nominal voltages:
- Line: 400-volt
- Phase: 230-volt
- Frequency: (Hz): 50Hz
- Number of phases: Three
- Number of wires: Four
- Neutral Connection: Star Point
- Earthing System: MEN
- Ambient air temperature range: (°C): -5°C to 40°C
- Maximum relative humidity: (%): 90%

2.8 SAMPLES

Submit samples for approval for permission to use materials, fabrication, or workmanship, or as an example of design. All subsequent work is to be of the same quality as the sample on which the permission to use was given. Permission to use may be withdrawn if the standard of the sample is not maintained.

Keep approved samples in good condition on the site for the duration of the contract.

The Electrical Sub Contractor will be solely responsible for the consequences of delay resulting from failure to allow adequate time for the assessment and approval of samples, or from the rejection of samples which do not comply with the specification, or the like.

With every sample provide a sample information sheet: A separate sample information sheet must be provided for every location the relevant sample is to be installed where any of the installation conditions are different. Should a coordination conflict arise in a location that has not been addressed by a specific sample information sheet, the rectification of such a conflict must be undertaken at the Electrical Sub Contractor's expense and such conflicts will not be accepted as grounds for a variation.

The sample information sheets are provided as evidence that the Electrical Sub Contractor has checked the coordination of all components of the installation.

Ensure the sample information sheets are A4 in size and include the following information:

- Sample identification.
- Project identification.
- Sample submitted for approval date.

- Details of the location/s the sample will be used in.
- Details of how the sample will be mounted in each location.
- Details of how the cabling will be run to and connected to the sample in each location.

Typical sample information sheets are available from the Electrical Design Group web site at www.edg.net.au.

2.9 QUALITY ASSURANCE

Establish and maintain records which give evidence that the trade works has passed inspection and/or test with defined acceptance criteria and submit one (1) copy of all such records within seven (7) days of completion of the relevant work.

Allow approved representatives the right to verify at source or upon receipt that the purchased product conforms to the specified requirements. Such verification will not absolve the Electrical Sub Contractor of the responsibility to provide acceptable product nor will it preclude subsequent rejection.

Ensure a quality system is planned, established, implemented and maintained according to the requirements of AS9002 for and during the carrying out of the Services.

Allow approved representatives appointed as a Quality System Auditors the right to undertake a quality assurance audit. Provide access and all necessary assistance to the Auditors in order to demonstrate compliance with the requirements of the quality standard.

Review and analyse the cause of any deficiency revealed in the report of an audit by the Quality System Auditors and develop and implement or procure the development and implementation of corrective action to prevent recurrence.

2.10 LABELLING

Permanently label and individually number all components, fixtures, fittings, outlets and cables installed as part of this contract such that they can be quickly and accurately identified. All labels must be permanent with the type and size of label appropriate to the location and conditions. The label type must be appropriate for weathering, UV exposure, vandalism and mechanical damage. Stick on and hand-written labels are not acceptable. The numbering and identification are to be consistent and consecutive for all items. Provide matching labelling and numbering where an existing numbering and labelling system exists. Submit all labelling types, identification schemes and numbering schemes for approval. Ensure all labelling is clearly identified and cross-referenced in the manual and on the work-as-executed drawing. Double sided tape is not acceptable as a method of securing labels.

- Power outlets and light switches with clip-on faceplate / surrounds are to have the circuit identification labelled by using indelible ink in a concealed location under the clip-on faceplate / surround on the screw fixed plate.
- Isolators and power outlets and light switches that do not have clip-on faceplate / surrounds (such as weather proof outlets) are to have the circuit identification labelled by engraving with a contrasting infill colour on the faceplate of all power outlets and isolators in a permanently visible location. Such engraving is not permitted to be located on clip on faceplates / surrounds. If the entire faceplate is clip on then the label is to be provided as a screw fixed trefolite panel engraved with a contrasting infill colour mounted immediately above the outlet.
- Communication outlets are to have the circuit / channel identification labelled by engraving with a contrasting infill colour on the faceplate of all outlets in a permanently visible location. Such engraving is not permitted to be located on clip on faceplates / surrounds. If the entire faceplate is clip on then the label is to be provided as a screw fixed trefolite panel engraved with a contrasting infill colour mounted immediately above the outlet.
- All exposed labels and identification method are to be identical in type and style.

2.11 KEYING

Ensure all of the lockable enclosures provided as part of the electrical installation are keyed alike and keyed as part of the sites master key system. Where enclosures are required to be accessed by authorities, key the enclosure to the authorities' requirement.

2.12 INSPECTION AND WITNESSING

Allow for inspections and witnessing.

Arrange for and give sufficient notice so that inspection for approval may be at the following stages:

- Concealed conduits: Prior to concrete pours, etc.
- Cables laid: After laying underground cables and before and after laying protective covering and marker tape.
- Roughin: Cables have been installed in walls and the ceiling space before the like has been sheeted.
- Connection: Connection of cabling and wiring.
- Factory testing of all control panels and switchboards.
- Factory inspection of all custom-made components.
- Earthing: Installation and connection of earthing system.
- Acceptance: Installation ready for acceptance.
- Inspections required by Regulatory Authorities prior to their approval of the installation or its stages.
- All testing and commissioning.

To prevent an abortive factory visits the manufacturer is to provide written evidence, including appropriate certification, that testing has been carried out to the required specification prior to the factory visit. As part of the factory testing and commissioning all operational, functional and safety sequences are to be simulated and checked. Should the factory testing and witnessing have to be repeated due to the manufacturer failing to provide the required written evidence or appropriate certification and or failing to carry out the testing prior to the visit, the Electrical Sub Contractor is to agree to a variation credit of \$2,000.00 to the contract per repeated factory test.

The manufacturer is to undertake the following prior to the factory visit:

- Undertake all required tests and ensure that signed test sheets and relevant product documentation and certification are in place.
- Obtain copies of the latest design specification and drawings
- Confirm the 'as built' drawings incorporate the latest modifications to the design drawings.
- Wire external switches on a temporary basis to simulate operational conditions for testing. Note that external switches and pots can be connected for test purposes.

2.13 TESTING

Arrange for and give two weeks' notice so that, the tests may be witnessed for approval.

Undertake on site the following tests:

- Insulation resistance measurements: on motors and major medium voltage equipment items, at 1000-volt D.C.; on cables and wiring.
- Functional checks: Full functional and operational checks on energised control equipment and circuits, including adjustments for the correct operation of safety devices.
- Motor rotation: Checking and where necessary altering connections for the correct motor rotation.
- Earth resistance.
- Earthing: Confirmation of effective earthing of the exposed metal of electrical equipment.

During testing, replace fuses and equipment damaged as a result of incorrect installation work.

Provide all Test Results for approval within one (1) week of the test being undertaken on A4 paper and as an electronic PDF file copy on CD for approval.

Check control systems for correct operation under representative operational conditions. During the commissioning period these conditions may not arise because the building is unoccupied, and it is difficult properly to verify the performance of seasonal variations in control strategies. Control systems should therefore be checked when the building is occupied. In addition, illuminance cannot be checked until the space is completely fitted out and furnished. Representative operational conditions will often involve checks at dusk and/or night time.

The extent and frequency of post-occupancy checks should be included in the control system specification as part of the contract between the building owner and the construction supply chain and will depend on the nature and complexity of the control system. Lease documents should support any contractual requirements for post-occupancy evaluation and ensure that the leaseholder is required to provide reasonable access for their performance.

Post-handover checks comprise a continuation of functional checking relating directly to the lighting control system. Where a central control system is implemented, use should be made of its logging functions and the ability to display trend logs once it is confirmed that they are operating accurately.

2.14 COMMISSIONING

Commission all components of the electrical services to ensure the correct interfacing operation and control of all systems to the satisfaction of the engineer as per the approved commissioning method statement and commissioning plan. Arrange for and give two weeks' notice so the commissioning may be witnessed for approval.

Provide all necessary software, equipment and personnel to fully program and configure all systems to the satisfaction of the architect.

Following the completion of the commissioning and prior to Practical Completion thoroughly clean all components of the electrical installation to the satisfaction of the engineer.

Following commissioning, operate each component and system at the convenience of the engineer to the satisfaction to provide evidence to the engineer that each component and system is working correctly.

A record of all settings, set point and offsets should be maintained throughout the commissioning period and included in the operation and maintenance manual. Update the operation and maintenance manual record following the completion of each of the post practical completion commissioning requirements. The defects and liability period will not end until the operation and maintenance manual has been updated.

As part of the commissioning process ensure the following actions are completed:

- Check that time schedules enable the intended operation at the correct times.
- Check that any specified out-of-occupancy periods, weekend and holiday time schedules operate correctly (note that the current operating date can be changed to simulate weekend and holiday dates).
- Check that the specified routine to ensure unified time clocks throughout the complete control system operates correctly.
- Check that any specified summer/winter seasonal changes to control strategies are properly enabled.
- Check that the calendar function can take leap years into account.
- Check the correct operation of the interlocks by individually switching interlocked items of plant.
- Check all safety interlocks, e.g. electro-thermal links and emergency knocks off buttons etc.
- Check the specified interlocking between different control systems, for example any interlocking between a fire detection system and a BMS.
- Check that the specified temperature interlocks operate correctly, e.g. low temperature frost protection.
- Check for the correct sequencing control in response to varying inputs operates in the correct order and at the desired set points.

- Check for the correct control and operation on start-up and shutdown. Check that the defined restart routine operates correctly when power is reinstated after failure. Check for any specified sequenced start-up to accommodate high loads.

Check the control system to confirm its specified operation following a mains power supply failure. In particular undertake the following checks:

- Check that controllers preserve control strategy configuration data for a specified period when the mains power is lost.
- Check that the condition of any volatile data protection system is regularly and automatically monitored. Check that an alarm is raised on loss of data by any controller or other device and/or failure of the monitoring system.
- Check that the control system operates correctly under generator standby and UPS power if applicable,
- Check that the control system will automatically return to normal action without operator intervention restoration of the mains electrical power supply.
- Check that any specified load shedding procedures operate correctly.

Check the application software and certify quality control off-site. Specific items or routines to be checked include though is not limited to:

- Specified set points have been configured.
- Suitable on/off times are entered for all time schedules and are associated with the correct items of plant.
- In principle all interlocks are configured correctly.
- Life safety interlocks are hard-wired unless approved by the relevant authorities (must be performed on-site).
- Each control loop is in place and that realistic default values have been added to enable commissioning to proceed.
- Any sequence control is configured and in principle associated with the correct items of plant.
- Configured software will start-up and shutdown the specified items of plant in the correct sequence.
- The configured software will trigger automatic plant change over in response to the specified signal (plant failure or hours run etc).
- All specified alarms are configured along with any specified time delays, masking and alarm categorisation in order to avoid unwarranted alarms.
- The use of mnemonics and abbreviations is checked between the display and the graphics to avoid inconsistencies.
- Data logging routines and parameters are set up in accordance with the control system specification.
- The binding of graphics with monitored points.

The manufacturer is to check the switchboard at the factory. Specific items or routines to be checked include though is not limited to:

Visual outside

- The finish to ensure there are no sharp edges.
- The metalwork: hinges on doors, flush doors, opening and closing doors, no sagging or drooping of doors when open, interlocking of doors.
- The door seals and gland plate gaskets are in place and securely fixed.
- The common key for all panels.
- For secure operation of door locks.
- That safe access to the control equipment is possible without having to isolate the control panel where specified.
- That the physical arrangement of the panel will allow transport to site and mounting in the final location.
- If the completed panel weighs more than 50kg check that eyebolts are fitted.
- The location and labelling of switches and indicators (including colour).

- That plastic rivets or screws are used to mount labels.
- The scale of analogue devices and the status of digital devices.

Inside

- That all doors on any panel containing exposed dangerous voltages are provided with interlocking isolators so that the door cannot be opened except with the isolator in the 'off' position.
- That equipment that requires on-line adjustment and testing by non-electrically qualified personnel is accessible and usable without interrupting the supply or overriding the safety interlocks. (In general, outstations must not be located within control panels where isolation is necessary to gain access.)
- Access for incoming cables
- Access for outgoing power and control cables
- Provision of suitable gland plates
- All doors/gland plates to be earthed by cable links
- Bus bars and power cabling as specified
- Anti-condensation heaters and thermostats are included and correctly set where specified
- Ventilation grills, filters and fans and thermostats are included and correctly set where specified
- Panel ventilation is adequate for the heat load
- Tightness of all connections, bolted power connections and bus-bar bolts tightened to the correct torque
- Neatness of cable looms with no pinching
- Sufficient spare capacity in all cable trunking to comply with BS 7671(13).
- Colour coding and numbering of all cables where specified and corresponding with numbering of terminals.
- Numbering of all terminals
- Shrouding and labelling of non-isolated equipment
- Shrouding of switches, lamps etc on doors if low voltage
- Segregation of power cabling and switch-gear from control cabling and electronic equipment
- Trunking lids cross referenced
- Connections between panel sections are numbered as specified, accessible and physically simple to connect/disconnect.
- Link type terminals for control system cables if specified
- Spare fuses and fuse ways if specified
- Drawing holder
- Fuses (type and ratings) against fuse chart
- Layout of equipment against drawings
- Ensure spare back panel space is provided as specified
- Ensure no equipment is mounted on the bottom or sides of the panel (similarly terminations) unless back/side plates are fitted
- Labelling of equipment in panel
- Access to all equipment especially devices requiring adjustment
- Power outlet is provided complete with 30 mA RCD protection
- Flexible looms connecting door mounted to interior mounted components will not weaken or break with repeated door opening. Check that the loom is arranged to avoid pinching or looping when the door is closed and is fully supported at each end.
- Screen and earth connections associated with the control system equipment comply with the manufacturer's installation requirements

Typical starter/power circuit

- Fuse or circuit breaker frame size, trip unit type and settings against the drawings.
- Correct labelling has been provided.
- Energise the starter/contactors by 'making' the control circuit and ensure the starter operates correctly and that power is provided to outgoing terminals.
- Trip the starter and check that it de-energises and the trip indicator lights up.

All wiring is to undergo though not be limited to the following checks and testing:

- Cable type as specified
- Cable identified at both ends
- Cable cores identified at both ends if not self-numbered or colour coded
- Security of fixing/protection of cables to walls etc where surface-run
- Cable carrier/container in accordance with the specification (tray, basket, conduit/trunking etc)
- Cable management in accordance with the specification
- Cables not damaged
- Secure termination of wires (using ferrules)
- Screening continuity
- Cable only earthed at one end (field controller) or as specified
- Electrical continuity ('belling out')
- Correct polarity where applicable
- Correct input/output (by briefly disconnecting cable)
- Correct and secure termination
- Separation of mains and signals cables
- No short circuits line-to-line and line-to-earth
- Volt-free contacts are volt-free (prior to the installation of the field controllers).

Undertake including though not limited to the following on site communications network checks and tests:

- All network devices such as routers and bridges are installed correctly.
- All control devices can be addressed over the communication network.
- When used in conjunction with an office IT network ensure that permission has been granted from the IT manager. All network data routing is correctly set up by the IT department including allocation of the appropriate TCP/IP addresses and default router addresses.
- For structured cabling systems ensure that all outlets are properly labelled and assigned. Ensure that any changes to the cabling system are reflected in the updated documentation.

Undertake including though not limited to the following on site insitu field control devices (controllers, outstations and unitary controllers etc) checks and tests using NATA approved testing equipment:

- Type as specified
- Size as specified
- Enclosures as specified
- Number and location (height, access) as specified
- Adequate mechanical fixing
- Identification by mnemonic labelling
- All cables terminated and identified
- All terminals used (check that any unused terminals are intended to be spare)
- Continuous power available and of an appropriate quality
- Fuse correct type/spares if specified
- hardware configuration agrees with the specification
- All printed circuit boards in place
- All connection cables plugged in
- Document wallet containing wiring diagram where appropriate, i.e. when located in a control panel

2.15 TRAINING

Provide the operator with sufficient training such that they are capable of understanding how the system operates as a complete system and how the controls work as part of the system.

Beyond time spent during commissioning stage, at times to be agreed with the operator, instruct the operator's staff in the recommended methods of operation the electrical services. Allow to provide two such operational training sessions on site each for duration of 2 hours.

Provide the basic operator training such that following the training an operator with this level of training will have a basic understanding of the control system architecture and have the ability to view point data. It is not expected that the operator will make any alterations to the system. The basic operator abilities include;

- call up and view point data from schematics and/or points lists
- acknowledge system alarms
- view trend logs

In addition to the operator training above at times to be agreed with the operator, instruct the operator's maintenance staff in the recommended methods of operation and maintenance of the electrical services. Allow to provide two such operation and maintenance training sessions on site each for duration of 2 hours.

Ensure the maintenance staff training includes the following information:

- A review of the operations and maintenance manual.
- The types of luminaries used.
- The correct types of lamps to be used for each luminaire type.
- The correct type and location of all consumables used within the electrical installation. This is to include though not be limited to lamps, indicating lamps, fuses, surge protection devices etc.
- Advised maintenance cycles.
- Access for maintenance.
- The location of spares.
- The location of switches.
- Basic trouble shooting and fault-finding techniques.

3.0 INSTALLATION REQUIREMENTS

3.1 UNDERGROUND SERVICES

3.1.1 EXTENT OF UNDERGROUND SERVICES

The conduits and pits detailed within the electrical services documentation have been included as there are specific requirements that need to be accommodated do not cover every requirement necessary to complete the installation. Unless the conduits and pits detailed within the electrical services documentation have been noted as being for future use or for use by another trade it is acceptable to install the cabling for the initial installation through the conduits and pits detailed within the electrical services documentation. As the conduits and pits detailed within the electrical services documentation do not cover every requirement necessary to complete the installation the electrical-sub contractor must allow for all additional pits and conduits necessary to complete the electrical installation.

Under no circumstances are buried direct cables permitted.

Before excavating any public area including roads, footpaths, reserves, and the like, obtain the approval of the relevant authorities and comply with their requirements for alternative traffic arrangements, excavation methods, backfilling and reinstatement.

Restore areas outside the limits of the Works, which have been disturbed by the Works, to their original condition on completion of the excavation. Reinstatement surfaces to their original level without subsidence and without cracking at junctions with existing surfaces. Restore pavements to match existing. Regrass grassed areas.

Provide a reinforced plastic, 150mm wide, underground, yellow or orange coloured marking tape with the words 'WARNING - ELECTRIC CABLES BURIED BELOW' or similar above all underground conduits at a depth of 200mm below ground level for the entire length of all underground conduits.

3.1.2 TRENCHING

Unless noted otherwise provide all trenching, bedding, backfilling and reinstatement required to complete the electrical services.

Excavate trenches in sections of suitable length, lay and bed the relevant service length, and backfill the trench section, with the minimum of delay, and if possible, on the same working day, unless otherwise approved.

Provide all saw cuts in existing concrete or bitumen surfaces in a straight line to a minimum depth of 75mm before excavation is commenced. Lift and store paving slabs for later reinstatement.

Ensure all trenches are cleared of sharp projections.

Notify, and obtain approval from, the appropriate owner or authority before any excavation is commenced beyond the site boundary. Carry out the excavation to the owner's or authorities' requirements. Reinstatement the surface to match existing.

3.1.3 BORING

Where specified or required by the relevant authorities, provide under road boring, by an approved specialist in lieu of trenches. Make the bored dimension to ensure a tight fit. If voids are encountered, fill by pressure grouting.

3.1.4 CONDUITS IN TRENCHES

Install all underground conduits 500mm below ground level and provide each conduit with a spare polypropylene draw cord.

Provide a minimum surrounding of 75mm clean sand around cables and conduits installed underground.

Under roadways and areas subject to traffic movement, install cables in a duct or conduit extending to not less than 1m on either side of the sealed surface or trafficable area and encase in concrete with a strength of 20MPa having a minimum cover thickness of 100 mm.

Seal the buried entries to ducts and conduits with a pliable non-setting waterproof compound. Seal spare ducts or conduits immediately after installation, and seal the other after the cable installation.

Install all conduits either straight or with large radius sweeping bends with a radius 40 times the diameter of the conduit. All conduits must be installed in such a manner to allow simple removal and installation of additional cables following the completion of the project. In cases where multiple conduits have been specified, install all initial cabling within the first conduit. Written approval must be obtained from the engineer prior to installing any cabling in the subsequent conduits.

Where underground conduit rise above ground, ensure they rise vertically and they are protected at ground level by a concrete plinth extending 250mm below ground, 100mm above ground. The plinth is to extend in each direction beyond the conduits more than three times the diameter of the largest conduit other than the side of the plinth / conduit that is against a structure. Provide the plinth with a fall such that water does not pool against the conduit or the adjacent structure.

3.1.5 BACKFILLING TRENCHES

Backfill trenches as soon as possible after approval of laid and bedded service to the following:

- Garden areas: Backfill the top 150mm of the trench with topsoil.
- Lawn areas: Re-loam the top 150mm and returf trenches passing through existing lawned areas.

Remove all excess soil and fill from the site unless otherwise directed. Reinstall existing surfaces and assets disturbed or removed as a result of the excavations of trenching. Reinstall concrete surfaces to the original level using approved reinforcing steel, keyed to the existing and laid to prevent the reinstalled concrete from subsiding and cracking.

In existing bitumen surfaces camber the reinstated surface so that the edges are flush and the centre is 10mm above the existing pavement. Fill the top 150mm below the bitumen surface with mechanically compacted finely crushed gravel. Prime coat the existing bitumen edges of the trench with bitumen prior to laying 75mm minimum of hot pre-mix bitumen to the finished cambered surface. If it can be shown that hot pre-mix is not available, cold pre-mix will be accepted. Provide a written certification that the backfilling has been completed as specified and compaction completed such that the trench will not subside.

3.2 CABLES

3.2.1 INSTALLATION

Unless otherwise specified, install and terminate cables in accordance with the manufacturers' recommendations. Unless noted otherwise joints are not acceptable. Install power wiring utilising the loop-in, loop-out system with joints in cables being affected at outlets.

Ensure oil, wax and powder based electrical cable lubricants are not used as cable lubricants. If cable lubricants are required to be used then use polymer-based for copper cables and silicon-based for optical fibre cables.

Remove redundant equipment and wiring, including that in accessible ceiling spaces, and make good exposed surfaces before commencing the installation of new wiring.

Handle cables so as to avoid damage to insulation and serving or sheathing. Replace all wiring with insulation damage after determining and removing the cause of damage.

Identify multicore cables and trefoil groups at each end and at crowded intermediate points by means of stamped, non-ferrous tags, clipped around each cable, or trefoil group.

Install and adequately support fixed wiring as specified throughout the installation. In accessible false ceilings, keep cables clear of all ceiling insulating material and/or removable ceiling tiles by securely fixing the cabling to permanent structural members. If the structural members are more than 1,200mm above the suspended ceiling, provide a catenary support system. It is not allowable to fix cables to the ceiling hangers.

Provide flexible connections or an approved form of vibration/movement isolation on the terminations of all cables that will experience vibration or movement under their normal operation.

Cable installation in areas where there are motors and/or generators shall comply with the guidelines set out in AS/NZS 3548 and AS/NZS 2834.

3.2.2 GENERAL CABLING REQUIREMENTS

The terms wiring and cabling are used interchangeably throughout this contract to refer to any cabling types and relevant standards.

Ensure all of the electrical services cabling comply with the following requirements:

- All cables are installed without joins.
- All cabling is concealed from view.
- All cabling installed externally is installed in conduit.
- All cabling that is installed in locations that are not concealed such as on exposed roof trusses, are to be run in conduit.
- Cabling fixed to trusses and beams in concealed ceiling spaces is to be fixed to the side of the truss / beam and not on top of the bottom cord of the truss / beam.
- Chasing of masonry walls is co-ordinated with other trades. Horizontal wall chases must be approved.
- Coordination of the installation of conduits and cables in the ceiling space does not interfere with the operation or maintenance of any equipment.
- Cables do not come into contact with hot water pipes.
- Above suspended ceilings, all conduits and cables are secured to the ceiling support members or roof structure above. Conduits and cables laid directly on the ceilings (on the ceiling suspension system or framing) are not acceptable.
- All cables in underground conduits are approved by the manufacture for external underground use.
- Enclose cables from above down to switches, outlets and equipment in conduits where the equipment is installed on single leaf masonry walls or concrete walls. TPS power cables where installed in cavity walls may be unenclosed within the cavities, unless otherwise detailed.
- Cables are secured to prevent any strain on the cable terminations. Support cables at a maximum of 1200mm spacing with minimum sag.
- The use of spring clips will not be permitted without approval.
- Do not install double insulated cables in locations where they cannot easily be withdrawn for rewiring purposes. Where double insulated cables are installed in accessible locations such as cavities, stud partitions and the like, do not clip or secure the cables such that they cannot be withdrawn.
- Double insulated cables are installed in conduits where they are installed within cement render, masonry walls or concrete slabs.
- External cabling is installed underground where installed between buildings, connecting signs, luminaries and the like.
- Catenaries are provided between cable trays and access conduits.
- Where cables traverse areas above set plasterboard ceiling (or similar) particularly in an office environment and providing access difficulties, use conduit secured to a catenary wire, or suitably saddled to the ceiling.
- Support all horizontal cabling via a dedicated catenary, cable tray, cable ladder, or via a structurally secure cable support system specifically installed to support cabling. All cable support systems must

be submitted for approval. It is not acceptable to use double sided tape, stick on hangers to support cables or to support cables from the ceiling support system or any other services support system.

- All cables entering wall cavities are to enter vertically above the outlet position and the access into the cavity allows for simple withdrawal of the cable and the simple installation of a second cable of equal size.
- Do not run cables horizontally through walls. Where such runs are necessary, (half height walls), use corrugated conduit to facilitate the cable run to the outlet or switch. Indicate the extent and location of all cables reticulated horizontally through walls.
- All cables passing through a metal surface, any sharp surface or any surface that could damage the cable insulation over the life of the installation is to be protected by grommets nylon bushes.
- Replace all wiring that contains kinks or abrasions.
- Provide all final connections from the wall box or isolator in flexible smooth wall PVC conduit to equipment. Enter the isolator with flexible conduit from the underside thus forming a drip loop and neatly install such conduit to minimise retention of grease, etc.
- The cable sizes indicated on the drawings are provided as a minimum only. The current capacity, voltage drop and fault capacity of the cables must be established by the Electrical Sub Contractor and the cables sized accordingly by the Electrical Sub Contractor. Size all cables to accommodate the respective loads, starting currents and maintain a spare capacity of 10%. All loads and fault levels must be confirmed on site by the Electrical Sub Contractor with the actual equipment being supplied.
- Unless otherwise approved, terminate copper conductors to equipment, other than small accessory and luminary terminals, by means of compression-type lugs of the correct size for the conductor, compressed only by the correct tool.
- Loom and lace together, with PVC straps, all conductors from within the same cable or conduit from the point of cable sheath or conduit termination to the terminal block. Neatly bend each conductor to enter directly into the terminal tunnel or terminal stud section, allowing sufficient slack for easy disconnection and reconnection.
- Provide flexible connections on the terminations of all cables that would experience sufficient stress/force under a bolted line fault condition that would cause damage to the cable termination or the equipment.

Provide mechanical protection of all cables in the following locations:

- Within 2,400mm of any floor, platform or landing that is accessible under normal operation and routine maintenance.
- All locations it is reasonable to expect that the cabling would be interfered with.
- All locations the cable could be subject to damage during normal operation and maintenance.

Provide all power and lighting cabling in accordance with the following:

- All T.P.I and T.P.S power and lighting wiring is to utilise stranded copper conductors with a minimum size of 2.5 mm sq. with 0.6/1kV V90 PVC insulation.
- Provide PVC free cables as low smoke zero halogen with X-HF-110 insulation.
- Provide PVC insulated cables with 0.6/1kV grade PVC compound, type V-75 or higher insulation.
- Provide PVC insulated and sheathed flat cables and single double insulated cables up to 16mm with 450/750V grade PVC compound, type V-90 insulation and sheathing.
- Provide PVC insulated and sheathed circular cables with 0.6/1kV grade PVC compound, type V-75 or higher insulation and sheathing.
- All low voltage and extra low voltage (32Vac or 115Vdc maximum) circuits and/or fire services are to be provided with different colour sheathing.
- Provide XLPE insulated and PVC sheathed cables with 0.6/1kV grade XLPE compound, type X-90 insulation, and PVC sheath.
- Provide all flexible cords as ordinary duty 250/440V rated with V-75 PVC insulation and PVC a sheath.
- Use white insulation for all TPS power cabling. For all cables supplying essential equipment use fire rated approved cables.
- Ensure all power and lighting wiring and cabling utilises stranded copper conductors.
- Ensure all wiring is provided and installed in such a manner that its installed overload rating exceeds the overload rating of the protective device.
- For fixed power wiring, colour the conductor insulation or, if this is not practicable, slide not less than 150 mm of close-fitting coloured sleeving to each conductor at the termination points as follows:

Active conductors in single phase circuits: RED.

Active conductors in polyphase circuits:

- A PHASE - RED
- B PHASE - WHITE
- C PHASE - BLUE

Run consumers mains and sub-mains in dedicated conduits and ensure there are no other cables in the same conduit as the consumer's mains or sub-mains.

3.2.3 SETTING OUT OF RETICULATION

The routes shown on the Drawings are approximate only. Determine the final routes to suit the building structure or site conditions. Obtain approval for the final routes prior to installing consumers' mains and sub-mains. Unless otherwise specified, conceal and protect cables and conduits. Arrange cables and conduits parallel with walls, ceilings and floors. Provide the main switchboard with a diagram indicating the route of any underground consumers' mains, printed on a durable card or similar, and indicating run distances for each 'leg' of the consumers' mains route.

3.2.4 WIRING IN CONDUIT

Complete and permanently fix the conduit run before installing the wiring. Use draw wires to pull in the conductor groups from outlet to outlet. For vertical conduit runs in excess of 15m make adequate provision for supporting the weight of the wiring to avoid insulation damage. Run circuits originating at different distribution boards in separate conduits.

3.2.5 TERMINATIONS

Terminate all cables installed as part of this contract. It is the Electrical Sub Contractor's responsibility to check and ensure the component or equipment the cable is being terminated to be appropriate and suitable for the cable to be terminated to. Advise the architect of any concerns with the component or equipment prior to the cable being terminated.

Where core identification is required, fit to each core durable numbered ferrules permanently engraved with numbers and/or letters to suit the specified connection diagrams. Terminate and identify any spare cores into spare terminals, if available; otherwise neatly insulate and bind the spare cores to the terminated cores.

Insulation displacement terminations or connections are not acceptable for 240-volt cabling. All 240-volt terminations must be screw type.

3.3 CONDUITS

Ensure all conduits installed as part of the electrical services are installed in accordance with the following requirements:

- Conduits are sized to permit drawing-in of cables to finished conduit runs without damage to cables.
- Protect all PVC conduits against UV exposure.
- Steel and galvanized conduit are not installed underground.
- Rigid UPVC conduit fittings are fastened to the conduits by fresh solvent cement in accordance with the manufacturer's recommendations. The cement is to be a contrasting colour to the conduit.
- Corrugated UPVC conduit fittings may be fastened with solvent cement as above or by use of snap-lock connectors in accordance with the manufacturer's recommendations.
- Flexible smooth wall PVC conduit fittings of the black nylon conduit clamp band type are provided.
- Conduits, pipes and conduit fittings are not visible on any wall, floor or ceiling surface with the exception of Switch rooms, Plant rooms and risers.
- Installation of conduits enables wiring to be drawn in and out at any future time without damage to the building and cabling and without disruption of the conduit continuity.
- Only conduit, deep draw-in boxes and couplings are to be cast in concrete. Do not cast conduit tees and elbows in concrete.

- Constant supervision at all times is provided when concrete containing conduits is being poured.
- Conduits passing through expansion joints are provided in concrete slabs with approved flexible expansion couplings.
- Conduits with expansion joints are provided as required to accommodate the expansion of the conduits and the supporting surfaces with a minimum of an expansion joint in straight runs at intervals of no more than 12,000mm.
- Unless noted otherwise provide conduit located internally as PVC light duty (LD), high impact rigid, minimum size being 20mm circular. Corrugated PVC conduit shall not be used unless approved.
- Unless noted otherwise, provide conduit located externally as PVC heavy duty (HD) conduit and stamped "underground" type.
- Conduit adaptors are lock nutted into metal wall boxes or welded into PVC boxes.
- Conduits, fittings and welding solution of the same manufacture are used.
- All change directions of conduits are set. Undertake setting by warming the conduit and bending around an internal spring. Ensure burn marks are not visible as a result of warming. Cold bending is not permitted. Secure conduits within 50mm of each change in direction.
- Secure 40mm or larger conduits every 500mm or less. Secure conduits less than 40mm every 300mm or less.
- Conduit ends above ceilings at right angles are set in the direction of the cable run.
- Conduit ends are cut square and free from sharp edges, burrs, and the like.
- Where subject to mechanical damage, exposure to sunlight, weather and/or damp conditions and/or ambient or contact temperatures exceeding 60 degrees Celsius, use heavy duty galvanised screwed steel conduit. Provide mechanical protection to UPVC conduit for a height of not less than 3m above ground or platform level.
- Where PVC conduit is embedded in concrete which is screeded or vibrated after pouring, or where conduits may be subjected to heavy traffic prior to concrete pour, provide constant supervision by a tradesperson to ensure that conduits are not damaged.
- All conduits are installed in concrete slabs above the bottom layer of reinforcement and securely tied in place. Boxes are firmly fixed to the formwork.
- Groups of conduits in slabs are separated by a distance equal to the diameter of the conduit/s. Obtain approval prior to installing conduits greater than 40mm OD in concrete slabs.
- Proprietary sealing caps (or aluminised flashing tape if sealing caps are not manufactured) are fixed to all conduit ends prior to the commencement of pouring of slabs, laying of bitumen, gravel, and the like and are to remain in position until the conduits are finally terminated.
- All conduits cast into a concrete slab, protrude perpendicular 100mm above the surface of the slab and are located as close as practicable to a wall.
- Prior to the installation of wiring, ensure conduits are clear of debris and liquids.
- All underground electrical conduits and conduits/pipes for special services (including spares) are sealed internally to approval at switchboards and/or at special services enclosures and where entering buildings to prevent the ingress of water.
- Metallic saddles with corrosion protection equal to hot dipped galvanizing with two galvanized fixings per conduit saddle are used to secure all surface mounted conduits. Do not use explosive-powered or similar equipment unless approved. Ensure the metallic saddles and fixings do not create a galvanic reaction with the support structure. In locations it is not practical to use saddles, submit details of the proposed conduit securing method for approval prior to commencing installation of the conduit. Any alternative conduit securing method must provide corrosion protection equal or better than galvanizing.
- UPVC conduits installed in accessible roof spaces and the like are protected by timber battens.
- Up to the commercially obtainable conduit lengths of run, conduits are installed without joints. Remove all jags, burrs, and sharp edges from each length before completing each conduit joint. Fit moulded plastic screwed bushes to the free ends of metallic conduit runs before installing the conductors.
- All inspection fittings and the like are accessible.
- Draw-in boxes are provided at suitable intervals not exceeding 30m in straight runs, and at intervals not exceeding 25m in other runs including directional changes.
- Conduits are not run in topping slabs unless approved.
- After removal of sharp edges, burrs, etc., ends and joint threads of steel conduits are painted with a rust-inhibiting metallic paint, which maintains conductivity.
- Standard size wall boxes of the same material as the conduit are used. Where special size boxes are specified and where such boxes are not obtainable in UPVC, use pre-fabricated metal boxes.

- Galvanised steel water pipe may be used for cable enclosures buried in the ground or run in concrete trenches or the like. Seal joints against the entry of water or moisture. Associated fittings will be either galvanised steel, cast iron or approved non-ferrous metal.
- Round off sharp edges and provide PVC bushes or the like for cable entries into metallic ducting.
- All conduits and ducts on cool room panels are mounted on 25mm stand offs.
- Arrange conduits below 2,700 AFFL such that a person cannot hang from or climb from the conduit by using the conduit as a foot hold or hand hold.
- All PVC conduits located externally above ground to a height of 2,000mm AFFL are protected with 1.6mm thick folded galvanised sheet steel hat section. Galvanized conduit may be substituted in the above ground location in lieu of the PVC conduit and steel hat section.
- Where the conduit is in an exposed location, paint the exposed conduit and hat section to match the building colour.
- All conduits are installed such that any moisture in the conduit drains away from the electrical connections. Where required provide the conduits with weep holes and drip loops.
- All conduits are installed and sealed such that insects cannot nest or seek refuge in them.
- All conduits are sealed such that the sealant can be removed in the following locations to prevent vermin and moisture entering through the conduits:
 - Conduits passing between different functional parts of the building such as food preparation areas, plant rooms, service areas and public areas.
 - Conduits passing between levels.
 - Conduits entering or leaving the building.
- Do not use conduits smaller than 20mm diameter in any circumstance or conduits smaller than 25mm diameter underground.
- Do not use light duty (MD-UPVC) conduit underground or where it may be exposed to mechanical damage or to sunlight.
- Ensure all associated plastic conduit fittings are of the same material as the conduits.
- Install conduits so the installation can be wired using the 'draw-in loop-in' principle.
- Provide power circuit conduit s so the power circuit wiring is drawn in only at outlets and the initial conduit entry point.
- Install conduits directly from the entry point to the termination point, with the minimum number of sets ensuring the number bends does not exceed the equivalent of 3 x 90-degree bends.
- Do not install elbows, tees, etc. in inaccessible locations.
- Cap all conduits during construction.
- Do not run conduits in roof spaces directly below the thermal insulation or sisalation.
- Do not run conduits in roof spaces or ceiling spaces directly on top of the ceiling.
- Provide deep pattern wall boxes securely fixed such that the front edge of the box is no more than 10mm behind the wall finish.
- Do not install wall boxes across the junction between different wall finishes.
- Provide all plastic wall boxes with threaded brass inserts for securing the flush plates.
- Do not use wall boxes with sliding type lugs for attaching flush plates.
- Earth all metal wall boxes.
- Run conduits within concrete slabs such that they are securely fixed to the reinforcing rods and pass above a single layer of rods or between a double layer of rods, generally midway in the thickness of the slab.
- Space parallel conduits within concrete slabs more than 75mm apart.
- Arrange conduits within concrete slabs such that cross overs are avoided and the number of conduits in one location is kept to a minimum.

Rectify all damage caused by flooding or vermin ingress that has occurred as a result of the conduits not being correctly sealed. Any such damage post practical completion is to be considered a latent defect and must be rectified as such.

3.4 PENETRATIONS

All penetrations that exit the building are to be waterproofed.

Seal all penetrations in a neat and tidy manner in such a way that the sealing material can be removed to allow future use of the penetration. Ensure all penetrations are sealed to at least the original integrity of the member or structure being penetrated. Provide independent certification of all fire rated and sound rated penetrations. Do not penetrate fire rated finishes, structural members, acoustically rated finishes or damp courses without approval. Run pipes entering a building at ground level under the waterproof membrane and vertically penetrate the membrane and the floor slab. Provide a suitable seal between the pipe and the roofing material.

Fit a UPVC sleeve for each penetration through ground floor slabs, ground floor beams and external walls for cables not enclosed in conduit. In addition, for MIMS cables fit a sleeve for each masonry penetration. Provide a penetration of diameter 10mm greater than the pipe or sleeve diameter for pipes and sleeves penetrating existing external walls, ground slab, or ground floor beams.

Fireproof all penetrations through fireproof walls or floor slabs, irrespective of size, upon completion of installation of cables. Provide fireproofing by fixing a suitable galvanised sheet metal cover (minimum thickness 1.6mm) around the cables on both sides of the wall and underside of slab, pack space with fireproof material. Provide independent certification of the rating of all penetrations through fire rated members. Fix plastic grommet around metal edges bearing against cables. Paint sheet metal covers to match surrounding areas.

Provide all electrical penetrations into refrigerated enclosures as rigid conduit extending a minimum of 50mm beyond each side of the refrigerated panel. Seal inside and outside of the refrigerated panel around the conduit with Sikaflex. After the cabling has been installed, seal around the cable within the conduit with Sikaflex. Ensure all penetrations into outlets, switches and fittings within refrigerated enclosures are waterproof.

In all locations where, underground conduits pass under a building or structure, provide flexible conduit with a smooth interior for 300mm each side of the transfer to accommodate movement of the building or structure. All such conduits are to be similar to Vindex Coreflow conduit.

Provide all outlets and switches flush mounted within floors, walls and ceilings that have an acoustic or fire rating with additional protection to achieve the same acoustic and / or fire rating as the base structure. Provide a copy of an independent certification for approval of the additional protection that the required acoustic and /or fire rating is achieved with the installation method and components employed. Provide a copy of the certification in the maintenance manual and indicate the location of all such additional protection installations on the as build documents. Surface mounted wall blocks are not acceptable as methods of achieving the required rating if the outlet / switch has been specified as flush. If additional furring channel and or wall / ceiling sheeting is required that is not part of the base design all such additional materials must be included as part of the tender price.

Provide ceiling roses or flush faceplates with a cable gland to trim all cables penetrating a wall or ceiling that are to be connected to equipment that is bracket mounted that does not inherently accommodate concealed cabling.

3.5 ACCESSORIES AND FITTINGS

Provide all accessories and fittings in accordance with the following requirements:

- All switches and outlets provided are of a like appearance, flush set sized at 115 x 70mm.
- Switch flush plates are mounted with the 115-dimension orientated vertically. Outlets are mounted with the 115-dimension orientated horizontally.
- All accessories shall be flush mounted rocker action type. Use red switch toggle marker 'dots' on GPO's but not on light switches. Provide accessories as white in colour unless specifically detailed otherwise.
- Flush plates are installed plumb and fit hard against wall surfaces. Wall boxes are used for masonry and concrete walls and proprietary mounting accessories for "stud" type partition walls.
- Switches and power outlets in exposed locations and in areas such as plant rooms and car parks are provided as IP56 rated light grey in colour with one piece covers where available.

- All wall boxes specified for future use are provided with blank flush plates.
- Instructions for final positions of all outlets and switches are requested at least ten working days in advance.
- Relocation of outlets and switches is allowed for at a maximum of 1.5m without additional cost, providing chasing is not required.
- Outlets, switches and accessories are installed to suit tiling and surrounding fixtures. The mounting heights shown on the electrical services drawings shall be taken as indicative only.
- All accessories are to be flush mounted installed in wall boxes.
- Supply of all outlets mounted within the joiners or nominated as being mounted below bench via surface duct run within the joinery is allowed for. Allow to mount all such outlets on surface mounting blocks. Coordinate the location of the duct and the outlets on site with the joinery. If the installation permits counselled cabling and flush mounted outlets do not install the surface duct or mounting blocks.
- All suspended equipment provided is mounted off a raked ceiling with an adjustable ceiling mounting such that all suspended equipment hangs vertically.
- All fittings and accessories installed in refrigerated rooms and enclosures must be non-ferris.
- All mechanisms and blank mechanism fillers are to be screwed fixed in place on the rear of the faceplate.
- Use fastenings that are of the same or more corrosive resistant material than the materials fastened, of a minimum number of varieties and sizes, and suitable for fitting with commonly available tools. Lubricate screw threads with long life lubricant.
- Provide washes under all nuts.
- Ensure fastenings subject to vibration are locked tight.
- Do not use self-tapping screws where periodic dismantling is required.
- Use bolts and set screws with hexagonal or Allen-keyed heads.
- Use blind rivets of the pressure tight type. Do not use Imex. rivets where they may be loaded in tension.

3.6 EARTHING

Provide a comprehensive earthing system throughout the project addressing all aspects of the structure, all services, all systems and components in addition to those forming part of the power distribution.

Provide earth electrodes as 19mm diameter of either copper or steel rod copper clad and will incorporate integral driving heads and points. Stainless steel rods grade 302 is also acceptable. Install earth electrodes vertically. Electrodes may be driven direct into the ground or installed in holes previously drilled and packed with suitable conductive graphite slurry. At ground level cover the rods with fibreglass reinforced concrete pits with appropriately embossed or stamped lids flush with the surrounding ground. Bond all exposed metallic parts or components in the project (i.e. conduits, frames, water pipes, enclosures, light fittings, sinks, cable sheaths, cable trays, skirting duct, partitions and the like) by means of adequate clamping/fixing. Where allowed by the supply authority, provide the earthing system as a combined earthing system.

Where electrodes are to be installed in rock, fill the gap between the rock and electrode with bentonite clay or resin compound or as otherwise approved. Where electrodes are to be installed in corrosive soil, install each electrode in a 200 mm bore hole, backfill with a conductive metallic grouting compound and compact with a vibrator.

Run a PVC-insulated copper conductor from the main switchboard earth bar to the slab reinforcing mesh. Clamp conductor to mesh (one point of contact only required) with a brass earth clamp. Wrap clamp and exposed copper conductor with insulation tape. Provide a label engraved 'Slab Reinforcing Mesh Bond' adjacent to the termination on earth bar.

Copper conductor is to penetrate slab inside building enclosure and be such as to avoid moisture penetration to slab reinforcing mesh.

Bond the electrical earth to all piped services (if metallic pipes) at the closest practical point to where these piped services enter the building. This includes cold water, hot water, soft water, steam, condensate return, waste, medical gases, suction and the like. The bonding earth conductor to be 6 sq. mm minimum.

3.7 ACCESS

In non-habitable locations such as plant rooms and store rooms provide cable access to surface mounted electrical equipment such as switchboards, control panels, intruder detection panels and communication equipment by surface mounted PVC or metal duct. Provide the duct with a removable lid of lengths not exceeding 1,200mm and arrange the duct such that it runs square with the building. Silicon seal between the duct the wall, the floor and the ceiling. Cover all conduits entering through the floor with such duct. Where the duct abuts the boards/panels provide neat cut-outs free of burrs in the duct and boards/panels to allow cable access. Where the duct does not adjoin the boards/panels provide cable glands in the duct and the boards/panels for all cable access. Ensure all of the cables run within the duct are supported vertically and horizontally to the cable manufacturer's requirements and as a maximum such supports are not to exceed 1,200mm. Provide or paint the duct to match the wall colour.

3.8 CATENARY SUPPORTS

Provide catenary supports in accordance with the following requirements:

- Use catenary wire as a minimum as seven strands galvanised steel wire.
- Catenaries are anchored and supported to the ceiling slab or structural members and tensioned by way of 2 wire clamp turnbuckles fixed in place by Dynabolts with a minimum size of 6mm.
- Where the cable loading is excessive for catenary wire or saddled enclosures, use tray/ladder.
- Catenary wire is supported by jack chain or similar at distances of no more than 3 metres. Do not use ceiling hangers as support for catenaries or cabling.
- Where cables leave a catenary, they must be supported in PVC conduit and/or PVC ridged and/or flexible conduit and/or an additional catenary and then the conduits. The conduits will be fastened to the catenary and then at every change of direction in a workmanship like manner. Corrugated conduits should not lay about in ceiling spaces.
- Attach an earth to the catenary with a 2-screw tunnel type connector.
- Catenary wire systems must installed be true to the building line in such a manner that they are not interfered with or in contact by the structure or any other service.

3.8.1 CATENARY WIRES

- Catenary wires shall be minimum 3.0mm diameter galvanized stranded steel wire, sized to carry the cable weight and shall be supported at regular intervals, not exceeding 3000mm, from structural components.
- The maximum deflection for loaded catenaries shall not exceed 150mm.
- All fixings, anchors and supports for catenary wires shall utilize metal fasteners.
- Cables shall be tied to catenary wires at maximum 900mm centres over the entire length, using proprietary nylon cable ties.

3.9 CABLE LADDER AND TRAY

Bolt the tray/ladder to single sided brackets for horizontal runs and roll steel channel in vertical runs. Provide cable tray as rolled or folded steel at least 1mm thick galvanised prior to delivery or from extruded structural grade aluminium with a thickness not less than 1.5mm. Use cable ladder with cable support rungs between the two rails spaced at intervals of not more than 300mm. Each adjacent length of the cable tray is to be bolted together.

Use tray/ladder 150 mm, 300mm, 450mm or 600mm wide. Provide bends, connectors, trays, ladders, brackets, and other support necessary to make a complete cable or conduit support system of the same manufacture, sized to adequately support the installed cabling.

Provide cable ladder with a cable contact area of less than 10% for power cables required to be supported on tray/ladder. Provide perforated cable tray for all non-power cables required to be supported on cable ladder or tray. Use tray that has slots that on both the normal and reverse sides there are no burrs or sharp edges. All trays and ladders must be galvanised after manufacture, prior to delivery to site.

Do not run cables with an outside diameter smaller than 13mm on cable ladder unless supported at intervals not exceeding 100mm. Slots or ladder rails will be considered suitable for fixing cable ties, strapping or saddles. Ensure all bends have a minimum inside radius of not less than twelve times the outside diameter of the largest diameter cable carried. Provide sufficient space on the tray or ladder for not less than 50% more cables or conduits than specified.

Position the tray/ladder to give adequate access for inspecting, replacing, or adding cable. Fix cable to the tray/ladder by proprietary nylon ties, straps or saddles, at 1000 mm centres for vertical runs and 2000mm centres for horizontal runs. Provide a slightly curved support surface under cables leaving the tray/ladder to protect the cable sheath from impingement by the tray/ladder edge.

Where the tray/ladder is exposed, provide a cover over the tray/ladder. Provide the cover as removable galvanised sheet steel screw fixed to the tray in lengths that allow it to be safely removed by a single person. Ensure the cover is installed in a neat manner without undue gaps and is free from burrs.

3.10 CEILING SUPPORTS

Provide termite resistant plywood support to all components mounted within lay-in ceiling tiles such that the weight of the component and any associated control gear is supported on the ceiling grid and not on the tile. Provide all necessary T Bars and cut tiles required to accommodate the installation of all components mounted within suspended tile ceilings. Provide all necessary additional structural supports and T Bar rails to mount the fittings and support the plywood support. Provide all cut-outs in set plaster ceilings and modify the structural support of the ceiling where necessary to accommodate the cut-out.

3.11 MOUNTING REQUIREMENTS

As part of the electrical-sub contract works allow for all necessary mounting brackets, fixings, trims, cut-outs, block outs and any other incidental component that will be required to complete the electrical installation. Provide a shop drawing of all such components including how they are mounted for approval.

Fittings and components that have any moving parts or weigh more than 2.5 Kg's that are fixed to the lined ceiling or walls must be provided with independent support system connected to the structure.

4.0 POWER DISTRIBUTION

4.1 SCOPE

The power distribution component of this contract includes works within three separate areas being the Prep School, the Middle School and the Senior School.

The Prep School power distribution works include:

- The existing circuits supplied from the MSB-P integral distribution board MDB-P are to be resupplied from the existing distribution board DB-PL with new switchgear and controls reflecting the existing in capacity and function allowing MDB-P to be removed.
- The supply to the existing prep school distribution board DB-PS2 from MSB-P is to be removed and DB-PS2 is to be supplied from the adjacent DB-PS1.
- The supply to the existing prep school distribution board DB-PN from MSB-P is to be removed and DB-PN is to be supplied from the distribution board DB-PA on the level above.
- The existing 630 Amp chassis in MSB-P is to be replaced insitu with a new 630 Amp chassis that can accommodate 6 x 160 Amp MCCBs and 2 x 250 Amp MCCBs. The remaining 5 existing 160Amp MCCBs and associated submains are to be reconnected to the new MSB-P chassis.
- The existing underground pit and conduit system is to be extended to provided cable access from the MSB-P to the crawl space under the Campbell Centre. A new cable ladder is to be provided through the crawl space under the Campbell Centre to connect the cable access from the conduit to the new MDB-C.
- MSB-P is to be provided with a new 250 Amp MCCB to supply the new MDB-C via a new submain.
- The existing distribution board in the Campbell Centre is to be replaced with a new switchboard MDB-C which is to incorporate a new DB-C to accommodate the existing Campbell Centre circuits. All of the existing Campbell Centre circuits are to be reconnected with new switchgear and controls reflecting the existing in capacity and function.
- MDB-C is to be provided with MCCBs to supply a new distribution board in the new prep building DB-P and a new mechanical services switchboard in the new prep building MSSB-4 via new submains.
- The two existing submains from the Goodwin DB to the mechanical services condensers on the southern side of Goodwin are to be removed. New submains are to be provided from the existing circuit breakers in the Goodwin DB to the relocated mechanical services condensers.

The Middle School power distribution works include:

- The existing switchboard MDB-M including all incoming and outgoing submains are to be removed.
- MSB-M is to be provided with a new 200 Amp MCCB to supply the existing Goodwin distribution board via a new submain run through the existing conduits.
- MSB-M is to be provided with a new 63 Amp MCCB to supply the existing Donaldson distribution board run through the existing conduits.
- MSB-M is to be provided with a new 300 Amp MCCB to supply the new DB-SC via a new submain run through the existing conduits.
- The existing distribution boards (DB-A and DB-K) in School House are to be replaced with a new switchboard DB-S B-C which is to incorporate new distribution chassis to accommodate the existing School House circuits. All of the existing distribution boards (DB-A and DB-K) in School House circuits are to be reconnected with new switchgear and controls reflecting the existing in capacity and function.

The Senior School power distribution works include:

- Removing the existing tuckshop MCCB and submain from MSB-S.
- Replace the existing spare 160Amp MCCB in the right-hand chassis with a new 250 Amp MCCB. Remove the cable and fuses connected to the existing spare 160 Amp MCCB. Use the new 250 Amp MCCB to supply the new DB-1 via a new underground submain.
- Provide a new 250 Amp MCCB opposite the DB-1 MCCB and use it to supply the new MSSB-1 via a new underground submain.
- Supply a new DB-K via the new DB-1.
- The supplies to the Norman Creek Bridge and Smith Field are to be maintained at all times.

The existing electrical services to the Norman Creek Bridge and Smith Field are to be identified and all necessary works undertaken to ensure these serves are maintained at all times during darkness and during school hours.

All interruptions to the power supply to the remaining existing facilities external to the building must be constrained between 12.01am and 5.00am. The school must be provided with two weeks written notice of any potential interruption to the power supply to the existing facilities.

All existing services effected by the works that remain are to be reconnected in such a manner and with timing that the operation of the school is not adversely affected.

All of the existing electrical services that become redundant due to the works are to be removed.

Power is to be reticulated from the distribution boards as required to equipment isolators and to outlets via final sub circuits.

The power distribution component of this contract includes, but is not limited to the following extent of work:

- Power distribution.
- Earthing.
- Switches, Outlets, Isolators and Accessories.
- Clocks.
- Modifications to the existing switchboards as required.
- Modifications / redirections to the existing circuits and submains as required.
- New Distribution boards MDB-C, DB-1, DB-K and DB-P.
- Removal of MDB-M and all associated cabling.
- Submains.
- Cable access.
- Conduits and pits.
- Trenching and reinstatement.
- Cable ladder.
- Final sub-circuits.
- Connection to equipment.

Provide written advice to all associated contractors and sub-contractors of the following information where switchboards and control panels are supplied outside of the electrical services and are provided with power by the electrical services: Provide a copy of such advice for approval and provide a copy of each piece of advice within the operation and maintenance manual.

- Upstream protective device size and configurations.
- The fault level at the final point of termination.
- The cable size, type and configuration.
- Control and interface configuration and requirements.

Provide a sample of each type of switch and outlet. Provide shop drawings of all switchboards, distribution boards, load centres, metering panels and control panels. As part of the tender submission the Electrical Sub Contractor must include for all contractual requirements and costs required by the suppliers to the electrical sub-contract to provide the necessary samples. The Electrical Sub Contractor must bear the cost of supplying samples of the components specifically specified as well as those specified generically or by performance.

All suppliers and sub-contractors to the Electrical Sub Contractor must ensure they are familiar with and comply with the requirements of sections 1.0, 2.0 and 3.0 of this specification

4.2 INSTALLATION

4.2.1 SWITCHBOARDS

Ensure all switchboard enclosures are appropriate for the location they are intended to be installed in and have appropriate space and capacity to contain all equipment and cabling in the final configuration.

The switchgear sizes indicated on the drawings are provided as a minimum only. The current capacity and fault capacity of the switchgear must be established by the Electrical Sub Contractor and the switchgear sized accordingly by the Electrical Sub Contractor. Size all switchgear to accommodate the respective loads, starting currents and maintain a spare capacity of 10%. All loads and fault levels must be confirmed on site by the Electrical Sub Contractor with the actual equipment being supplied.

All switchgear throughout the entire site is to be of the same manufacturer. All miniature circuit breakers are to be compact DIN style DIN rail mounted circuit breakers.

4.2.2 OUTLETS AND ACCESSORIES

The outlet and accessories sizes indicated on the drawings are provided as a minimum only. The current capacity and fault capacity of the outlet and accessories must be established by the Electrical Sub Contractor and the outlet and accessories be sized accordingly by the Electrical Sub Contractor. Size all outlets and accessories to accommodate the respective loads, starting currents and maintain a spare capacity of 10%. All loads and fault levels must be confirmed on site by the Electrical Sub Contractor with the actual equipment being supplied.

Ensure all electrical connections to equipment other than light fittings and control panels or switchboards with integral isolators are via a switched outlet or a switchable isolator. Provide all isolators as 20 Amp, lockable, IP56 isolators. Connect all isolators to the respective equipment via smooth flexible conduit unless noted otherwise.

Do not connect any motors larger than 5Kw to an isolator without motor protection relay and a control contactor.

4.2.3 FAULT PROTECTION

Unless specifically shown otherwise, provide overload, short circuit and earth fault protection utilizing automatically operated circuit breakers.

Provide 30mA earth fault protection of all cabling and outlets within residential areas, all general-purpose outlets and circuits that the public could have access to during normal operation.

Ensure all circuits are suitably protected against earth faults and the protective device operates within the required time. Include details of how such protection is achieved with the testing and commissioning data for the worst-case point on every circuit and submain. Such details must be in the form of one of the following:

- Circuit protected by a 30 mA RCD.
- Perspective fault current at the point, circuit impedance and protective device tripping characteristics

4.2.4 CABLING

Unless otherwise specified provide all power cables with copper conductors, a minimum size of 2.5mm² with insulation coloured as follows:

- Actives of single-phase circuits: Red
- Actives of multiphase circuits:
 - A phase: Red
 - B phase: White
 - C phase: Blue
- All neutrals: Black

4.2.5 CLOCKS

As part of the power distribution, provide wall mounted clocks to BS 3456 Section 2.16.

Provide clocks with a case plastic, white or cream in colour. Ensure the clocks have a round white face, with a convex non-reflective bubble glass, with well-defined black numerals or large graduation marks for each hour position and smaller black graduation marks for minute positions. Ensure the clocks have black hour and minute hands and a red distinct sweep second hand.

Provide clocks which have at least 12 months operation from a single 1.5-volt leak proof dry cell battery. The operation of the clocks is to be via Quartz crystal oscillator, combined with a high-performance DC motor for an accurate of + 15 seconds per month and be capable of operation in a temperature range of -10 degrees C to 50 degrees C.

Provide the clocks with a knurled knob at the rear of the mechanism for hand setting and also a pause button to enable greater accuracy of time setting to be affected.

Provide the clocks with a suitable bracket for wall mounting. Fix using wood screws screwed into approved masonry fixings or direct into timber studding or battens. Where screws are exposed, use chrome plated screws.

4.3 COMMISSIONING

As part of the commissioning of the power distribution undertake the following tests as relevant on all components of the power distribution installation: Typical test result forms are available from the Electrical Design Group web site www.edg.net.au.

- Has been fully commissioned in accordance with this specification.
- Phase rotation.
- Power availability.
- Resistance to earth.
- Voltage.
- Overload protection.
- Fault protection.
- Earth leakage residual current protection.
- All mechanical fixings.
- Maximum demand of each switchboard and submain.

Schedule the results for each item and component and include a copy of all test results in the operation and maintenance manual.

Ensure the correct phase sequence at the main switchboard after connection of the supply.

Balance the load as evenly as practicable at Practical Completion. Re-check and, where necessary, re-balance the load at completion of the Defects Liability Period. Submit the balance results for approval and include a copy of the results in the operation and maintenance manual.

As part of the commissioning of the power distribution, undertake any necessary adjustments to components of the power distribution installation which, have integral adjustment capacity as directed. Record all adjustments undertaken and include a copy of all adjustments in the Operation and Maintenance Manual.

Upon the completion of the commissioning of the power distribution provide a written and signed statement that the power distribution installation:

- Has been fully programmed as necessary.
- Has been tested.
- Complies with the intent of the contract.
- Complies with the relevant authority requirements.
- Complies with the relevant standards and codes.
- Is fit for purpose and suitable for the intended use.

Include a copy of the power statement in the operation and maintenance manual. Typical statement of compliance forms is available from the Electrical Design Group web site www.edg.net.au.

Ensure the following components of the power distribution system installation are complete and have been checked and tested prior to the adjusting of the power distribution system installation to commence:

- Labelling.
- Correct operation of the power distribution system.
- All components have been installed and are operating.

Should these items not be complete prior to the adjusting of the power distribution installation the additional expenses in re-attending the installation to undertake the adjusting of the power distribution installation as incurred by the engineer will be charged to the Electrical Sub Contractor.

Provide all equipment such as ladders, scaffolding and tools necessary for adjusting the power distribution installation. Should the Electrical Sub Contractor not have available the necessary equipment to complete the adjusting and aiming of the power distribution installation, the additional expenses in re-attending the installation to undertake the adjusting and aiming of the power distribution installation as incurred by the engineer will be charged to the Electrical Sub Contractor.

The adjusting and aiming of the power distribution installation will include the following:

- Adjusting mountings and brackets.
- Adjusting switch gear settings.
- Testing all operations of the power distribution installation.
- PE Cells.
- Time clocks.

Allow attending site twice during the defects and liability period and undertaking the above adjustments to and reprogram as directed by the operator the power distribution.

At practical completion provide a Queensland Government, Department of Local Government and Planning Form 16 certifying the power installation and include a copy in the operation and maintenance manual.

4.4 OUTLETS

Provide all power outlets and connections as follows:

- Provide isolators for motors with a suitable motor rating; where motors are supplied by other trades, confirm motor ratings prior to sizing isolators.
- Unless otherwise detailed, all appliances will be supplied and installed by other trades, and connected by the Electrical Sub Contractor either by means of an isolator or by means of a power outlet.
- It will be the responsibility of the Electrical Sub Contractor to check with suppliers that cable and circuit breaker/fuse sizes are suitable for the equipment being installed prior to the installation of cables and circuit breakers and/or fuses.
- Specific details regarding connection to various items of equipment are not given in the specification where it is considered that the installation is of a straightforward nature and full details are available from single line diagrams/circuit schedules.
- Ensure all three phase power outlets throughout the installation have identical phase rotation and polarity.
- Install a neutral conductor to every three-phase power outlet.
- The location of sinks and fittings and swing of doors shall be confirmed before the installation of general-purpose outlets and light switches.
- Mount outlets of the one type where grouped together under the common flush plate.
- Provide all outlets mounted on stainless steel joinery of the flush stainless-steel type with black mechanisms.
- On face plates, secure the mechanism with retaining screws, or construct the faceplate and mechanism so that the mechanism cannot be displaced during normal operation.
- Orientate switch mechanisms to operate in the vertical plane.
- Provide all GPOs, 10 amps, 3 flat pin flush, impact resistant, polycarbonate switch plug combinations, all mounted under the one cover plate with the earth pin at the 6 o'clock position.
- Mount all special purpose outlets with the earth pin at the 6 o'clock position, the neutral pin in the centre, and the red, white and blue phases in a clockwise sequence when viewed from the front of the socket.

- Provide a matching plug top with a screw ring for each three phase and screw type outlet.
- All accessories are to be flush mounted installed in wall boxes.

4.5 SWITCHBOARDS

4.5.1 OPERATIONAL MAINTENANCE

During the maintenance period, provide the following for DB-A:

- Carry out periodic inspections and maintain the switchboard installation in a condition to meet the specified performance.
- Promptly rectify all faults.
- Replace faulty materials and equipment without charge.
- Provide a thermoscan report undertaken by Thermoscan Inspection Services Pty Ltd www.thermoscan.com.au at Practical Completion, at 6 months and at end of Defects Liability Period.
- Provide written reports on maintenance activities.
- Provide on line chart recording using a Fluke 1735 of the mains supply for a period of one week at Practical Completion, at 6 months and at end of Defects Liability Period.
- Ensure the chart recorder includes the following information:
 - A sample every 200ms.
 - Data presented in 5-minute intervals including the minimum, the average and the maximum value recorded for each 5-minute interval.
 - Voltage of each phase to earth and each phase to phase.
 - Current of each phase and neutral.
 - Power factor of each phase.
 - Voltage and current harmonics to the 10th order for each phase.
 - Frequency of each phase

Include the chart recorder and thermoscans information within the operation and maintenance manual with simple explanation of the findings of each.

4.5.2 EXTERNAL DESIGN

Provide enclosures comprising panels, doors and the like, giving the specified enclosure, segregation and degree of protection. Provide separate compartments with metal segregation for all extra low voltage equipment.

Provide DB-A with doors.

Fabricate supporting frames from rolled, cold formed or extruded metal sections, with joints fully welded and ground smooth. Provide concealed fixing or brackets located to allow the assembly to be mounted and fixed in the specified location without removal of equipment.

Machine fold sheet metal angles, corners and edges with a minimum return of 25 mm around the edges of front and rear panels, and 13 mm minimum return edge around doors. Provide stiffening to panels and doors where necessary to prevent distortion or drumming. All panels are to be continuously welded and ground smooth.

Provide equipment mounting panels, fixed to threaded metal inserts, located inside the enclosure at the rear of the mounting panels.

Provide fixings in the supporting structure, and removable attachments, for lifting switchboard assemblies whose shipping dimensions exceed 1.8 m high x 0.6 m wide.

Provide all visible hardware or hardware immediately behind doors, as chromium plated or stainless steel. Hardware behind escutcheons, Bramite panels and the like which is not normally visible, may be cadmium plated for internal switchboards and chromium plated or stainless steel for external switchboards. Secure Bramite panels using dome headed hexagonal nuts.

Provide all removable doors and panels with locating pins designed to prevent it from falling when the fastening screws are removed.

Provide all switchboard doors with / as:

- Dished type
- Fitted with a combined lock and catch and a separate key
- Concealed door hinges

In locations the door covers a section of board where live terminations could be exposed once the door is opened, provide the door with the following engraved laminate red/white/red label with 10mm text;

'DANGER'
LIVE ELECTRICAL TERMINATIONS

LICENSED ELECTRICIAN OR
SUPPLY AUTHORITY REPRESENTATIVE
ONLY TO OPEN.

4.5.3 REMOVABLE PANELS AND COVERS

The maximum width of any removable panel is 750 mm. Hang panels and covers on fixed studs with knurled nuts or captive nuts with knurled bolts, in either case fixing is to remain part of the panel or cover when the panel or cover is removed. Provide chromium plated 'D' type handles to each removable plate. Provide a resilient strip seal, of foam neoprene or the like, around each cover or panel, housed in a suitable channel or housing, fixed with an approved industrial adhesive. In indoor locations, provide certified smoke seals to all panels and covers. For external switchboards provide a continuous positive line of weatherproof contact.

All doors are to be locked using a three-point locking system and operated by stainless steel lockable swing handles. Supply four keys on individual stamped aluminium key tags. Ensure all of the switchboards are keyed alike and are keyed on the site master key system. All meter panels located externally and in areas subject to unauthorised access are to be locked to the supply authorities' requirements using the supply authority key.

Provide each door with a substantial internal stiffener fitted with plan pockets and wind stops.

Provide all fixings on switchboards located externally or in potentially corrosive environments as stainless steel. Provide all fixings on switchboards located internally in non-corrosive environments as chrome plated. Plastic or nylon fixings are not acceptable.

4.5.4 ESCUTCHEON PLATES

The maximum width of any escutcheon plates is 750 mm and the maximum height is 1,200mm. Hang escutcheon plates on lift-off pin hinges on one side and secure on the other with fixed studs with knurled nuts or captive nuts with knurled bolts, in either case fixing is to remain part of the escutcheon when the escutcheon is removed. Provide chromium plated 'D' type handles to each side of the escutcheon. Provide removable escutcheon plates with neat cut-outs for circuit breaker handles and the like. Provide a continuous 12 mm wide support frame for the fixing of each escutcheon plate, including additional support where necessary to prevent panel distortion. Hang escutcheon plates on hinges, which allow opening through a minimum of 90 and permit the removal of the escutcheon when in the open position.

Provide cut-outs in the escutcheons for all spare future circuit breakers. Provide blank fillers in all spare escutcheon cut-outs.

Ensure all circuit breaker labels and adjustment dials are visible through the escutcheon when the escutcheon is closed.

4.5.5 FINISHES

Where metal surfaces are to be painted:

- Unprotected steel: Remove rust by abrasive blast to AS 1627.4 Class 3, clean by immersing in trichloroethylene or an alkaline solution, and apply a coat of iron phosphate.
- Galvanised steel: Clean by immersing in a suitable alkaline or acidic solution, apply a chromate or zinc phosphate chemical conversion coating, rinse and degrease.
- Aluminium: Clean by immersing in a suitable alkaline or acidic solution, caustic etch and apply a chromate chemical conversion coating.

Paint the internal and external surfaces of all switchboards, control panels and meter panels located externally in a polyurethane epoxy or epoxy powder coat. Paint the external surfaces, escutcheons and doors of all switchboards, control panels and meter panels located internally with a baked enamel or epoxy powder coat. Paint the internal surface of switchboards, control panels and meter panels located internally as acrylic, baked enamel or epoxy powder coat. Ensure all paint finishes are applied in accordance with the manufacturers' recommendations.

After the switchboards have been installed, repair all chips and scratches in the paintwork to an as new condition.

4.5.6 CONDUCTORS

4.5.6.1 BUS BARS

Provide bus bar systems as high conductivity copper capable of withstanding the thermal, magnetic and physical stresses set up by the fault level detailed for a period of one second. Provide fault level calculations with the shop drawings. Phase colour the bus bars at appropriate intervals for ease of identification over their entire length at any opening, to within 10.0mm of fixings and terminations. Ensure the connections from the bus bars to the equipment are as short as possible and made using bus bars unless the latter is physically impossible. Design bus bar systems for continuous full load operation over a 24-hour period at an ambient temperature of 40°C, with short time peaks of 50°C, resulting in a maximum final bus bar temperature of 105°C. Make allowance for totally enclosed cubicles and for cubicles installed within recesses with or without doors. Provide neutral links and earth bars with sufficient capacity and terminals for connection of all conductors, one conductor per terminal, with spare capacity as detailed and with each terminal being numbered by means of stamping. Clearly mark and number terminal connections. Provide neutral bars with a current carrying capacity equal to that of the incoming phase conductors. Provide bus bar circuits within the switchboard, extending from the termination of the incoming unit to the line side of protective equipment for outgoing circuits. Provide stud connections for cables of cross section 16 mm² or larger.

Divide the bus bar system into separate 'essential' and 'non-essential' circuits, each segregated from the other by fixed and continuous barriers. Clearly label each segregated section of the bus bar system.

Pre-drill the Bus Bars for future extension and extend bus bar droppers to spare locations. Drill each dropper to suit connection of future equipment of the same type as that specified.

Radius all bus bar edges and corners to prevent damage to insulation. Provide support sufficient to withstand without damage, the maximum prospective fault currents. Make bus bar joints with high tensile bolts and nuts, locked in position with lock nuts or locking tabs. Tighten bolts to the manufacturer's recommendation with a tension wrench. Do not use tapped holes and studs or the like for jointing current-carrying sections.

Colour the insulation or bus bar as follows:

- Active Bus Bars: Red, white or blue.
- Neutral Bus Bars: Black.
- Earth bus bar: Green and yellow.

4.5.6.2 NEUTRAL AND EARTH LINKS

Locate neutral and earth links within 0.6 m of each cable entry. Provide terminals for incoming and outgoing neutral and earth conductor.

4.5.6.3 WIRING

Provide all wiring within switchboards as follows:

- Install all internal cabling neatly horizontally and vertically. Cable trough (PVC with slotted sides) may be used, or alternatively cables may be laced/loomed using proprietary cable ties, with adequate insulated supports being provided. Ensure laces/looms are not unnecessarily tight.
- Unless otherwise specified, provide PVC wiring ducts to support and manage all switchboard control wiring and outgoing sub circuits. Ensure the total cross section of the wiring within any one duct, including allowance for outgoing connections, does not exceed 40% of the duct cross sectional area.
- Support cabling to ensure that strain does not occur at terminations.
- Use crimp type lugs at terminations, unless equipment has been specifically designed to preclude terminations being made in this manner. Use lugs with insulated ends.
- Fix cables 25.0mm² and over in size to internal cable trays.
- Bush openings in internal barriers for the passage of cables to prevent damage to insulation using Wattmaster or equivalent 'movable' bushing, glue fixed in position.
- Install cables associated with metering equipment and current transformers in conduit.
- Identify wiring at each end of each conductor with a captive type marking ferrule. Horizontally mounted markings are read from left to right and vertically mounted markings are read from top to bottom.
- Provide the cable lugs associated with consumers' mains and/or submains with permanent identification to denote phase colours.
- Provide sufficient space on mounting rails for future outgoing circuits possible in any cabling compartment.
- Provide terminal blocks for interconnecting wiring on each side of shipping breaks.
- Identify, by markers, each control core using an approved numbering system.

Provide cables sized to suit a current carrying capacity of not less than the maximum continuous rating of the equipment mounted within the switchboard, or sized to withstand the 'let-through' energy of the circuit protective device, whichever is the greater. If the conductors are to be bunched or installed within wiring ducts, apply appropriate de-rating factors when determining conductor size. The minimum size power conductor is multistrand 2.5 mm².

Provide control and indication conductors of not less than 1.0 mm² with 32/0.2 stranding and otherwise sized to suit the current carrying capacity of the particular circuit.

Colour code the wiring as follows:

- A Phase: Red.
- B Phase: White.
- C Phase: Blue.
- Neutral: Black.
- Earthing: Green/Yellow.

If no provision is made in wiring ducts for external connecting cables, install a galvanised perforated cable tray between terminal blocks and cable entries, of a size, and with available access space, sufficient to permit ready installation of the external wiring.

Segregate electric circuits subject to possible interference, and the like.

Segregate terminal groups and install together terminals for each outgoing circuit, in the same order throughout, as follows:

- Terminals for power wiring: 3 phases or phase and neutral;
- Control terminals: In numerical or alphabetical order of wire identification, with the lowest number or letter next to the power terminals.

4.5.7 SWITCHGEAR AND CONTROL GEAR

4.5.7.1 MOULDED CASE AND MINIATURE CIRCUIT BREAKERS

Provide all circuit breakers of the same manufacture.

Mount the circuit breakers so that the 'ON-OFF' and current rating indications are clearly visible with the cover or escutcheon in position, and so that arc discharges from the circuit breakers are directed away from live metal and insulation. Align operating toggles in the same plane.

For miniature over current circuit breakers provide clip tray assemblies, capable of accepting the installation of single, double, or triple circuit breakers, and related Bus Bars. Provide moulded clip-on pole fillers for all unused portions of the chassis.

Maintain sufficient space around the circuit breakers to allow all incoming and outgoing cables, including cables to spare poles, to be installed and terminated without overcrowding. For clip tray chassis mountings, the clearance between the circuit breaker terminals and compartment walls will not be less than 90 mm up to 36 poles and 115 mm above 36 poles.

Provide auxiliary contacts shunt trips, motor operators and other required accessories. All motor operated circuit breakers for load shedding switchboards to be fitted with under volts trips.

Provide all circuit breakers that do not have adjustable trip units that supply motors and / or inductive loads as D curve circuit breakers. All other fixed trip unit circuit breakers are to be provided as C curve circuit breakers. Advise the engineer in writing of the circuits that will be supplied with D Curve circuit breakers so the clearing times of earth faults can be checked.

4.5.7.2 RESIDUAL CURRENT DEVICES

Unless specifically noted otherwise provide residual current devices (RCD) with a maximum tripping current of 30milli-Amps and a maximum tripping time of 20 milli-seconds. Use RCDs specifically designed to be added to or integral to the circuit breaker and be suitable for mounting in the same manner as specified for moulded case and miniature circuit breakers. Ensure all RCDs have a test facility which can be operated with the escutcheon closed. Use RCD/circuit breaker combinations that do not use more than a single pole per single phase circuit and no more than four poles per three pole circuit.

All RCDs that protect supplies to variable speed drives are to have a minimum tripping current of 300milli-Amps.

Ensure that short circuit, cascading, a discrimination performance of the circuit breaker will not be affected by the earth leakage device.

4.5.7.3 TIME SWITCHES

Provide time switches that operate either by synchronous motor or electronically controlled drive from 240 V 50 Hz supply. Provide day omit and manual override facilities. Photoelectric cell input for operation is to be integral.

To account for mains failure, provide either a 24-hour spring or a battery with 100-hour operating capacity and a guaranteed life of 5 years.

The minimum contact rating is to be 20A at 240 V AC to utilisation category AC-22.

Provide a readily accessible means of adjustment of the switch operation. Ensure the switch operational settings are clearly visible when the switch cover is fitted. All time switches mounted in switchboards are to be extended through the escutcheon.

Provide engraved or etched surrounds or labels, identifying the control function of each push button and switch and the operation at each switch position.

4.5.7.5 CONTACTORS

Provide contactors with a minimum rating of 20A at AC-22 of the block type, air break rated for continuous duty. Ensure the contactor is rated above the full load current of the load controlled when mounted in the nominated enclosure. Provide contactors with an utilisation category above AC-3 or DC-3 as applicable. Provide auxiliary contacts for the specified control circuits. Where space is available, fit not less than two sets of spare contacts. Where the number of specified auxiliary contacts exceeds the number which can be accommodated, provide a separate slave relay. Ensure reversing contactors are mechanically and electrically interlocked.

Mount the contactor with sufficient clearance to other equipment and to its enclosure to allow full access for maintenance, removal and replacement of coils and contacts, without the need to disconnect wiring or remove other equipment. All contactors mounted in switchboards are to be extended through the escutcheon.

Do not connect contactors in series or parallel to achieve the specified ratings.

4.5.7.6 CONTROL RELAYS

Provide control relays with a minimum rating of 5A suitable for continuous operation under the specified conditions with operating characteristics suitable for the application. Use plug-in types latched to the receptacle base by a captive clip, which can be applied and released without the use of tools.

Ensure the control relays employ electrically separate, double break, silver alloy, and non-welding contacts.

For standard control relays, provide assemblies with a minimum of four sets of contacts and capable of being expanded to a total of eight contacts in the same assembly. Where space is available, provide not less than one normally open and one normally closed contact.

Provide contact blocks, which are readily convertible in the field to either normally open or normally closed contacts.

Use time delay relays adjustable over the full timing range and have a timing repeatability within 12.5% of the nominal setting.

Use phase failure relays of the solid-state type, which drop out at 80% of the normal voltage after an appropriate time delay. Ensure the sensing circuit rejects disturbances having frequencies other than 50 Hz, and induced voltage spikes.

4.5.7.7 FUSES WITH ENCLOSED FUSE LINKS

Provide fuse-holders and fuse-links of the same manufacture throughout the installation. Mount the fuse-holders so that the fuse carrier may be withdrawn directly towards the operator and away from live parts, and provide fixed insulation which shrouds all live metal when the fuse carrier is withdrawn.

Provide fused links as enclosed, high rupturing capacity (HRC) type mounted in a fuse carrier. Provide a "fuse blown" indication, which is visible, when the link is fitted to its carrier. Where necessary, for safe removal and insertion of the fuse carrier, provide extraction handles and mount them on clips within the spares cabinet.

Provide fault current limiting fuses as HRC fuses (cartridge and fitting) with a minimum and maximum current rating.

Provide three spare fuse cartridges in each switchboard of each size installed in each switchboard, mounted on a holder fitted internally to the switchboard such that it is not visible when the door is closed. Provide tools fixed in a similar manner required to remove or install the entire fuse sizes used.

4.5.7.8 SURGE PROTECTION

Provide DB-1, DB-K, DB-P and DB-C with surge protection in accordance with AS1768 with the following features and requirements:

- The Maximum Discharge Current, I_{max} , as defined in IEC 61643-1 must be 50kA, 8/20 μ s per phase.
- The Nominal Discharge Current, I_n , as defined in IEC 61643-1 must be 25kA, 8/20 μ s per phase.
- The Voltage Protection Level Up as defined in IEC 61643-1 must be less than 750V at 3kA 8/20us and 6kV 1.2/50us.
- The Voltage Protection Level Up as defined in IEC 61643-1 must be less than 1200V at 20kA 8/20us and 6kV 1.2/50us.
- The Maximum Continuous Operating Voltage, U_c must be 415 Volts three phase 240 Volts single phase.
- The products must be UL recognised under UL1449-2 standard.
- (The product must be equivalent to CRITEC TDS 150 or the CRITEC TDS350)
- The surge diverter must have light indication and voltage free contacts.
- Provide a manufactures warranty of a minimum of 5years for the surge diverter.
- Tested in accordance with the requirements of UL1449 Edition 2 and EC 61643-12 Class I and II

All surge protection devices are to be extended through the escutcheon.

4.5.8 LABELS

Provide a two-colour laminated plastic schematic for each switchboard. Provide additional control schematics as required. Securely fix the schematics to the front of the switchboard or behind the switchboard door if the switchboard is provided with a door.

Include the following information on the schematics:

- All installed cable types, lengths and cable sizes.
- All protective device frame sizes and settings.

Provide samples of proposed label material, label sizes, lettering sizes and lettering text for approval.

Screw-fix each label adjacent to its relevant item of equipment, but not on the equipment.

Provide warning notices as white letters on red background and other labels as black lettering on a white background.

Provide the lettering height not less than:

- Switchboard designation: 25mm.
- Main switches: 20mm.
- Feeder control switches: 10mm.
- Identifying labels: (on outside of cubicle rear covers, etc.): 6mm.
- Equipment labels within cubicles: 4mm.
- Warning notices: 4mm.

Provide the main switchboard with a diagram indicating the route of any underground consumers' mains, printed on a durable card or similar, and indicating run distances for each 'leg' of the consumers' mains route.

Provide each distribution board with a neatly typed A4 circuit index schedule, that includes the circuit breaker number, rating and the circuit function (i.e. 4 G.P.O's Sales Area, etc.). Mount the circuit index schedule in an index holder located on the inside of the switchboard door that is provided with a clear perspex cover.

Include a copy of the circuit index schedule and the SLD in the manual.

Provide DB-A with the following engraved laminate white/black/white label with 10mm text located in a prominent position:

COMPUTER/CONSOLE SUB-BOARD
IMPORTANT
DEDICATED POWER WITH BATTERY BACK-UP,
ISOLATED BY THE MAIN SWITCH
BUT CIRCUITS REMAIN LIVE UNTIL BATTERY DRAINED
SWITCH "OFF" ONLY FOR EMERGENCY OR SERVICE
NOTIFY THE IT MANAGER PRIOR TO SWITCH OFF

Provide the word IMPORTANT as engraved in RED on a white background.

4.5.9 SWITCHBOARD OPERATING PARAMETERS

Provide DB-1, DB-S, DB-C and DB-P to the following requirements:

- Fault level 6KA RMS 1 Sec.
- Line: 400 v.
- Phase: 230 v.
- Frequency: 50 HZ.
- Number of phases: three.
- Number of wires: four.
- Neutral connection: star point.
- Earthing system: MEN.
- Ambient air temperature range: -5 to +45deg c.
- Relative humidity: 90%.
- Switchboard designations: main switchboard.
- Mounting: floor mounted.
- Degree of protection: IP44.
- Numerical designation: category 1.
- Equipment connection: front connected.
- Gland plates: 3mm thick brass or aluminium or 6mm thick grey UV stabilised PVC in internal locations.
Provide all gland plates with a neoprene gasket.

Provide DB-K to the following requirements:

- Fault level 6KA RMS 1 Sec.
- Line: 400 v.
- Phase: 230 v.
- Frequency: 50 HZ.
- Number of phases: three.
- Number of wires: four.
- Neutral connection: star point.
- Earthing system: MEN.
- Ambient air temperature range: -5 to +45deg c.
- Relative humidity: 90%.
- Switchboard designations: main switchboard.
- Mounting: floor mounted.
- Degree of protection: IP65.
- Bottom entry only.
- Numerical designation: category 1.
- Equipment connection: front connected.
- Gland plates: 3mm thick brass or aluminium or 6mm thick grey UV stabilised PVC in internal locations.
Provide all gland plates with a neoprene gasket.

4.5.10 MATERIALS AND FINISH

Enclosure: Zinc anneal, powder coat Light Grey, (AS 2700 - colour N35).

Escutcheons: Zinc anneal, powder coat white.

Doors: Zinc anneal, powder coat Light Grey, (AS 2700 - colour N35).

Plinths: Mild Steel, Painted Black.

4.6 EARTHING SYSTEM

Modify the existing earthing as necessary to accommodate the new construction.

Provide a comprehensive earthing system throughout the project addressing all aspects of the structure, all services, all systems and components in addition to those forming part of the power distribution. The existing earthing system is to be modified to accommodate the new structure.

5.0 LIGHTING

5.1 SCOPE

The lighting component of this contract includes internal lighting to all areas of the buildings, external lighting, general lighting control, emergency and evacuation lighting and the lighting sub circuit wiring. All of the light fittings and accessories are to be provided as part of this contract.

All light sources are to be solid state LED with a 5-year manufacturer's warranty.

All existing external light fittings made redundant by the works are to be removed.

Provide separate DALI bus systems in the Viking Cafe and Prep building to provide user inputs into the BMS via the schools embedded communications network via IP BACnet. The DALI buses are to include:

- DALI power supplies DIN Rail mounted in the respective DB's adjacent the BMS controller.
- DALI controllers DIN Rail mounted in the respective DB's adjacent the BMS controller.
- DALI network cable / bus.
- DALI push buttons mounted in the switch panels.
- Programming and commissioning as per the BMS section of this specification.
- Connection of the DALI controllers to the school's communications network via Cat 6 fly lead.

The lighting component of this contract includes, but is not limited to the following extent of work:

- Lighting.
- Light fittings and accessories
- Light poles.
- Lamps.
- Earthing of the lighting installation.
- Lighting control.
- DALI bus control systems.
- Emergency and exit lighting.
- Lighting subcircuits.

Irrespective of the mounting heights given in the electrical documents, the mounting heights of all wall mounted light fittings and the suspension heights of all suspended light fittings must be confirmed with the architect. Provide written evidence such confirmation has been received. If any wall mounted or suspended lights are installed without the height confirmed by the architect, adjusting the height will not be acceptable grounds for a variation.

Provide a sample of each of each type of light switch, lamp and luminaire. Provide Shop Drawings of all custom luminaires. As part of the tender submission the Electrical Sub Contractor must include for all contractual requirements and costs required by the suppliers to the electrical sub-contract to provide the necessary samples. The Electrical Sub Contractor must bear the cost of supplying samples of the components specifically specified as well as those specified generically or by performance.

All suppliers and sub-contractors to the Electrical Sub Contractor must ensure they are familiar with and comply with the requirements of sections 1.0, 2.0 and 3.0 of this specification.

5.2 COMMISSIONING

5.2.1 GENERAL

Upon the completion of the commissioning of the lighting, provide a written and signed statement that the lighting installation:

- Has been fully commissioned in accordance with this specification.
- Has been fully programmed as necessary.
- Has been tested.
- Complies with the intent of the contract.

- Complies with the relevant authority requirements.
- Complies with the relevant standards and codes.
- Is fit for purpose and suitable for the intended use.

Include a copy of the lighting statement of compliance in the operation and maintenance manual. A typical lighting installation statement of compliance form is available from the Electrical Design Group web site www.edg.net.au.

As part of the commissioning of the lighting, undertake the following tests as relevant on all components of the lighting installation: Typical test result forms are available from the Electrical Design Group web site www.edg.net.au.

Schedule the results for each item and component and include a copy of all test results in the operation and maintenance manual.

As part of the commissioning of the lighting, undertake any necessary adjustments to components of the lighting installation which have integral adjustment capacity as directed by the project manager. Record all adjustments and include a copy of the adjustment records in the operation and maintenance manual.

Chemically clean all reflectors, lenses, diffusers and lamps prior to the aiming and adjusting of the lighting installation.

Undertake each of the following mechanical checks for each component of the lighting installation as part of the commissioning process:

- All luminaires have been positioned to coordinate with other installers (such as air conditioning contractors, installers of girders and plasterers).
- All luminaries are in the correct position and in the correct orientation.
- All luminaries are clean and undamaged with the correct lamps fitted (i.e. manufacturer, rating, phosphor and electrical type).
- All channel dials and function switches (as appropriate) have been set to the specified settings.
- All sensor levels have been set to the specified levels.
- All components are uniquely and clearly labelled.
- The alignment of all luminaries has been adjusted to avoid glare and unwanted over-spill.
- All cover plates have been fitted and electrical segregation is complete.
- All raise and lower gear has been checked.
- All safety chains, safety cords and filter holders etc. on luminaries have been securely mounted; associated control gear have been fixed securely on lighting trusses, booms, barrels and bars, or placed in a secure position.

Undertake each of the following electrical checks for each component of the lighting installation as part of the commissioning process:

- All luminaries, switched and sensors have been wired according to the wiring diagram provided.
- All lights and track circuits have been wired to the specified control switch or dimmer.
- All mains wiring has been tested and certified as complying with the recommendations of AS3000.
- The voltage and frequency is stable and within the relevant authority limits.
- Control operation.
- The Resistance to earth of each fitting switch panel and exposed metallic component.
- The supply voltage and frequency at each fitting.
- Overload protection has been installed and operates correctly.
- Fault protection has been installed and operates correctly.

At practical completion replace all lamps in emergency luminaries that have operated for more than 96 hours during the construction phase.

At practical completion provide a Queensland Government, Department of Local Government and Planning Form 16 certifying the lighting installation and include a copy in the operation and maintenance manual.

5.2.2 LIGHTING CONTROLS

Confirm all light sensors are located in an appropriate representative location for the intended task. Calibrate the light sensor to indicate the light levels as advised by the engineer on site. Confirm the calibration of the light sensors with an independent NATA certified portable light sensor.

The calibration should take place remotely to the sensor at the lighting controller or at a remote operator workstation (via configuration software).

Confirm all light occupancy sensors are located and orientated appropriately in relation to the occupants. Confirm the occupancy sensor sensitivity is appropriate by adjusting the detector sensitivity to ensure the occupant movement is detected throughout the occupied zone. Configure the sensitivity to ensure seated occupants are detected, whilst movement outside the controlled zone does not activate the lights. Confirm the time delay setting is representative of the occupant work/movement patterns and is assessed when the building is occupied.

Set all pre-sets, upper and lower limits of all dimmers as advised by the engineer on site.

Set all start and stop times along with override controls (e.g. occupant or security staff override) as advised by the engineer on site.

Ensure that scenes operate as advised by the engineer on site. Ensure that scenes are labelled adequately to allow an untrained user to select the correct option.

Ensure that the central control system has / is:

- The specified software release is installed
- Passwords and associated access levels are set up correctly.
- All outstations and unitary control devices can be addressed and data sent and retrieved. This should include any specified retrieval of point data and the ability to download configuration software and perform alterations to control points and strategies.
- Any specified building schematics are displayed correctly on request and that the monitored point data associated with each schematic are also correct i.e. ensure that the 'binding' - correlation - of the graphics and monitored data is correct.
- Data logging functions operate correctly.
- Logged data can be displayed correctly.
- Archiving of logged data, system configuration details and control parameters operate correctly.
- Any specified automatic report generation software operates correctly (automatic generation of point list and control strategy schematics etc).
- Any specified third-party management software such as energy targeting and monitoring software can retrieve the necessary data from the central supervisor/BMS. Ensure for the specified operation of the software (data analysis and display/management reports etc).

5.2.3 INTERIOR LIGHTING

Confirm the aiming and focusing of adjustable luminaires is adequately addressed. If all other lighting needs to be switched off during this process, ensure the site to be free from other workers requiring light.

Provide a safety method statement that allows those aiming and focusing the luminaires to use appropriate access gear belonging to, or hired by, the installer. If it is intended that the luminaires be adjusted by the end user after practical completion of the project, this must be indicated in the commissioning method statement.

5.2.4 EMERGENCY LIGHTING

The commissioning of emergency lighting must be in accordance with AS2293 and completed by the holder of a Queensland Building Services Authority (BSA), Emergency Lighting Licence, Class 1 and 2. Provide a copy of the BSA licence and associated professional indemnity insurance certificate for approval prior to practical completion and include a copy in the operation and maintenance manual.

At practical completion provide a Queensland Government, Department of Local Government and Planning Form 16 certifying the emergency lighting installation and include a copy in the operation and maintenance manual.

5.2.5 OCCUPANT INTERFACES

Undertake the following commissioning procedures for all lighting control occupant interfaces:

- Ensure the physical location of occupant control devices is correct.
- Ensure that each occupant control device is linked to the building control system communications network.
- Ensure that each occupant control device controls the correct items of plant.
- Ensure that the occupant control device/plant zoning relationship is correct.
- Ensure that the control band of the occupant control is specified.
- Ensure that the default control settings for each occupant control device are correct.
- Ensure that any specified automatic override function operates correctly.

5.3 LUMINARIES

5.3.1 GENERAL

It is the electrical sub contractor's responsibility to ensure the luminaire is appropriate for the intended location considering the following:

- Mounting requirements.
- Lay in diffusers are sized such that they do not fall out of the light fitting or ceiling when the installation is subjected to normal air pressure changes and or winds.
- Fitting size.
- IP protection.
- Exposure to corrosive environment.
- Hazardous environment.
- UV exposure.
- Safety.
- Heat.
- Vandalism.

Irrespective of the fitting type specified, provide all light fittings in compliance with the restricted zone requirements of AS3000. Provide all light fittings over baths as Class II double insulated.

Provide each fitting with a screw tunnel type fused terminal block capable of housing 4x2.5mm² conductors in each terminal.

Provide all discharge fittings with low loss control gear. Replace any ballasts causing audible humming or crackling. Ensure all discharge lamps are compatible with the ballasts and other starting and control gear. Provide written evidence from the manufacturer of such and include it within the manuals.

Provide recessed luminaries with an external 1500 mm length of 1mm² 3-core PVC/PVC flexible cord to AS 3191, connected to a 10 A 3-pin plug top to AS 3112 (Flex and Plug).

Provide all discharge light fittings with power factor correction to achieve a power factor of not less than 0.9 lagging after two hours of continuous operation.

Where required by the supply authority, provide blocking inductors to the authority's approval.

Provide luminaries with all internal wiring colour coded to AS3137.

Provide each extra-low voltage luminaire with a dedicated step-down copper wound, iron core sealed type c/w internal automatic thermal switch and a flex and plug. Provide the engineer with written confirmation that the proposed step-down transformers are compatible to be dimmed by the dimmers specified. Mount the transformers such that they are hanging in free air in a concealed location such that they can be accessed and removed.

5.3.2 MOUNTING

Co-ordinate with other trades to ensure that mounting locations are clear of other services. Ensure the locations of all luminaries are symmetrical with the adjacent fixtures and that unintentional glare is avoided.

Provide luminaries suitable for mounting in the required position or ceiling type. Ensure that all luminaries and luminary control gear are not covered by insulation and have appropriate ventilation. Mount all light fittings to fixed rigid supports.

Provide termite resistant plywood support to all luminaries mounted within lay-in ceiling tiles such that the weight of the light fitting and control gear is supported on the ceiling grid and not on the tile. Provide all necessary T Bars and cut tiles required to accommodate the installation of luminaries mounted within suspended tile ceilings. Provide all necessary additional structural supports and T Bar rails to mount the fittings and support the plywood support. Provide all cut-outs in set plaster ceilings and modify the structural support of the ceiling where necessary to accommodate the cut-out.

Provide all light fittings mounted within T Bar ceilings with a flexible lead and plug and an unswitched active. Provide such fittings with an approved plug base securely fixed to the structure above the fitting.

For fixing of surface-mounted luminaries to ceilings or walls, provide not less than, four fixings in square and rectangular luminaries and three fixings in circular luminaries, placed symmetrically.

In locations light fittings are recessed into thermal or acoustic insulation provide all necessary supports and modifications to the insulation to allow the fitting to be installed and the integrity of the insulation to be maintained.

Provide all fittings in food preparation areas as follows:

- Sealed with no top surfaces less than 45 deg exposed to the room air.
- All lamps are fully enclosed.
- All trims are sealed against the ceiling.
- All diffusers are to be held in place in a sealed frame.
- The diffuser frame is to be fixed in place with a positive contact sealing gasket against the fitting trim and secured in place by a minimum of four stainless steel screws.
- Diffusers sealed into the fitting trim by a sealant are not acceptable.

Provide suspensions and luminaries suspension connectors capable of supporting, without damage, five times the mass of the luminaries, or 25kg, whichever is the greater. Ensure all suspended light fittings hang horizontal and adjacent fittings are hung to the same level. Provide all light fittings suspended from a raked ceiling with an adjustable ceiling mounting such that the fitting equipment hangs vertically. Where light fittings are not supplied with integral suspensions provide the suspensions as follows:

- Structurally support the light fittings on threaded booker rod.
- Cover the booker rod with conduit painted to match the light fitting colour.
- Run all wiring to the light fitting through the conduit.
- Fix the conduit into a ceiling rose on the ceiling to provide a neat finish to the conduit.

In all cases suspended light fittings are subject to movement due to wind or air conditioning breeze provide the suspensions as fixed rod suspensions.

Provide poles which incorporate a tamper resistant access panel within the pole base. All poles are to be provided with base plates that incorporate a minimum of four hold down bolts. Provide poles and insitu concrete footings designed specifically to suit the local conditions and be able to withstand wind gusts of 250km/h. The design of the pole and the footing is to be undertaken by a resisted structural engineer. Provide a certificate from the structural engineer indicating the poles and footings meet the specified design criteria. Provide detailed drawings of all poles and footings for approval. Provide a fused connection within each pole located behind the pole base access panel. Connect the pole to the electrical earth via a lug fixed to a stud welded to the pole located within the pole located behind the pole base access panel. Trim the hold down bolts such that they do not protrude more than 15mm above the nut. Treat the trimmed hold down bolt against corrosion and ensure it does not contain sharp edges that represent a hazard. Ensure the base plate is between 50 and 100mm above the finished landscape level. Provide a neat smooth finished concrete grout fill under the base plate ensuring any splatter is immediately washed off the base plate and pole. Extend the conduit into the pole 50mm above the base plate.

Provide poles less than 20m that comply with AS/NZS 1170.0:2002 Structural design actions Part 0: General principles - Importance level 1 and poles that are more than 20m that comply with importance level 2 both with a design working life of 50 years.

Design the poles to a wind loading as per S1170 AS/NZS 1170.0:2002 Structural design actions Part 0: General principles. The fraction of critical damping is to be taken as 0.05 (ultimate) and 0.01 (serviceability) for poles with more than two- (2) overlaps and 0.02 (ultimate) and 0.005 (serviceability) for all others. The natural frequency of the pole is to be calculated considering varying diameters and thicknesses over the height of the pole and using a 1.1 safety factor for the mass at the top of the pole.

Ensure pole deflection at serviceability wind speeds have a deflection less than 6.7% for poles under 30.0m and less than 3.3% for poles 30.0m and over or for poles with integral access i.e. climbing rungs.

Ensure all welds are by a continuous automatic gas shielded electric arc process complying with the relevant parts of AS1554 Structural steel welding. Ensure the longitudinal seam welds on pole sections conforms to GP standards while baseplate and spigot welds shall conform to SP standards as mentioned in AS1554. Weld sizes are to be verified by a qualified structural engineer and specified in the engineering report and on workshop drawings.

Provide all poles with a galvanised foundation bolt assembly complete with positioning template and two- (2) nuts and washers per bolt provided to suit the pole baseplate. Foundation bolts must be manufactured from deformed reinforcing bars with a nominal yield stress of 500 MPa. Provide bolts threaded in accordance with AS1275-1985 Metric screw threads for fasteners and fitted with class 5 nuts in accordance with AS/NZS 1112:1996 ISO metric hexagon nuts. Foundation bolts must be tied to a suitable reinforcing cage. The length of each foundation bolt must allow for the length of the thread above ground, a minimum of 100mm cover and a development length in accordance with AS3600-1994 Concrete structures, Table 13.1.2.2(A). The underside of the baseplate is to be grouted.

Provide flush fitting access doors to house luminaire control equipment. The pole section at the access door is to be reinforced and analysed according to BS EN 40-3-3:2003 Lighting columns, Design and verification- verification by calculation or a recognised finite element analysis package. Poles housing more than eight sets of control gear are to have a vented bottom access door.

The section capacity of the pole is to be analysed over a minimum of 100 increments according to AS4100 - 1998 Steel structures and AS/NZS 4600:2005 Cold-formed steel structures.

luminaires are to be accessed by external machinery e.g. cherry pickers. Luminaire crossarms shall be designed to ensure easy access of fittings for re-lamping and aiming. Climbing rungs and maintenance platforms are not required.

The pole and all steel accessories are to be hot dip galvanized after fabrication in accordance with AS/NZS 4680:2006 Hot-dip galvanized (zinc) coatings on fabricated ferrous articles.

If powder coating is required, poles are to be sanded after galvanizing and preheated to 220°C to drive off any trapped gas under the galvanized surface. A zinc rich prime coat - Interpon Polyzinc 660 or equivalent shall be applied to within 60µm and 80µm within four hours of preheating and green cured to 200°C for 3 minutes. Prime coat shall be lightly sanded before application of top coat. Colour topcoat shall be a ripple, high build finish to within 50µm and 70µm. If painting is required either two coat polyurethane or epoxy painting systems shall be used.

Ensure all manufacturing tolerances are in accordance with AS 1798-1992 Lighting poles and bracket arms - Preferred dimensions. In particular the poles shall be checked for compliance with the straightness requirements of this standard: 0.3% of height.

Assembly and erection are to be carried out only by qualified rigging personnel. Assembly and erection instructions are to be provided with every pole over 6.0m mounting-height.

Grout the underside of all pole baseplates within seven- (7) days of installing the pole.

5.4 LAMPS

Supply all light sources as solid-state LEDs with a fire year warranty.

5.5 EMERGENCY LIGHTING

Provide a single point emergency lighting system that complies with the latest issue of all parts.

Install emergency light fittings nominated as maintained as follows:

- The lamp is to be permanently on supplied via an unswitched active mains supply when the mains supply is available. When the mains supply is not available, the lamp is to remain on supplied by the emergency pack. Single lamp maintained emergency lights are not switched with the local general area lighting. (The lamp is always on.)

Install emergency light fittings nominated as non-maintained as follows:

- If the fitting is not shown as being switched, the lamp is to remain off when the mains supply is available. When the mains supply is not available the lamp is to be switched on supplied by the emergency pack. Unswitched single lamp non-maintained emergency lights are not switched with the local general area lighting. (The lamp is on only when the mains supply is not available.)
- If the fitting is shown as being switched, the lamp is to be supplied and controlled with the local general area lighting when the mains supply is available. When the mains supply is not available the lamp is to be switched on, supplied by the emergency pack. (The lamp is on when turned on with the local general lighting or the main supply is not available.)

Provide the emergency lights as the self-contained type, Twin rate constant current, constant voltage, and temperature compensated type with automatically selected boost and float charging rates, 70°C rated sealed plastic type lithium iron with a rated battery life of 10 years. Indelibly stamp each battery with its date of manufacture. Protect the inverter system against damage whilst in operation in the event of failure, removal or replacement of a lamp.

Label each circuit breaker which controls the unswitched active to exit lights with a label fixed adjacent; engraved plastic laminate, green background with white characters: -

**WARNING
INTERRUPTING SUPPLY WILL DISCHARGE
EMERGENCY LIGHTING BATTERIES**

Provide written evidence of the initial commissioning and testing and testing for the duration of the maintenance period in accordance with AS 2293.2.

This evidence is to be in the form of a log book similar to the General Lighting Service Pty Ltd "Emergency Lighting Maintenance Log Book and Manual" which is to be provided by the electrical sub-contractor and have all entries fully completed and be presented for inspection at practical completion. The log book is to be retained by the electrical sub-contractor for the duration of the maintenance period, and the six-monthly test and maintenance results entered. The log book is to be presented for approval at final completion (expiry of the maintenance period) and will be forwarded to the operator for their use.

Provide maintenance of the emergency and exit lighting installation including records in accordance with the latest issue of all parts AS2293.

Provide the emergency lighting system with a supply sensing and testing facility in accordance with AS 2293.1 where noted in the distribution board schedule.

5.6 LIGHTING CONTROL SYSTEM

5.6.1 GENERAL CONTROLS

Provide all manual light switches that are not controlling inductive loads (luminaries that do not have transformers or magnetic ballasts) as 20A mechanisms mounted with the rocker operating in the vertical position. Provide all manual light switches that control inductive loads (luminaries that do have transformers or magnetic ballasts) as 15A inductive load mechanisms mounted with the rocker operating in the vertical position. Position manual light switches and switch panels at 1100mm AFFL unless noted otherwise. Where multiple switches are located in the same location, use multigang switchplates. Use standard faceplates for quantities of up to six switches. For quantities of more than six switches and in locations dimmers and fan controllers are required, use flush engraved black marked stainless steel multigang switchplates. Where the function of any switch being not immediately logically obvious, label the switch with an engraved contrasting colour label on the switchpanel.

Provide all switch mechanisms in bathrooms, laundries, toilets, amenities and in locations the switch is within 2,000mm of a tap as IP56.

Switch the load via an AC3 20 Amp switching contactor for all switched lighting loads above the following ratings:

- Resistive loads above 2,500 watts.
- Inductive loads above 1,500 watts.
- Capacitive loads above 1,000 watts.

In locations that have accessible ceiling space, locate the switching contactors in an IP56 PVC storm grey din rail enclosure mounted in the ceiling space above the switch panel no more than 1000mm horizontally from the switch panel. In service areas that do not have accessible ceiling space, locate the switching contactors in an IP56 PVC storm grey din rail enclosure wall mounted against the ceiling or at 2,400mm AFFL immediately above the switch panel, no more than 1000mm horizontally from the switch panel. In all other locations, locate the switching contactors in the distribution board.

Provide a screw fixed engraved label with the words "This switch panel has two sources of supply" immediately above any switch panel that has supplies from different sources or distribution boards.

Utilise battery backed-up 24-hour 7-day programmable time clocks with a separate contactor to switch the time clock-controlled load. Locate the time clock and contactor within an equipment section of the associated switchboard. Provide each time clock with a key-operated bypass switch mounted on the door of the associated switchboard. Obtain from the operator the settings of each time clock. Ensure the operating and programming instructions for each time clock are included in the operation and maintenance manual.

Utilise adjustable photo electric (PE) cells with a separate contactor to switch the PE Cell controlled load. Locate the PE Cell on site such that it is able to obtain an accurate indication of the daylight level under normal operation and such that it will not be obscured by the future growth of vegetation or effected by incident light from any light fittings on this site or adjacent sites. Mount the PE Cell in an inverted position. Provide each PE Cell with a key operated bypass switch mounted on the escutcheon of the associated switchboard. Ensure the PE cell is located on the work-as-executed drawing and the operating and programming instructions for PE cell clock are included in the operation and maintenance manual.

Provide all over-rides of the automatic lighting control with adjustable time over-ride periods. Provide the timers with a time range from one minute to two hours. Locate the adjustable timers in the associated distribution board and label appropriately.

As part of the programmable lighting control system, allow to program the operation of the programmable lighting control system on site under the instruction of the engineer to the satisfaction of the engineer. Allow to attend site and adjust the programming of the programmable lighting control system a further four times following practical completion.

Schedule the results of the programming and include a copy of them in the operation and maintenance manual.

5.7 ADJUSTING AND AIMING OF LIGHTING INSTALLATION

Ensure the following components of the lighting Installation are complete and have been checked and tested prior to the adjusting and aiming of the lighting installation to commence:

- Circuiting.
- Labelling.
- Connection of correct lights to correct channels.
- Correct operation of lighting control system.
- All lights have been installed and are operating.

Should these items not be complete prior to the adjusting and aiming of the lighting installation the additional expenses in re-attending the installation to undertake the adjusting and aiming of the lighting installation as incurred by the project manager will be charged to the Electrical Sub Contractor.

Allow for the adjustment and aiming of luminaries over a period of four (4) hours per night for two (2) nights during the hours of darkness to achieve final set-up. This work will be carried out under the direction and to the satisfaction of the project manager.

Provide all equipment such as ladders, scaffolding and tools necessary for adjusting each luminary. Should the Electrical Sub Contractor not have available the necessary equipment to complete the adjusting and aiming of the lighting installation, the additional expenses in re-attending the installation to undertake the adjusting and aiming of the lighting installation as incurred by the engineer will be charged to the Electrical Sub Contractor.

The adjusting and aiming of the lighting installation will include the following:

- Setting all PE cells and time clocks.
- Focusing of lights.
- Adjusting mountings and brackets.
- Aiming of fittings.
- Testing all operations of the lighting control system.
- Testing the emergency and exit lighting system.

Allow attending site twice during the defects and liability period and undertaking the above adjustments to and reprogram as directed by the operator the lighting installation.

Document the final results of all adjusting and aiming of the lighting installation and include them in the operational and maintenance manuals.

6.0 COMMUNICATIONS CABLING

6.1 SCOPE

All aspects of the communications works including the following are to be undertaken by either of the following as a nominated subcontract to the electrical subcontract:

- Queensland Data & Electrical is Richard Francis 0411 704 434 or 07 3889 7733
- General Communications Amanda Bryon (07) 5533 9876

The communications cabling component of this contract includes an integrated telephone and data EIA/TIA 568-B Category 6 Krone certified RJ45 cabling solution.

The existing communications rack CR-A is to be retained. All of the existing fibre cabling connecting to or running through the building is to be retained with the exception of the existing FIP service.

Provide a new 12 core type OM3 optical fibre from CR-1 to the existing CR-MS in the Magnus Building.

Provide all new communications outlets in the Viking building supplied from CR-1.

Provide a new 12 core type OM3 optical fibre from CR-D to the existing CR-G in the Goodwin Building.

Provide all new communications outlets in the Prep building supplied from CR-D.

Upgrade the existing FOBOTs in CR-MS and CR-G as required to accommodate the new optical fibre cables.

Provide the FIP in each building with a 4 core type OM3 optical fibre cable from the FOBOT in the communications rack in the associated building. Provide patching to allow the FIPs to be connected to the existing FIP optical fibre loop.

All of the optical fibre cables are to be fully terminated with LC connectors.

Provide the replaced distribution boards DB-C and DB-S in the Campbell Centre and School House each with two communications outlets connected to the existing patch panel in the associated buildings existing communications rack. The communications outlets are to be used to connect the BMS controllers in the associated switchboard to the schools ethernet network.

The communications cabling component of this contract includes but is not limited to the following extent of work:

- Communications cabling.
- Communications system earthing.
- Facility cabling.
- Patch panels.
- Fibre cabling and terminations.
- Access and conduits.
- Independent certification.
- Trenching.
- Outlets.
- Patch leads not required.

All of the existing copper telephone cabling and distribution panels are to be removed back to the source. This includes removing all of the existing cabling that connects the building to / from other buildings through underground conduits.

Provide new cat 6 patch panels within CR-1 and CR-D to accommodate the new communications cabling.

Provide the communications system as a propriety Krone structured cabling system with a Krone 15-year warranty over the communications installation. Include a copy of the propriety structured cabling system manufacturer's warranty in the operation and maintenance manual.

All suppliers and sub-contractors to the Electrical Sub Contractor must ensure they are familiar with and comply with the requirements of sections 1.0, 2.0 and 3.0 of this specification

Ensure that the work is performed by the holder of a current ACMA license and the staff member has been trained and is certified by the propriety structured cabling system manufacturer. Provide a copy of the appropriate ACMA license and propriety structured cabling system manufacture's certification for approval prior to commencing work onsite and include a copy in the operating and maintenance manual.

Provide independent testing and certification of the performance of the communications installation and include a copy of such in the operation and maintenance manual.

The telephone and data active equipment is to be provided by the operator.

All outlets, patch panels and FOBOTs that are required to terminate the cabling provided as part of the communications cabling are to be provided as part of these works.

Within all cases in this contract, Category 5 and Cat 5 is to be read as Category 5e enhanced Class D.

Within all cases in this contract, Category 6 and Cat 6 is to be read as Category 6 Class E.

The terms Category and Cat are used interchangeably throughout this contract to refer to cabling types and standards.

A telephone reference conductor (TRC) system is not required.

Provide all copper products within the communications cabling scope as being capable of supporting the provision of power to the Data Terminal Equipment via the electrically conductive Media Dependant Interfaces as specified in the latest IEEE 802.3af "Power over Ethernet" standard.

Provide as part of the tender response, a list of the technical support staff and installation staff, together with their working experience in the relevant field who are proposed to undertake the installation and provide maintenance support. Include the date each of the nominated staff members received formal classroom training by the structured cable system manufacturer. Nominate the location of the office proposed to control and support the installation and maintenance.

Provide the communications cabling installation in accordance with the requirements of the following standards including all subsequent amendments and addendums:

- ACMA TS008, 1996, Requirements for Authorised Cabling Products.
- ACMA TS009, 1996, Installation Requirements for Customer Cabling (Wiring Rules).
- AS 3080:2002 Telecommunications Installations - Integrated Telecommunications Cabling Systems for Commercial Buildings.
- AS/NZS 3084:2003 Telecommunications Installations - Telecommunications Pathways and Spaces for Commercial Buildings.
- AS/NZS 3085.1:1995 Telecommunications Installations - Administration of Communications Cabling Systems. Part 1: Basic Requirements.
- TSB 36 Category 6 cabling.
- TSB 40 Category 6 connectors.
- AS/NZS 3548 EMC - Information Technology.
- Vendor Installation training manual (Copper & Fibre).
- AS/NZS 4117 Surge Protective Devices for Telecommunication Applications
- AS/NZS ISO/IEC 14763-3 Implementation and Operation of Customer Premises Cabling - Part 3: Acceptance for Optical Fibre Cabling

- AS/NZS IEC 61935.1 (Replaced AS/NZS 3087 in 2006) Testing of Balanced Communications Cabling In Accordance with ISO/IEC 11801 - Part 1
- ISO/IEC 11801 Ed 2 Information Technology - Generic Cabling for Customer Premises - Class A to F
- ISO/IEC 11801 Ed 2 Amendment 1 Information Technology - Generic Cabling for Customer Premises - Class E A and F A Channels
- ANSI/TIA 568-C.2 Balanced twisted Pair telecommunications Cabling and Components

All items not covered by the above Standards are to comply with the following:

- EIA/TIA-569-C Commercial Building Standard for Telecommunications Pathways and Spaces.
- EIA/TIA-606 the Administration Standard for the Telecommunications Infrastructure of Commercial Building.
- TSB67 Transmission Performance Specification for Field Testing of Unshielded Twisted Pair Cabling Systems.
- TSB72 Centralised Optical Fibre Cabling Guidelines.

Ensure the communications cabling installation meets the minimum performance requirements of the following:

- AS/NZS 3080 for Class D (Cat 5)
- ISO 11801 Ed 2 for Class D (Cat 5E)
- ISO 11801 Ed 2 for Class E (Cat 6)
- IEEE 802.3 10/100/1000 Base-T Ethernet
- RS 232 Asynchronous Communications @ 19.2 Kbps.
- ISDN (ETSI).
- Digital Voice Telephony.
- Analogue Voice Telephony.
- Voice over IP.
- ISO 9314 FDDI at 100Mbps.
- Asynchronous Transfer Mode @ 622Mbps.

Use only the 568A wiring scheme for 8-position modular components throughout the site. Do not mix 568A and 568B wiring schemes.

6.2 INSTALLATION

6.2.1 CABLING

6.2.1.1 GENERAL

Shielded twisted pair cables are not acceptable.

Ensure all communications cables are not installed with a pulling force that exceeds the manufacturer's recommended maximum pulling force. Use cable mounted pulling eyes / cable netting to install cables.

Do not paint communications cables.

Do not run communications cabling and power cables parallel in skirting duct for more than 10 meters.

Do not use motorised winches or vehicles to pull in communications cables.

Ensure the cable manufacturer's minimum bending radii are not exceeded at any time. Any cables that exceed the cable manufacturer's minimum bending radii or are kinked must be entirely replaced. If the cable manufacturer's minimum bending radii is not available ensure that a minimum bending radius at least 10 times the diameter for all other multi-core fibre cables under no-load and 20 times the cable diameter during installation or long-term under load are not exceeded.

The communications cables are to avoid areas of concentration of electrical power and mechanical and hydraulic services.

Ensure where cables are reticulated via catenary wire, horizontal cables are tied off loosely, to the catenary wire at intervals no greater than 600 mm. Ensure a maximum of twenty-four (24) four pair UTP cables are supported on a single catenary wire support.

Ensure tension on the cable tie is such that ties must be able to be moved laterally along the cable run and yet still maintain the cable to the support structure.

Utilise installation procedures that ensure that no undue stress is placed on any cable and there is not any evidence of sag or kinks.

Ensure cable entry into a power pole, riser column, duct or cavity is preceded by at least a one-turn service loop of minimum 300 mm in diameter prior to entry into the pole, column, duct or cavity to allow for minor moves and changes allowances.

Use waterfall type control accessories for vertical direction changes of more than 45 degrees.

Ensure all cables have a unique cable identification permanently and legibly placed at each end of the terminated cable within approximately 200 mm from where the cable is terminated utilising a Brady type wrap around each label.

Do not install more than 10 UTP cables in a 35 x 40 duct or 15 UTP cables in a 40 x 50 duct or 18 UTP cables in a 50 x 50 duct. Do not install more than 75 UTP cables on a 150 wide tray or more than 160 UTP cable on a 300-wide tray. Do not install more than 2 UTP cables in a 20 dia conduit or 2 UTP cables in a 25 dia conduit or 7 UTP cables in a 32 dia conduit or 18 UTP cables in a 50 dia conduit. All communications cable trays are to be supported by cantilever L type brackets.

Ensure all communications conduits have 50% of the cross sectional area as spare after all of the cabling has been installed.

Use cable supports that are smooth and at least 34 mm wide with rounded-off edges.

It is not acceptable for any communications cables to be buried direct.

Ensure all cabling that is installed externally is loose tube, gel filled flooded PVC insulated PE sheathed installed in conduit. Ensure all external cabling including locations that are not secure such as sheds, covered areas, pool buildings, etc is installed in conduit and the conduit is arranged such that any water that may enter the conduit will immediately run out and not be trapped in the conduit. Minimise the extent of gel filled cable installed internally. Obtain approval of all internal runs of gel filled cable that are more than 30m. Do not use gel filled cable where the cable does not run externally.

Segregate the communications cables from other services by a minimum of 50mm. Increase the segregation distance as required to ensure the other services do not cause interference in the communications cabling.

For segregation between communications cabling and power cabling where a metallic earthed barrier is not present ensure:

- Where there are no more than 15 bunched circuits and all of the circuit are protected by an overcurrent device less than 60 Amps, a 200mm physical segregation is maintained.
- Where there are between 16 and 30 bunched circuits and all of the circuit are protected by an overcurrent device less than 60 Amps, a 300mm physical segregation is maintained.
- Where there are more than 30 bunched circuits and all of the circuit are protected by an overcurrent device less than 60 Amps, a 600mm physical segregation is maintained.
- Where any circuit is protected by an overcurrent device larger than 60 Amps a 600mm physical segregation is maintained.

For segregation between communications cabling and power cabling where a continuous metallic earthed barrier is present ensure:

- Where there are no more than 15 bunched circuits and all of the circuit are protected by an overcurrent device less than 30 Amps, a 50mm physical segregation is maintained.
- Where there are between 16 and 30 bunched circuits and all of the circuit are protected by an overcurrent device less than 30 Amps, a 100mm physical segregation is maintained.
- Where there are more than 30 bunched circuits and all of the circuit are protected by an overcurrent device less than 30 Amps, a 150mm physical segregation is maintained.
- Where there are no more than 15 bunched circuits and all of the circuit are protected by an overcurrent device less than 60 Amps, a 150mm physical segregation is maintained.
- Where there are more than 16 bunched circuits and all of the circuit are protected by an overcurrent device less than 60 Amps, a 300mm physical segregation is maintained.
- Where there are no more than 30 bunched circuits and all of the circuit are protected by an overcurrent device 60 Amps or more, a 300mm physical segregation is maintained.
- Where there are more than 30 bunched circuits and all of the circuit are protected by an overcurrent device 60 Amps or more, a 450mm physical segregation is maintained.

Ensure all UTP cabling is segregated from the following equipment by at least the dimension given:

- Segregate from all electrical appliances by more than 300mm.
- Segregate from all light fittings including remote control gear by more than 150mm.
- Segregate from all photocopiers and printers by more than 500mm.
- Segregate from all mains switching devices by more than 500mm.
- Segregate from all lighting system dimming equipment by more than 500mm.
- Segregate from all UPS less than 10kVA by more than 100mm.
- Segregate from all UPS between 10kVA and 30kVA by more than 300mm.
- Obtain a specific direction for the segregation distances for UPS larger than 30kVA.
- Segregate from all VSD controllers and VSD to motor cabling by more than 3,000mm.
- Segregate from all radio (wireless) transmitters by more than 3,000mm.
- Segregate from all thermostats by more than 500mm.

Ensure the communications cables are installed in dedicated compartments (separate to any power cabling) in all umbilical cable access ways associated with modular office systems. Additional separation or barriers are not required within the umbilical cable access ways. Ensure the ends of the umbilical cable access ways are arranged such that the minimum bending radius of the communications cables are not exceeded.

6.2.1.2 UNSHIELDED TWISTED PAIR CABLING

UTP cables within bundles or on tray are to be laid randomly and not installed in straight lines.

Install cables so coils and any bends follow the natural spiral lay of the cable.

Do not bundle more than 24 UTP cables in the same bundle and do not mix different category UTP cables in the same bundle.

Ensure the untwist in a pair at the IDC termination is less than, 13 mm for category 5 cables and 5 mm for category 6 cables.

Ensure all permanent category 6 cables have a minimum length of 15 m.

Secure Cat 6 cables with 6mm wide elastic Velcro™ ties applied at random spacing's up to 300mm apart on catenary wires and on vertical runs such that the weight of the cables are adequately supported.

Irrespective of the manufacture's recommendations ensure that the bending radius is not less than 50 mm radius (100 mm dia) during cable pulling, and not less than 25 mm radius (50 mm dia) for hand placement.

Avoid the provision of spare cable where possible unless specifically called for. If spare cable is specified as being required locate the spare cable so it is fully supported and that the minimum bending radius is maintained. Do not locate the spare cable inside service poles or skirting ducts. If spare cable is contained in loops, ensure there are no more than 4 loops in a coil and each loop is a different diameter with minimum diameter of 300 mm.

Ensure the cable sheath stripped back at any termination less than 10 mm from termination module.

Provide all facility cable as unshielded twisted pair having the following characteristics:

- Ensure the facility cables do not exceed 90m in length.
- 24 AWG 0.51mm solid plain annealed copper conductors.
- 4 pair/8 conductors.
- The insulated conductors shall be twisted into pairs, with the pairs balanced for maximum performance and noise reduction.
- Colour coded high density PVC-V75 diameter 1mm insulation.
- PVC-V75 sheath.
- 100+/- 15 Ohm.
- Conductor DC Resistance (Max): 9.38 Ohm/100m @ 20°C.
- DC Resistance unbalanced (Max): 5% @ 20°C.
- Insulation Resistance (Min): 5000 MOhm/km @ 20°C.
- Mutual Capacitance (Typical): 5.6nF/100m.
- Characteristics impedance: 100Ohm+/- 3Ohm @ 100MHz.
- Worst Case Cable Skew : 25 nsec/100 meters

If the project requires the minimisation of PVC use low smoke zero halogen (LSZH) non-PVC Cat 6 solid 4-pair cable colour grey.

Ensure the length of each cable is based on the distance set out in the tables and formulas in ISO/IEC 11801 plus de-rating for ambient temperature.

6.2.1.3 OPTICAL FIBRE CABLING

All internal cables tight buffered unless specific approval has been obtained to use an alternative cable type (loose tube) internally.

Provide optical fibre cables installed vertically with least 3 coils of at least 0.5 metre diameter at 20 m intervals to limit vertical loads on the fibres in the cable. Fully support the coils to carry the weight of the cable until the next supporting coils.

Provide all optical fibre cables with 1m of loosely looped cable within the FOBOT. Provide all loose tube cables with an additional 2m spare loosely looped cable at each end located either in the first pit or in a pre-approved location.

It is acceptable to install optical fibre cables on the same tray as the UTP provided the optical fibre cables are segregated from all other cables by either a physical barrier or by a separation distance of at least 25 mm.

Provide all OM3 optical fibre cables with the following characteristics:

- Multimode
- 50/125 um wavelength
- Sheath colour Aqua if tight buffered or Blue with OM3 printed on the sheath if loose tube.
- Maximum fibre attenuation: 3.5 dB/km at 850 nm and 1.5 dB/km at 1300 nm
- Minimum bandwidth: 1,500 MHz.km at 850 nm (OFL) and 2,000 MHz.km at 850 nm (EMB) and 500 MHz.km at 1300 nm
- Numerical aperture: 0.2
- Supported length of 550 m at 1300 nm
- Supported length of 300 m at 850 nm

- Standard Kevlar strength member.

Provide all unused optical fibre adaptors with a plastic dust cap.

Ensure all insertion losses are below the following:

- 0.3 dB for multimode mated RC to NC connectors
- 0.5 dB for single mode mated RC to NC connectors
- 0.75 dB for single mode and multimode mated NC to NC connectors
- 0.3 dB for single mode and multimode splices

All loose tube optical fibre cables are to be terminated by fusion splicing onto factory pre-terminated pigtails and tight buffered optical fibre cables are to be direct terminated or terminated by fusion splicing onto factory pre-terminated pigtails. All optical fibre connectors are to be provided with a ceramic ferrule connector with a physical contact pre-radiused ferrule installed by epoxying the connector onto the fibre end. All optical fibre connectors are to be secured to the FOBOT via a minimum of two bolts.

Crimp and adhesive type optical fibre terminations and connectors are not acceptable.

Ensure all fusion splicing complies with the following:

- Cleaved by a cleaver approved by the manufacturer providing the system warranty.
- Spliced by a fusion splicer approved by the manufacturer providing the system warranty.
- Provided with a protective sleeve.

6.2.2 CONDUITS

Ensure the communication conduit fill rates do not exceed the following:

	Conduit Size				
Cable type	25mm	32mm	40mm	50mm	100mm
Internal 8 and 12 core optical fibres	4	6	10	15	65
External 8 and 12 core optical fibres	1	3	4	6	25
Cat 5 and Cat 6 UTP	4	7	12	18	75
10 pair UTP	2	3	6	10	35
25 pair UTP	1	3	3	4	20

Provide all above ground communications conduits with draw-in boxes at least every 30m or after the equivalent of two 90-degree bends whatever being the lesser distance. The draw-in boxes are to be located in straight runs of conduit and are not to be used for bends. Provide the draw-in boxes with an IP66 screw fixed lid and a conduit saddle within 50mm of the draw-in boxes on each conduit.

6.2.3 SERVICE OUTLETS

Provide all UTP service outlets as clip in female RJ45 socket terminals, clipped into an outlet face plate. Mount the outlets with the keyway at the bottom and the contacts at the top. Provide the faceplates with a dust cover flap to prevent dust from entering the outlet when not in use. In locations where outlets are immediately adjacent, up to 6 outlets are to be accommodated on a single faceplate. The general communication outlet faceplates are to match the adjacent GPO in style, brand and colour. Ensure the outlets are a minimum of 150mm from the nearest power outlet contact.

Where there is insufficient depth behind the outlet to accommodate the cable bending radii, utilise angled faceplates. Obtain approval for the use of all angled faceplates prior to installation.

All cables must be arranged such that there is no Z bends or kinks in the cable behind the service outlet once it has been installed.

Ensure the UTP communications outlets have the following performance characteristics:

- Near End Crosstalk (NEXT) performance greater than 54dB @ 100MHz, and greater than 46dB @ 250MHz.
- RJ Interface resistance less than 20 mOhm
- Insulation resistance greater than 100 MOhm at 500 vDC
- Contact resistance less than of 20 mOhm
- Current rating greater than 2A at 20°C
- Rated for 1000 operations
- A contact force greater than 100g per contact using an FCC-approved plug.
- A plug retention force greater than 133 N.
- Rated for operation with a temperature range of -20°C to +75°C
- A minimum thickness hard gold contact plating on each pin of 1.3um
- A minimum thickness nickel contact plating on each pin of 2.0um under the gold coating.

6.2.4 INSULATION DISPLACEMENT CONNECTIONS (IDC)

Ensure all IDC's have the following performance characteristics and features:

- A minimum of 3 mechanical forces must be applied to the wire to provide a reliable and stress-free resistant connection.
- The IDC termination must have a 45 deg angular configuration when connecting with the cable conductor.
- The IDC contact element is to be spring special brass with silver plating, angularly arranged across the axis of the conductor.
- The contact range is to be silver-plated.
- The insulation displacement connectors of the outlets are to accept two insulated solid conductors of 26 to 22 AWG (0.40 - 0.65 mm) of the same size.
- Insulation resistance greater than 100 MOhm at 500 vDC
- Contact resistance less than of 20 mOhm
- Current rating greater than 2A at 20°C
- Rated for 1000 operations
- Rated for operation with a temperature range of -20°C to +75°C

6.2.5 EARTHING

Provide a dual-purpose telecommunication earthing system for both functional earthing and protective earthing purposes. Bond each communications rack and frame to a Communications Earthing Terminal (CET) Block located not more than 10m away from the communications rack or distribution frame. Bond each CET to the local power distribution system protective earth. Provide permanent machine printed labelling on / adjacent the CET with the wording "Communications Earthing Terminal". All earthing conductors are to have green/yellow insulation and a stranded copper conductor with a minimum area of 6 mm². Ensure each communications rack and frame has a resistance to earth of less than .5 ohm.

Earth a metallic cable access system with a 2.5mm² stranded copper conductor with green/yellow insulation to the power distribution system protective earth and ensure the resistance to earth is less than 1 ohm.

Ensure the communications, racks, distribution frames, pits, conduits, and cables are not located in positions the Earth Potential Rise could exceed 430 V AC under fault conditions. If the site contains a power substation or is located in a power substation hazard zone, establish the Earth Potential Rise and submit details of the Earth Potential Rise for approval prior to proceeding with the installation. In cases where the Earth Potential Rise will exceed 430 V AC under fault conditions, provide a custom engineered solution addressing the Earth Potential Rise and submit the details of the custom engineered solution for approval prior to proceeding with the installation.

6.2.6 RECORDS AND LABELLING

Label every component within the communications cabling system including though not limited to, outlets, patch panels, break out panels, cables, patch leads, racks, distribution panels, consolidation points and cable access pathways. The labelling between all components is to correspond allowing all associations between the source and destinations to be readily made. All labelling is to be arranged logically and be consecutive. Use a dash between numbers and abbreviations without any spaces.

Confirm the naming standard of the outlets and patch panels with the client. The naming standard is a 2-letter building code with room number followed by a dash followed by a sequence number - e.g. HM12-35 (HM = Hayward Midson room 12, outlet 35). The outlet sequence numbering starts at 1 and ends at the last number for the whole building. The naming standard is for the whole building not per room.

Provide a machine printed label with the wording "Communications Cabling" on all communications cable pathways every 10 metres.

All names and labels are to read from bottom to top, left to right, omitting the letters "I" and "O".

Submit the labelling scheme for approval.

Provide each distribution panel and rack containing patch panels with a patching record book that contains the records of the connection of patch panel numbers to work station outlet numbers, the date and signature of the patching installer, a schematic drawing and a floor plan of the area detailing the location and labelling of all communications outlets and equipment within the area the associated panel or rack serves. Ensure the log book is able to simply accommodate future additions, moves and changes and it contains at least 50% or three, whatever is the lesser, spare pages. All entries in the log book are to be legible and only in pencil. Clearly designate the sites name and the name of the distribution panel or rack the log book applies to on the cover and on every page of the log book.

Submit a blank example page from the log book for approval.

Provide each distribution panel and rack containing patch panels with a wall mounted laminated A3 floor plan of the area detailing the location and labelling of all communications outlets and equipment within the area the associated panel or rack serves. Include a copy of the floor plan in the operation and maintenance manual.

Ensure all racks and distribution panels are uniquely identified with the label located on the external face of any door or cover that is normally closed and on the body if the door or cover is removable or lift off. For all racks and equipment that are floor mounted, provide the unique identifying label on both the front and rear doors / covers and the body.

Provide consolidation points with a unique identifying label that also includes the cable distance back to the source rack / distribution panel.

Provide a machined typed label either clear wrap around self-adhesive type or slip-on plastic ring type or a long plastic strip type fixed onto each permanent cable within 100 - 150mm from the termination point for UTP cabling and 200 - 400mm for Optical Fibre cabling. In addition to the end labelling, provide a label on each Optical Fibre cable at each side of every penetration and at intervals no greater than 10m. Each cable label is to designate the cable type, size and source / destination.

Permanently label each communications outlet with the channel number in accordance with clause 2.10. In addition to the label that is normally visible, neatly hand write in indelible ink the channel number on the faceplate behind the surround such that it is covered when the faceplate is in place.

In cases the maximum allowable fly lead length is less than 10 metres provide the faceplate with the following additional label designating the maximum allowable fly lead length "maximum fly lead Xm"

Provide each patch lead with a unique number at each end within 150mm of the termination.

6.3 COMMISSIONING

6.3.1 GENERAL

As part of the commissioning of the communications cabling, undertake the following tests as relevant on all components of the communications cabling installation including each pair in every cable for:

- Has been fully commissioned in accordance with this specification.
- Has been fully commissioned in accordance with the requirements of the system manufacturer.
- Compliance with the cabling diagram.
- Continuity.
- Cable location, identification and length.
- The installation of all cables must be complete and the cables and terminations cleaned prior to testing.
- All tests in accordance with the communication system certifying manufacturer's requirements.
- Undertake all tests in accordance with the recommendation of the testing equipment manufacturer.
- Test the resistance to earth of each Communications Earthing Terminal (CET) Block, each communications rack and each frame.
- Test the resistance to earth of each metallic cable access system.

6.3.2 UNSHIELDED TWISTED PAIR CABLING

Test every UTP cable / link in accordance with the following requirements:

- Correct sequence.
- Reversed pairs.
- Transposition and split pairs.
- Attenuation.
- Impedance matching of all twisted pairs within each UTP cable in the form of impedance Vs distance and impedance Vs frequency graphs.
- All mechanical fixings.
- Electrical length.
- The difference between the signal attenuation and the near-end cross talk (ACR).
- Power Sum ARC (PSARC)
- Near End Cross Talk (NEXT).
- Power Sum Near End Cross Talk (PSNEXT)
- Insertion Loss,
- ELFEXT, PSELFEXT.
- Return Loss.
- Delay Skew.
- Propagation Delay.
- All Cat 5 cables and components are to be tested in accordance with the requirements specified in the latest draft of ISO 11801 Class D.
- All Cat 6 cables and components are to be tested in accordance with the requirements specified in the latest draft of ISO 11801 Class E.

The UTP cables / links are to meet or better the following requirements:

	Cat 5	Cat 6
Correct sequence.	Pass	Pass
Reversed pairs.	Pass	Pass
Transposition and split pairs.	Pass	Pass
Attenuation.	24 dB	21.7 dB
All mechanical fixings.	Pass	Pass
Electrical length.	<90m	<90m

ACR	6.1 dB	18.2 dB
PSARC	3.1 dB	15.4 dB
NEXT	30.1 dB	33.9 dB
PSNEXT	27.1 dB	37.1 dB
Insertion Loss,	24 dB	21.3 dB
ELFEXT	17.4 dB	23.2 dB
PSELFEXT.	14.4 dB	20.2 dB
Return Loss.	10 dB	12 dB
Delay Skew.	50nsec	50nsec
Propagation Delay.	548nsec	548nsec

Tester and testing equipment

- Ensure the tester batteries are adequately charged and do not fall below 25% of the total battery capacity.
- Ensure all test gear and equipment is not worn, dirty and is in good as new working order.
- Ensure the NVP is not set HIGHER than specified for the cable.
- Ensure the tester "Margin Warning" or "Star-Pass" is always enabled during testing.
- The latest software available for the tester is being used.
- The tester has been independently calibrated within 12 months of the test.

Configure the tester for Cat 6 cabling as (F/UTP PVC 65% / UTP LSZH 79% / UTP PVC 69%), permanent Link Test limit to ISO 11801 Class E and channel test limit to ISO 11801 Channel Class E.

Configure the tester for Cat 5 cabling as (F/UTP PVC 69% / UTP LSZH 70% / UTP PVC 69%), permanent Link Test limit to ISO 11801 Class D and channel test limit to ISO 11801 Channel Class D.

The following testers are acceptable:

- Fluke DTX-18003.
- Fluke DTX-1200
- LANTEK 6A and 7G
- LANTEK II
- Agilent WireScope Pro
- Agilent WireScope WS350

Negative results (eg - 0.5 dB) for NEXT or RL on runs less than 15m even though a PASS is indicated in the test results are unacceptable and must be considered as unacceptable terminations.

Poor UTP terminations must be fixed by adding twist into the pairs, re-terminated and re-tested.

6.3.3 OPTICAL FIBRE CABLING

Test every Optical Fibre core in accordance with the following requirements:

- Undertake all testing in accordance with the requirements of ISO/IEC 14763-3 and ISO/IEC 11801, using Light Source and Power Meter (LSPM). An OTDR is not acceptable for Link loss measurements.
- The optical attenuation of each fibre core at 2 appropriate wavelengths must be tested after installation in both directions (A to B and B to A) including pre-terminated cables. Only the single highest test result of each wavelength from either direction needs to be recorded (to 1 decimal place).
- Continuity and Maintenance of Polarity
- Length
- Propagation Delay

- Each termination must be visually inspected as part of the commissioning and be noted as being free of abnormalities
- Record the overall configuration of the link including connector types, cable type and length and number of splices.
- OTDR test results alone are not acceptable.
- Test the insertion loss in both directions at the following wavelengths:
 - Multimode 850 and 1300 um.

The optical fibre cables / links are to meet or better the following requirements:

	Multimode 850 um	Multimode 1300 um
Insertion loss		
Attenuation.	2.99 dB	2.48 dB
All mechanical fixings.	Pass	
Length.		
Continuity	Pass	
Maintenance of Polarity	Pass	
Propagation Delay.		

Provide a Light Source & Power Meter (LSPM) and an Optical Time Domain Reflectometer (OTDR). Ensure all optical fibre testers have been warmed up for 15 minutes prior to commencing testing.

Where LSPM results exceed the Power Loss allowance, use an OTDR to determine the location of the faulty component.

Where the connectors on the LSPM tester are different from the connectors on the Link to be tested (E.g. SC on tester Receive port and MTRJ on Link), use the 3-Test Cord Method of Reference Setting as per CI 9.1.1.2 of ISO/IEC 14763-3.

Ensure the continuity and polarity of each optical fibre core / termination by either inspecting opposite ends at the same time with a red light source, or by using an LSPM that has been connected to the fibre at the far end, or by using an OTDR with a 'tail cord' connected to the correct fibre at the far end.

Record the cable length marking at each end of the installed cable.

Record the propagation delay on the test sheet by manually calculating it or as recorded by the tester. The propagation delay is to be manually calculated as (propagation delay (in nS) = 5.0 x length in m.

Ensure the connectors on the LSPM tester are the same as the connectors on the core being tested.

Ensure the LSPM Tester is able to meet Encircled Flux requirement in the launch test cord for all multimode cables. Ensure 3mm LSPM launch cords have at least 5 x turns of 17 mm diameter for 62.5 µm and 22 mm diameter for 50 µm cores. Ensure the LSPM launch cord has at least 2 x turns of 40±5 mm diameter, air-coiled or on a mandrel, for all single mode cables. Ensure the launch cord meets the reference conductor requirements and the tail cord insertion loss is less than 0.1 dB for multimode cables and 0.2 dB for single mode cables. The performance of the launch and tail cords are to be confirmed at the start of testing every day and at least once every four hours of continuous testing.

Ensure the OTDR launch and tail cords are longer than the dead zone of the OTDR and the launch cord is at least 25% longer than the tail cord. Use the lowest OTDR pulse width on cables that are less than 300m long. Configure the OTDR and test setup so ghosts are not present in the main part of the OTDR trace.

6.3.4 TEST RESULTS

Provide a copy of the "Plot Data Enabled" test results for each UTP cable and each core of each optical fibre cable in a recognised test vendor's application format such as Fluke LinkWare or Agilent DataScope Pro or LANTEK Reporter as well as a copy of all results in PDF. Ensure the test results contain all of the testing and commissioning information required by section 6.3. Ensure the test results are / include:

- A single file containing all the final commissioning and test results.
- All results and data are relevant to this project.
- The number of test results the number the number of test results on the communications system manufactures system warranty form.
- An explanation is provided for all missing cable identification.
- Include a copy of all test results in the operation and maintenance manual.

Supply a copy of the latest NATA calibration certifications for test instruments that are to be used, before any testing commences.

Schedule the results for each item and component and include a copy of test results in the operation and maintenance manual. Typical test result forms are available from the Electrical Design Group web site www.edg.net.au.

As part of the commissioning of the communications cabling, undertake any necessary adjustments to components of the communications cabling installation which have integral adjustment capacity.

Upon the completion of the commissioning of the communications cabling provide a written and signed statement that the communications cabling installation:

- Has been fully programmed as necessary.
- Has been tested.
- Complies with the intent of the contract.
- Complies with the relevant authority requirements.
- Complies with the relevant standards and codes.
- Is fit for purpose and suitable for the intended use.

Include a copy of the communications installation statement of compliance in the operation and maintenance manual. A typical communications installation statement of compliance form is available from the Electrical Design Group web site www.edg.net.au

6.4 PATCH PANELS

Provide UTP patch panels as modular, 1RU high, 24 port, Cat 6, RJ45 19inch rack mounted, black fully numbered with outlets to the same specification and performance as the respective service outlets with the worst pair NEXT loss values for the outlet greater than 54dB at 100MHz and greater than 46dB at 250MHz. The rear of the patch panels are to be provided with integrated cable management supports, strain relief posts, colour coded wiring guides and IDC's to facilitate cable termination. Provide patch panels with modular ports that can be removed and that facilitate access to the IDC's without having to remove the entire patch panel.

Provide sufficient patch panels to accommodate all of the facility cabling with a dedicated patch panel port for each service outlet. Provide sufficient patch panel ports to accommodate all of the tie cables with 2 pairs per patch panel port for tie cables.

7.0 SECURITY

7.1 SCOPE

The security system component of this contract includes the expansion / upgrade of the schools existing Inner Range access control / security system to provide intruder detection and access control in both new buildings.

Connect the new security equipment in each building to the schools existing via fibre modems utilising the optical fibre cabling provided in section 6.0 of this specification. Provide all necessary optical fibre patch and fly leads to complete the system.

The security system component of this contract includes but is not limited to the following extent of work:

- Intruder detection system power supply and distribution.
- Earthing.
- Movement detectors.
- Piezo Alarms.
- Key panels.
- Zone expanders.
- Data bus.
- Cabling.
- Patch leads and fly leads.
- Conduit access.

The existing security panels are to be removed / relocated as required and all new panels located in the position created by the removal of the telephone distribution frames to allow a new door to be cut into the electrical plant room.

Provide comprehensive details of the proposed equipment and components of the security system for approval prior to ordering.

Ensure all security system work is completed by a current member ASIAL. Provide a copy of the ASIAL membership of each staff member working on the security system component of the project for approval prior to the commencement of work. Include a copy of such licences in the operation and maintenance manual.

As part of the tender submission the Electrical Sub Contractor must include for all contractual requirements and costs required by the suppliers to the electrical sub-contract to provide the necessary samples. The Electrical Sub Contractor must bear the cost of supplying samples of the components specifically specified as well as those specified generically or by performance.

All suppliers and sub-contractors to the Electrical Sub Contractor must ensure they are familiar with and comply with the requirements of sections 1.0, 2.0 and 3.0 of this specification

7.2 INSTALLATION

Use multi-stranded copper conductor V75 PVC insulated or V75 PVC-insulated and PVC-sheathed stranded cables for all 240-volt cabling. Use flooded PVC insulated and PE sheathed cables for all cables run underground.

The cable type and sizes indicated on the drawings are provided as a minimum only. The attenuation, interference and voltage drop of the cables must be established by the Electrical Sub Contractor and the cables sized accordingly by the Electrical Sub Contractor. Size all cables to accommodate the respective signals, loads and maintain a spare capacity of 10%. All signals and loads must be confirmed on site by the Electrical Sub Contractor with the actual equipment being supplied. Provide the detector cabling as solid Cu PVC 6 core intruder detection cable and the reed switch cabling as solid Fig 8 Cu PVC cable. Where security system equipment is connected by a communications cable, provide the cable in accordance with the security system manufacture's requirements. Provide configuration, route, pinout and earthing details of such communications cables with the shop drawings.

Install all cabling clear of electric motors, neon signage, transformers etc. In locations with a high level of RF or EM radiation, ensure that the cables are properly shielded from interference.

Segregate the security system cables from other services.

Ensure all enclosures are appropriate for the location they are intended to be installed in and have appropriate space and capacity to contain all equipment and cabling in the final configuration.

The accessories' sizes indicated on the drawings are provided as a minimum only. All components and sizes must be confirmed on site with the actual equipment being supplied.

7.3 COMMISSIONING

7.3.1 GENERAL

As part of the commissioning, ensure all components of the security system are adjusted, programmed and are operating correctly.

As part of the commissioning of the security system, undertake the following tests as relevant on all components of the security system installation:

- Has been fully commissioned in accordance with this specification.
- Power availability.
- Resistance to earth.
- Signal strength.
- Fault protection.
- All mechanical fixings.
- System operation.

Schedule the results for each item and component for approval and include a copy of each test result in the operation and maintenance manual. Typical test result forms are available from the Electrical Design Group web site www.edg.net.au

As part of the commissioning of the security system, undertake any necessary adjustments to components of the security system installation which have integral adjustment capacity.

Upon the completion of the commissioning of the security system provide a written and signed statement that the security system installation:

- Has been fully programmed as necessary.
- Has been tested.
- Complies with the intent of the contract.
- Complies with the relevant authority requirements.
- Complies with the relevant standards and codes.
- Is fit for purpose and suitable for the intended use.

Include a copy of the statement of compliance in the operation and maintenance manual. A typical security system installation statement of compliance form is available from the Electrical Design Group web site www.edg.net.au

7.3.2 ADJUSTING AND AIMING OF SECURITY SYSTEM INSTALLATION

Ensure the following components of the security system installation are complete and have been checked and tested prior to the adjusting and aiming of the security system installation to commence:

- Labelling.
- Correct operation of the security system.
- All components have been installed and are operating.

Should these items not be complete prior to the adjusting and aiming of security system installation the additional expenses in re-attending the installation to undertake the adjusting and aiming of the security system installation as incurred by the engineer will be charged to the Electrical Sub Contractor.

Provide all equipment such as ladders, scaffolding and tools necessary for adjusting each detector. Should the Electrical Sub Contractor not have available the necessary equipment to complete the adjusting and aiming of the security system installation, the additional expenses in re-attending the installation to undertake the adjusting and aiming of the security system installation as incurred by the engineer will be charged to the Electrical Sub Contractor.

The adjusting and aiming of the security system installation will include the following:

- Adjusting mountings and brackets.
- Aiming of detectors.
- Testing all operations of the security system.

Allow to attend site twice during the defects and liability period and undertake the above adjustments to and reprogram as directed by the operator the security system.

7.4 EQUIPMENT

Provide the expander panels to the following requirements:

- Wall mounted in electrical services cupboard.
- Internal 8-hour Li Ion battery backup.
- Tamper switch.
- Expanded memory.
- All necessary zone expanders.
- Inner range concept 3000.
- Modular expandable system.
- 240-volt 50 Hz power supply.
- Operating temperature 0°C to 40°C.

Provide movement detectors to the following requirements:

- Surface mounted on an adjustable bracket.
- LED walk through feature disabled.
- Built-in resistor and an external test point.
- Dual technology.
- Tamper switch.
- Closed loop configuration.
- Each detector wired as a dedicated zone.

Provide Pizeo Alarms to all internal areas covered by movement detectors, with the following features:

- Flush mounted.
- Single alarm zone.
- Coloured to match the ceiling colour.

Provide arming-disarming key panels with the following features:

- Wall Mounted at 1400AFFL.
- Alphanumeric back illuminated display.
- Key pad.
- Tamper switch.
- Hinged cover flap.

8.0 PA SCHOOL BELL SYSTEM

8.1 SCOPE

The school is currently replacing the existing PA School Bell system with a Terracom system that will distribute all signals via the school's ethernet network to Ethernet to Audio interface units located in CR located in the communications racks within each building. The Ethernet to Audio interface units are then to be connected to conventional audio amplifiers located in the communications rack. Conventional speakers and horns are to distribute signal throughout the buildings and grounds.

The PA School Bell system component of this contract includes the facility to instigate lockdown, alert, evacuation via a four-button wall mounted alarm panel (ALP). The ALP is to connect to the school's ethernet network via Terracom Terra-IO unit located in CR-D. Provide the ALP with a power supply such that the respective lockdown, alert and evacuation button is illuminated upon activation. The Terracom Terra-IO unit is to control the illumination. The reset button is not illuminated and its operation is to turn off the associated alarm and buttons illumination.

Provide the Prep building communications rack CR-D with two amplifiers to drive the Prep buildings speakers. Zone one of the amplifiers to drive 12 external horns and the remaining amplifier to drive the internal speakers. Connect the Prep building amplifiers to the schools existing PA school bell system as an IP signal distributed through the school's ethernet network via Terracom Terra-EX Ethernet to Audio interface units located in CR-D.

Provide the Viking building communications rack CR-1 with three amplifiers to drive the Viking buildings speakers. Zone one of the amplifiers to drive the ground level dining speaker the second amplifier to drive 12 external horns and the remaining amplifier to drive the remaining internal speakers. Connect the Viking building amplifiers to the schools existing PA school bell system as an IP signal distributed through the school's ethernet network via Terracom Terra-EX Ethernet to Audio interface units located in CR-1.

A.B.C. Alarms Pty. Ltd. PO Box 128 Holland Park West Brisbane Queensland 4121 Ph (24 Hrs): (07) 3849 1939 (1300 795 910) Fax: (07) 3849 1940 (1300 795 920) Andre Cafun andrec@abcalarms.com.au 0408 917 505 Stewart stewartp@abcalarms.com.au 0431 543 716 is to be engaged as a nominated sub contractor to supply and commission the Terracom equipment.

Provide a copy of the schematic and layout of the proposed Terracom system within the Viking Café and Prep Building for approval. Include the details of amplifiers and speaker zones in the schematics to be submitted for approval.

Provide a radio microphone system in the Viking building with a fixed microphone duplex antenna in the ground floor dining room connected to the dining room speakers. The radio microphone system is to include a Mipro ACT-300B Dual-Channel Diversity Receiver mounted in CR-1 and a hand held radio microphone.

Provide a copy of the proposed radio system schematic and layout for approval.

Obtain from the school's IT department the IP Address, the Subnet Mask and the Gateway ID for each of the Ethernet to Audio interface units to be connected to the school's communications network.

All to mount the external speakers on existing structures within 50m of each of the new buildings. The school will confirm the positions of the external speakers on site prior to roughin.

Provide each of the three internal amplifier zones with a hearing augmentation IR transmitter mounted in the same rack as the amplifier. Provide each building with 8 ceiling mounted hearing augmentation IR radiators connected to the transmitters to distribute the appropriate audio signals. Confirm the radiator colour (Black or White) on site with the school. Provide the hearing augmentation such that it is compatible with the schools existing hearing augmentation equipment.

Provide a copy of the proposed hearing augmentation system schematic and layout for approval.

Size the amplifiers capable of driving 200% of all of the associated buildings speakers when tapped at 75%.

Each speaker and horn is to be cabled individually in star configuration to the rack.

Locate the amplifier in the top RUs of the rack.

The PA School Bell system component of this contract includes but is not limited to the following extent of work:

- Prep building ALP.
- ALP IO to Ethernet interface.
- No longer required.
- No longer required
- Ethernet to Audio interface units.
- Amplifiers.
- Speakers.
- Horns.
- Cabling.
- Conduit access.
- 24 No External horns not located on the drawings.
- Radio microphone system not located on the drawings.
- Hearing augmentation IR transmitters.
- 2 x 8 hearing augmentation IR radiators not located on the drawings.

All suppliers and sub-contractors to the Electrical Sub Contractor must ensure they are familiar with and comply with the requirements of sections 1.0, 2.0 and 3.0 of this specification

8.2 INSTALLATION

8.2.1 CABLING

Provide the Figure 8 cable to the following characteristics:

- Dual colour PVC insulation.
- 2 off 19 AWG conductors.
- 24/0.20 stranded bare copper conductors.

Terminate the Figure 8 cables into the screw terminal of the equipment and speakers or soldered to RCA outlets as required.

Run all audio cabling clear of electric motors, neon signage, transformers etc. In locations with a high level of RF or EM radiation, ensure that the cables are properly shielded from interference. Ensure all of the audio system cabling is segregated from all other services.

8.2.2 HOUSINGS

Ensure all enclosures are appropriate for the location they are intended to be installed in and have appropriate space and capacity to contain all equipment and cabling in the final configuration.

8.2.3 ACCESSORIES

The accessories' sizes indicated on the drawings are provided as a minimum only. All components and sizes must be confirmed on site by the Electrical Sub Contractor with the actual equipment being supplied.

8.3 COMMISSIONING

8.3.1 GENERAL

As part of the commissioning, ensure all components of the audio system are adjusted, programmed and are operating to the requirements of the project manager.

As part of the commissioning of the audio undertake the following tests as relevant on all components of the audio installation:

- Has been fully commissioned in accordance with this specification.
- Phase sequence.
- Power availability.
- Resistance to earth.
- Signal strength.
- Sound levels.
- Fault protection.
- All mechanical fixings.
- System operation.

Schedule the results for each item and component for approval and include a copy in the operation and maintenance manual. Typical test result forms are available from the Electrical Design Group web site www.edg.net.au

As part of the commissioning of the audio system, undertake any necessary adjustments to components of the audio system installation which have integral adjustment capacity.

Upon the completion of the commissioning of the audio system, provide a written and signed statement that the audio system installation:

- Has been fully programmed as necessary.
- Has been tested.
- Complies with the intent of the contract.
- Complies with the relevant authority requirements.
- Complies with the relevant standards and codes.
- Is fit for purpose and suitable for the intended use.

Include a copy of the audio installation statement of compliance in the operation and maintenance manual. A typical audio installation statement of compliance form is available from the Electrical Design Group web site www.edg.net.au

8.3.2 ADJUSTING OF THE AUDIO INSTALLATION

Ensure the following components of the audio installation are complete and have been checked and tested prior to the adjusting of the audio installation to commence:

- Labelling.
- Correct operation of the audio system.

Should these items not be complete prior to the adjusting of the audio installation, the additional expenses in re-attending the installation to undertake the adjusting of the audio installation as incurred by the engineer will be charged to the Electrical Sub Contractor.

Allow for the adjustment of speakers over a period of 2 hours to achieve final set-up. This work will be carried out under the direction of and to the satisfaction of the project manager.

Provide all equipment such as ladders, scaffolding and tools necessary for adjusting each speaker. Should the Electrical Sub Contractor not have available the necessary equipment to complete the adjusting and aiming of the audio installation the additional expenses in re-attending the installation to undertake the adjusting and aiming of the audio installation as incurred by the project manager will be charged to the Electrical Sub Contractor.

The adjusting of the audio installation will include the following:

- Adjusting mountings and brackets.

- Balancing of speakers.
- Testing all operations of the audio system.

Allow to attend site twice during the defects and liability period and undertake the above adjustments to the audio system.

9.0 FIRE ALARM SYSTEM

9.1 SCOPE

The fire alarm system scope is to include a new **AS1670.1 compliant** fire alarm system within each building as an expansion of the sites existing fire alarm system. The FIP within each building is to be connected to the existing loop in loop out optical fibre ring.

Utilise the 12 core optical fibre cabling provided as part of the communications cabling component of the electrical sub contract.

Provide fail safe signals from the FIP to the security system and each of the MSSBs to unlock / shutdown upon alarm.

The contractor is responsible for paying any call out fees issued by QFES that are the result of defective works, cabling or system components

Ensure all works installed under the fire alarm system component of the electrical sub-contract is undertaken by, or under the direction of a suitably qualified and experienced fire alarm system installer who hold the required QBCC and Fire Protection Contractors Registration Board of Queensland Inc registrations.

Prior to practical completion certify the installation on a Form 16 as complying with the relevant codes and standards.

This contract requires the contractor to provide the following performance guarantees:

- That all components will have adequate size, capacity and performance.
- The installation will be acceptable to the Queensland Fire and Emergency Service.
- The installation will not be subject to faulty equipment or workmanship.
- The installation will not be subject to undue false alarms.
- The installation will be considered fit for purpose.

This contract includes but is not limited to the following specific items extent of work:

- Fire Indicator Panel (FIP) and all associate components.
- Duct probe smoke detectors.
- Smoke detectors.
- Thermal detectors.
- Concealed space detectors.
- Addressable concealed space smoke detectors.
- Interface and monitoring of all sprinkler and hydrant system points.
- System interface diagram (AS1851)
- Speakers and horns.
- Provision of any additional speakers and horns to achieve evacuation sound levels with a minimum of 10dB (A) above ambient, and not less than 65dB (A) and no more than 105dB (A).
- Connect the FIP within each building to the access control system and all doors required to unlock or open upon alarm via a failsafe signal.
- Connect the FIP to each mechanical switchboard MSSB to indicate the alarm status to shut down the required mechanical services upon alarm.
- Cabling.
- Maintenance.
- Log book.
- Maintenance during the defects and liability period in accordance with MP6.1 of the QDC and AS1851.
- Pay all costs associated with the isolation and reconnection of the brigade monitoring of the fire alarm system.
- Connect each of the fire alarm systems to the sites existing fire alarm monitoring system via the optical fibre network.

Ensure all equipment used has all relevant authority approvals and include a copy of such approvals within the manual. Provide a copy of the authority approvals with the shop drawings.

The work must be performed by a Contractor registered by the QBCC and Fire Protection Contractors Registration Board of Queensland Inc. Provide a copy of the contractor's registration's for approval prior to commencing work and include a copy in the manual.

9.2 INSTALLATION REQUIREMENTS

Ensure that all components and equipment installed as part of the fire alarm system are suitable for the intended location and use.

Provide all wiring within the fire alarm system as "loop-in loop-out" with no joints, except at fittings. Ensure that detector wiring does not pass through a battery compartment. Provide all wiring from the FIP to relays, contactors and control equipment, including air handling plant shut down and the like to be fail safe, supervised circuits using red sheath. It is acceptable to utilise the existing wiring if it is in acceptable condition and meets the requirements of this specification.

Ensure that all wiring within the fire alarm system complies with the following:

- 240-volt wiring: 1.5mm² (stranded) minimum.
- DC wiring: 1.5mm² (stranded) minimum.
- Wiring to remote indicators: 0.75mm² (stranded).
- 240 V wiring: Grey sheath.
- DC fire alarm wiring: Red sheath.
- Multi-stranded copper conductors.
- All smoke fan control wiring is fire rated.

Completely separate all speakers wiring from 240-volt wiring. Space fire alarm system cabling from all other wiring or otherwise protected, to ensure that the magnitude of induced voltages cannot cause interference.

The current capacity, voltage drop and fault capacity of the cables must be established by the Contractor and the cables sized accordingly by the Contractor. Size all cables to accommodate the respective loads, starting currents and maintain a spare capacity of 10%. All loads and fault levels must be confirmed onsite by the Contractor. Provide all components with 25% spare capacity.

Ensure the fire alarm system cabling is protected from mechanical damage and complies with AS 3013 and all fire rated cabling meets or exceeds WS52W installation requirements. Secure all fire alarm system cabling with stainless steel cable ties.

Unless otherwise specified, install and terminate cables in accordance with the manufacturers' recommendations.

Ensure oil, wax and powder based electrical cable lubricants are not used as cable lubricants. If cable lubricants are required to be used then use polymer-based for copper cables and silicon-based for optical fibre cables.

Remove redundant equipment and wiring, including that in accessible ceiling spaces, and make good exposed surfaces before commencing the installation of new wiring.

Handle cables so as to avoid damage to insulation and serving or sheathing. Replace all wiring with insulation damage after determining and removing the cause of damage.

Identify multicore cables at each end and at crowded intermediate points by means of stamped, non-ferrous tags, clipped around each cable, or trefoil group.

Install and adequately support fixed wiring as specified throughout the installation. In accessible false ceilings, keep cables clear of all ceiling insulating material and/or removable ceiling tiles by securely fixing the cabling to permanent structural members. If the structural members are more than 1,200mm above the suspended ceiling, provide a catenary support system. It is not allowable to fix cables to the ceiling hangers.

Provide flexible connections or an approved form of vibration/movement isolation on the terminations of all cables that will experience vibration or movement under their normal operation.

Cable installation in areas where there are motors and/or generators shall comply with the guidelines set out in AS/NZS 3548 and AS/NZS 2834.

All cabling and cable support systems are to comply with requirements of AS 1170.4 (earthquake).

All penetrations through building elements used as cable penetrations are to be dedicated to cabling.

9.3 COMMISSIONING

9.3.1 TESTING

Undertake on site the following tests:

- Insulation resistance measurements.
- Functional checks: Full functional and operational checks on energised control equipment and circuits, including adjustments for the correct operation of safety devices.
- Earth resistance.
- Earthing: Confirmation of effective earthing of the exposed metal of all equipment.

During testing, replace fuses and equipment damaged as a result of incorrect installation work.

Provide all Test Results for approval within one (1) week of the test being undertaken on A4 paper and as an electronic PDF file copy on CD for approval.

Check control systems for correct operation under representative operational conditions.

9.3.2 COMMISSIONING

As part of the commissioning, ensure that all components of the installation are adjusted, programmed and are operating correctly in accordance with the manufacturer's recommendations and the relevant standard the equipment has been installed.

Submit for approval two prior to commencing any testing and commissioning a testing and commissioning method statement and program for the commissioning and testing.

As part of the commissioning of the fire alarm system, undertake the following tests as relevant on all components of the fire alarm installation:

- All testing required by AS 1670.
- Authorities' tests: Additional tests, which may be required by the relevant authority.
- Resistance to earth.
- Voltage.
- Overload protection.
- Fault protection.
- All mechanical fixings.
- Map of sound pressure levels at Floor Level.
- The operation of the fans under both simulated automatic and manual control conditions.
- The operation of each MCP and detector.
- The operation of the FIP.
- The operation of the brigade monitoring system.
- The operation of the monitoring of each circuit.

Provide at least two qualified personnel with two-way radios for all testing and commissioning. Ensure all testing equipment is calibrated, within the past six (6) months, and provide supporting documentation of the calibration upon request.

The testing equipment includes, though is not limited to the following:

- Smoke Detector Testing apparatus approved by detector manufacturer
- Thermal Detector Calibrated heater tester
- Manual Call Points (MCP) Suitable MCP Key
- Occupancy Warning speaker Sound level meter and Speech Transmission Index (STI) meter

Schedule the results for each item and component and include a copy of all test results in the manual.

As part of the commissioning of the fire alarm, undertake any necessary adjustments to the installation.

Upon the completion of the commissioning, provide a written and signed statement that the installation:

- Has been fully programmed as necessary.
- Has been tested.
- Complies with the intent of the contract.
- Complies with the relevant authority requirements.
- Complies with the relevant standards and codes.
- Is fit for purpose and suitable for the intended use.

Provide a copy of the statement of compliance in the manual.

Ensure the following components of the installation are complete and have been checked and tested prior to commissioning:

- Labelling.
- Correct operation of the fire alarm system.
- All components have been installed and are operating.

Should these items not be complete prior to the commissioning the additional expenses in re-attending the installation to witness the commissioning as incurred by the engineer will be charged to the Contractor.

Provide all equipment such as ladders, scaffolding and tools necessary for adjusting each detector and speaker. Should the Contractor not have available the necessary equipment to complete the commissioning, the additional expenses in re-attending the witnessing of the commissioning as incurred by the engineer will be charged to the Contractor.

The commissioning of the installation will include the following:

- Adjusting mountings and brackets.
- Adjusting detectors.
- Testing all operations of the fire alarm system.
- Balancing of all speakers.

Demonstrate to the satisfaction of the Authorities the operation of the systems installed in accordance with Authority requirement.

Commission all components to ensure the correct interfacing operation and control of all systems to the satisfaction of the engineer as per the approved commissioning method statement and commissioning plan. Arrange for and give two weeks' notice so the commissioning may be witnessed for approval.

Provide all necessary software, equipment and personnel to fully program and configure all systems.

Following the completion of the commissioning and prior to Practical Completion thoroughly clean all components of the installation to the satisfaction of the engineer.

Following commissioning, operate each component and system at the convenience of the engineer to the satisfaction to provide evidence to the engineer that each component and system is working correctly.

Maintain a record of all settings, set point and offsets throughout the commissioning period and included in the manual. Update the manual record following the completion of each of the post practical completion commissioning requirements. The defects and liability period will not end until the manual has been updated.

As part of the commissioning process ensure the following actions are completed:

- Check that time schedules enable the intended operation at/for the correct times.
- Check that the calendar/date function can take leap years into account.
- Check the correct operation of the interfaces by individually switching each item of plant.
- Check for the correct sequencing control in response to varying inputs operates in the correct order and at the desired set points.

Check the control system to confirm its specified operation following a mains power supply failure. In particular undertake the following checks:

- Check that controllers preserve control strategy configuration data for a specified period when the mains power is lost.
- Check that the condition of any volatile data protection system is regularly and automatically monitored. Check that an alarm is raised on loss of mains supply by any controller or device.
- Check that the system operates correctly under battery power without mains power.
- Check that the system will automatically return to normal action without operator intervention restoration of the mains electrical power supply.

Check the application software and certify quality control off-site. Specific items or routines to be checked include though is not limited to:

- Specified set points have been configured.
- Each control loop is in place and that realistic default values have been added to enable commissioning to proceed.
- Configured software will operate the specified events, alarm and items of plant in the correct sequence.
- All specified alarms are configured along with any the required time delays, masking and alarm categorisation in order to avoid unwarranted alarms.
- The use of mnemonics and abbreviations is checked between the display and the graphics to avoid inconsistencies.
- Data logging routines and parameters are set up in accordance with the control system specification.

9.4 MAINTENANCE

Provide maintenance of the complete fire alarm system for the defects and liability period. Undertake all inspections, tests, maintenance services and repairs in accordance with the equipment manufacturer's recommendations/ instructions, the Queensland Development Code MP6.1, AS 1851-2005 and the emergency services authority requirements.

Ensure the fire alarm system is maintained in a safe and operative condition. Ensure minimum interruption to the operation of the fire alarm system during the maintenance procedures. Coordinate the start and completion of each maintenance session with the Building Manager.

Ensure all maintenance and associated certification is completed by competent, experienced and licensed technicians equipped with the appropriate testing instruments, tools, equipment, etc. All such maintenance and testing tools and equipment must be appropriate and calibrated for the required task.

At the end of the defects and liability period, provide certification all maintenance has been completed in accordance at the end the annual maintenance period in accordance with the equipment manufacturer's recommendations/ instructions, the Queensland Development Code MP6.1, AS 1851-2005 and the emergency services authority requirements.

Record all maintenance events within the log book.

9.5 DETECTORS

Provide all detectors as addressable and ensure they comply with the requirements of AS1670 and are compatible with the FIP. Reduce the number of detectors permitted to an alarm zone to 75% of that allowed under AS1670.

Provide detectors of a type that will be effective in the location and avoid false alarms.

Unless noted otherwise, provide thermal detectors that comply with AS 1603.1, AS 7240.5, and are type A and smoke detectors that comply with AS 1603.2, AS 7240.7, and are the type photo-optical unless noted otherwise. Ensure the sampling device smoke detectors comply with AS 1603.13. During construction protect all smoke detectors from the build-up of dust and contamination due to building work. Remove the protective covers immediately prior though no earlier than 24 hours prior to practical completion.

Locate and select detectors used to initiate smoke control systems in accordance with AS 1668.1.

Provide detectors that are two part (removable plug and fixed base). Ensure all detectors include an indicator to identify activation.

Provide remote indicator in accordance with AS1603.15 comprising a light emitting diode mounted on an engraved plastic plate identifying the location of the detector for each detector located in a concealed position including locked cupboards.

Provide concealed space detectors as a proprietary item suitable for a concealed space depth of 600mm to 3,000mm, of a type that they can be removed through the exposed surface faceplate and man holes or access panels are not required for maintenance.

9.6 SPEAKERS

Provide speakers in accordance with AS1670.4 to achieve the sound levels as specified in AS1670. The speaker types and locations detailed on the drawings are indicative of an acceptable type and layout. It is the Contractor's responsibility to ensure that the installation meets the tone and alert requirements of AS1670.

Provide ceiling speakers with the following:

- 8 Ohms impedance.
- 93 dB sensitivity.
- Full range multi tapped transformer.
- Circuit fault monitoring.
- Screwed terminal block.
- Match the adjacent sound system (bell, PA or music) speakers or 200mm Dia if the project does not include a sound system.
- Plastic flush grille colour to match the ceiling colour unless noted otherwise.
- Frequency response 60 Hz to 20 kHz.
- Flush mounted in all suspended ceilings.

Provide horn speakers with the following:

- 8 Ohms impedance.
- Full range multi tapped transformer.
- Circuit fault monitoring.
- Screwed terminal block.
- Match the adjacent sound system (bell, PA or music) horn speakers if the project includes a sound system.
- Surface mounted adjustable bracket.
- Metal construction.
- IP56.

10.0 BMS

10.1 SCOPE

The BMS component of the works is to be undertaken by Environmental Automation Unit 37-1631 Wynnum Road, Tingalpa QLD 4173 contact Isaac Prior (07) 3648 5851 0488 207 151 Isaac Prior Isaac.Prior@aragroup.com.au as a nominated sub-contractor to the electrical sub contract.

The nominated BMS sub-contractor is to supply and install controllers within the mechanical services switchboards MSSBs as a nominated BMS sub-contractor to the mechanical services sub contract. The controllers provided as part of the mechanical services sub contract are to comply with all aspects of this specification.

The long-term aim is to expand the schools BMS to manage all aspects of the school's energy consumption over an already embedded IP network.

Expand the schools existing Reliable Controls building management system utilising Mach Pro Web Series controllers including all licencing costs as well as commissioning and updating the existing graphical user interfaces to include the existing BMS services and new BMS services as a seamless single installation.

Fully commissioning and update the BMS and its graphical user interfaces at the following times to the satisfaction of the superintendent:

- Practical Completion.
- One month post Practical Completion.
- Six months post Practical Completion.
- One year post Practical Completion.

Provide BMS IO controllers within the distribution boards with each circuit noted as being controlled via the BMS controlled via a dedicated addressable port. The inputs are to be via separate DALI buses in the Viking Café and the Prep Buildings. Connect the BMS IO controllers to the BMS Energy Management System via an on-board IP RJ45 Ethernet port. Coordinate the IP address and network permissions with the school's IT staff.

Connect the DALI bus controllers to the BMS Energy Management System via an on-board IP RJ45 Ethernet port via IP BACnet IP. Coordinate the IP address and network permissions with the school's IT staff.

Provide details of the BMS system and DALI Bus components and schematics for approval.

All components of the BMS must be compatible with the schools incumbent Reliable Controls energy management system BMS utilising the schools ethernet based Cat6 / fibre optic communications network. Provide the BMS controllers that communicate using BACnet IP the schools ethernet based Cat6 / fibre optic communications network.

Master controllers with distributed IO are not acceptable. RS485 and RS495 networks between switchboards, distribution boards or control panels are not acceptable.

BACnet MSTP or Modbus RTU protocols must only be used for connection to equipment located within the same switchboard, distribution board or control panel which houses the BMS controller and must be only used to provide direct high-level interface data.

At the end of the defects liability period the BMS supplier must provide all administration level passwords to the school and provide a sufficient training to the end user and their representatives in all aspects of the software including but not limited to, programming controllers, adding and editing graphic pages, creating and modifying alarms and creating histories.

The BMS component of the contract includes but is not limited to the following specific items extent of work:

- Controllers.

- Associated switch panels.
- Associated output relays and contactors.
- Connection and integration of the Mitsubishi Electric AE200 air conditioning centralised controller in each of the three mechanical services switchboards to the BMS.
- Connection and integration of the BACnet ethernet IP controllers within each of the three mechanical services switchboards to the BMS.
- Control of the mechanical services through the BMS.
- Cabling.
- Attendance at a handover meeting.
- Co-ordination.
- Approvals.
- Shop drawings.
- Work-as-executed drawings.
- Inspections.
- Testing and commissioning.
- Maintenance.
- Software.
- Licences.
- Programming.
- Manuals.
- Cabling, cable support systems and access.
- Cat 6 communications cabling.
- 240 volt power supplies including cabling.
- Monitoring of the lift pit water level alarm in each building. Not detailed on the drawings.
- Control of each circuit supplying hot water. No detailed on the drawings.
- All minor components and incidental works not specifically referred to, however necessary to complete the BMS installation such that it is handed over complete, operational and fit for the intended use.

All of the cat 6 cabling is to be undertaken in accordance with section 6.0 of this specification.

The BMS will be further expanded as part of separate future contracts to the remaining areas of the school as the remaining areas are renovated or when approved / requested by the school.

Expand upon the BMS's existing web-based functionality maintaining access from any computer connected to the network or network via a standard web browser. Ensure the system provides the ability to manage the system on a day to day basis, view graphics, set up trend logs, change set points and time schedules, and view and acknowledge alarms. Maintain the BMS such that it is reconfigurable from either a standard web browser anywhere on the network, or via engineering software loaded onto the site server PC with enhanced password protection protocol.

Undertake a detailed study of the potential demand management opportunities of the equipment controlled by the BMS and develop a demand management strategy in conjunction with the school. The demand management strategy is to utilise the BMS to automatically reduce loads based upon predefined criteria including demand set points.

10.2 SYSTEM REQUIREMENTS

The BMS comprises a network of interoperable, stand-alone digital controllers, graphics and programming and other control devices as required.

Provide secure password access to all features, functions and data.

The BMS is to utilise an open protocol BACnet IP control platform that will allow additional interfaces, expansion and changes without further licence or software costs. The system is to allow for the connection of any brand of BACnet ethernet IP based device.

Maintain the BMS's open, interoperable, integrated architecture that utilises peer-to-peer networked, stand-alone, distributed control.

The system is to incorporate the ability to access all data using HTML5 enabled browsers without requiring proprietary operator interface and configuration programs or browser plug-ins. Systems requiring a proprietary database and user interface programs or do not utilise HTML 5 are not acceptable.

Obtain from the schools IT department the IP Address, the Subnet Mask, the Gateway and the BACnet ID for each component connected to the schools communications network.

Update the following software packages installed to the Virtual Server to accommodate the expansion of the BMS:

- RC Studio
- RC Archive
- RC WebView
- RC Reporter
- RC Remote Access

All of the BMS devices are to utilise the open standard protocol (ASHRAE Standard 135) and have a formal certificate of conformance confirming the product has been independently tested by a recognized test organization and has passed all BACnet Testing Laboratories (BTL) testing requirements. Include a copy of each devices certificate within the manual.

10.3 CONTROLLERS

Ensure the BMS controllers are capable of fully independent operation regardless of the network status.

Ensure the BMS controllers are DIN rail mounted, fully programmable, have a battery backed clock, on-board data logging, programmable inputs and outputs and the ability to communicate with the other proposed and existing controllers on the network

If expandable points are used, they must be DIN rail mounted, located in the same physical compartment as the controller they are controlled by and the number of expansion points must not exceed the total number of hardware points on the controller they controlled by i.e. if the controller has 20 points then the total number of expansion points shall not exceed 20 points.

In each compartment containing a controller provide:

- A DIN rail to mount the associated BMS components.
- A switch to isolate the 240 volt power supply
- DIN rail mounted power supplies.

Each controller is to include as a minimum:

- Sufficient processing capacity to execute all its control routines and functions in less than 1 second
- Sufficient extra programming capacity to increase the amount of onboard programming by 100%
- Sufficient inputs and outputs to meet the requirements of the project
- A minimum of one 10/100 Ethernet Port
- RS485 port
- The BACnet operating stack must be embedded in the device at board level.
- Must operate peer-to-peer without the need for additional management devices required for communications with other vendor's products.

The controllers must be enabled to support and licensed with the following Open protocol drivers (client and server) by default:

- BACnet

- MODBUS

The controllers are to be capable of executing application control programs to provide:

- Calendar functions.
- Scheduling.
- Optimum start stop routines
- Trending.
- Alarm monitoring and routing.
- Time synchronization.
- Integration of BACnet, and MODBUS data.

The controllers are to support standard Web browser access via the Intranet/Internet and must support a minimum of 5 simultaneous users.

The controllers are to be able to route any alarm condition to any defined user location whether connected to a local network or remote via wide-area network.

Alarms are to be enunciated in any of the following manners as defined by the user:

- Text message and / or Email of complete alarm message to multiple recipients which can be set by time of day and day of week.
- Graphics with flashing alarm object(s).

The following are to be recorded by the SNC for each alarm (at a minimum):

- Time and date.
- Equipment (air handler #, access way, etc.).
- Acknowledge time, date, and user who issued acknowledgement.

All controllers are to have their own on-board CPU, clock/calendar, EEPROM, RAM, ROM, communication port(s), and network connection. All controllers are to be capable of complete standalone operation upon any network communications failure.

Provide memory that is adequate to meet both the needs of local I/O and the number of secondary controllers connected with each controller.

The input section of the controller is to have "universal" inputs / output capable of accepting / providing information on any point in the form of a temperature, voltage, digital, or pulse counter with only a programming command required for differentiation between the input / output type without the need for hardware changes.

Analogue inputs are to monitor each analogue input, perform A/D conversion, and hold the digital value in a buffer for interrogation. The A/D conversion is to have a minimum resolution 12 bits. The input ranges are to be within the range of 0-10 VDC.

The digital Inputs are to accept dry contact closures and voltage level transitions.

Provide outputs that are digital, analogue or universal.

Provide each controller with a battery backed uninterruptible "Real Time Clock", providing time of day, day, month, year, and day of week automatically accounting for leap years.

Upon restoration of power, each controller is to automatically and without operator intervention; update all monitored functions; resume operation based on current, synchronized time and status, and implement special start-up strategies as required.

Provide each controller with at least 48 hour of battery backup to maintain all volatile memory.

Clearly label with the model number of the controller and its system identity code cross reference the labelling of the controllers on the as built documentation.

10.4 FEATURES / FUNCTION

The BMS user interface is to provide:

- Statistical data that is configurable to the individual users preferences.
- An overall system status dashboard.

The BMS is to include interrogation capabilities that allow onsite and remote:

- Viewing of alarm history
- Managing schedules and calendar objects
- Managing trend logs
- Viewing trend log data
- Viewing and overriding system data and providing point over-rides where required
- Managing system users permissions and passwords

The BMS is to include management capabilities that include:

- Energy log data for accumulated parameters.
- Live power meter display pages.
- Ability to import historical/forecast data.
- Extensive energy reporting capabilities including, but not limited to:
 - Hourly/daily/weekly/yearly reports
 - Peak demand
 - Demand summary
 - Meter comparison
 - Greenhouse gas emissions
 - Progress against budget
 - Monthly degree days
- Provide data to the user via interactive web pages in HTTP formats.
- Expose HLI meter data to the system for control purposes.
- SQL Database to be backed up and stored at an agreed location.

The BMS is to include with the following general capabilities:

- Backup and restore
- System maintenance
- User activity log
- Remote file management
- Web based engineering tools
- System and network diagnostic tools
- Remote software updates
- Online documentation.
- Expose weather station data to the system.
- Issue/problem tracking system providing the ability to create, trace and close issues/problems.

The BMS is to facilitate the following actions:

- Implement a demand management strategy to reduce loads based upon predefined criteria including demand set points.
- Control any individual or combination of points / services based upon predefined schedule.

Ensure the BMS displays the demand from the MSB multifunction meter. Ensure the system includes the ability to remove or add meters.

The BMS is to be able to independently monitor power meters to records the energy generated by alternative sources such as solar PV cells and log and report this data as required.

Provide the BMS with the ability to align the displays with the billing periods and provide trend comparisons against previous billing periods.

Include the following general requirements:

- All controls and alarms, e.g. temperature, associated with an air handling unit are to be inhibited or de-energised if the associated air handling unit or item of plant is stopped.
- All time delays, set points, throttling ranges start/stop times, reset schedules, etc. are to be easily operator adjustable on-line from the keyboard at any time and at a certain operator level.
- Any start/stop point can be assigned to be under time schedule control at any time.
- It is to be noted that the school has the right to and will “fine tune” the control strategies during the contract and maintenance periods based on previous operating experience. Allow for fine tuning by the school including though not limited to minor software modifications, adjustments to set points and time delays etc.,

Ensure it is possible to override any control action and any input from the remote access. When any input or output has been overridden from the remote access ensure the display graphic clearly indicates what has been overridden.

10.5 NETWORK COMMUNICATIONS

All communications are to be via the school's local area network (LAN) operating at a minimum speed of 100 Mbits/s utilising Native BACnet over Ethernet / TCP-IP.

All network points are to be considered global points. Any program in any controller on the network is to be able to reference any point in any controller regardless of its location on the network.

10.6 SOFTWARE

Ensure all software operates solely from a web browser using HTML5 and all controller level software allows live programming such that the operational logic can be changed or fined tuned without the controller being taken offline.

10.7 MAINTENANCE

Undertake the following maintenance for the BMS works supplied under the electrical sub contract and for that supplied by the nominated BMS sub-contractor to the mechanical sub contract.

10.7.1 SYSTEM QUARTERLY MAINTENANCE

Undertake the following quarterly maintenance tasks:

1. For every site visit sign-in with the School's property and work department, filling out required security forms, sign-out security ID passes and any required keys.
2. Make contact with the School's Property and Works Manager and discuss any identified faults / issues with the Energy Management System.
3. Confirm all controllers are on line via the device manager, compare results against original device table details check all controllers are communicating, report and check the communications status of all controllers not appearing on device table.
4. Check and confirm the correct operation of time schedule settings, daylight savings settings, and holiday schedules.
5. Check and adjust communications voltages, setting the desired parameters for field controllers.
6. Set-up trend logs to assist in control strategy tuning and confirm the operation of plant input statuses.
7. Check the operations of all visual and audible alarms.
8. Carry out scheduled field controller maintenance.
9. Investigate all faults identified by the School's Property and Works Manager.
10. Fill out appropriate maintenance spreadsheet highlighting identified faults and a service report on completion of scheduled maintenance service.
11. Return all keys and security passes (if issued).
12. Provide a detailed report with a summary of identified faults with a remedy and budget cost.

10.7.2 SYSTEM HALF YEARLY MAINTENANCE

Undertake the following half yearly maintenance tasks:

1. Perform tasks 1 to 9 as specified in the quarterly maintenance.
2. Carry out a save of all controller software using the device manager; use the backup utility to carry out a backup to the BAS hard drive.
3. Carry out a backup to USB flash drive.
4. Delete all superseded, unrelated controller software.
5. Check if PC maintenance utilities defrag BAS PC hard drive, carry out disk scan, delete / empty recycle bin, to maximize system resources or equivalent has been carried out by the School's IT representative.
6. Check the operation of CPU and power supply ventilation fans and check the operation of controller cubical ventilation fans.
7. Tune control strategies to coincide with seasonal changes.
8. Carry out voltage checks of all control transformers, check the integrity of earth for secondary wiring for field controllers.
9. Perform tasks 10 to 12 as specified in the quarterly maintenance.

10.7.3 SYSTEM ANNUAL MAINTENANCE

Undertake the following annual maintenance tasks:

1. Perform tasks 1 to 9 as specified in the quarterly maintenance.
2. Perform tasks 2 to 8 as specified in the half-yearly maintenance.
3. Replace all global controller batteries.
4. Check for loose electrical connections.
5. Clean all DDC Cubicles.
6. Check and tighten all connections.
7. Tune controls strategies, implementing minor strategy control developments.
8. Perform tasks 10 to 12 as specified in the quarterly maintenance.

10.7.4.1 REMOTE CHECK

Undertake the following half yearly remote maintenance tasks for the air-conditioning controls:

1. Decrease zone set-point to 10°C monitor supply temperature, confirming the correct operation of the chilled water valve and actuator.
2. Check and calibrate 25% of zone sensors on a half-yearly basis, with the intention that all sensors be checked on a two year cycle.
3. If AC is operational confirm space temperature is within acceptable tolerances from set-point.
4. If AC is not operational, set manual override to active. Confirm status is active.
5. Confirm all AC parameters are set to auto operation.
6. Print off tabular page if available or fill out AC service check report, highlighting any anomalies.

10.7.4.2 LOCAL CHECK

Undertake the following annual maintenance tasks for the air-conditioning controls:

1. For every site visit sign-in with the School's property and work department, filling out required security forms, sign-out security ID passes and any required keys.
2. Make contact with the School's property and works manager and discuss any identified faults / issues with the Energy Management System.
3. Inspect each controller and tighten all connections.
4. Functionally test the operation of all components; valve actuators, filter DP sensors and fans.
5. Check valve actuator linkages, ensuring valve strokes are correctly set.
6. Perform tasks 1 to 6 as specified in the AC remote maintenance check.
7. Investigate all faults identified by the School's Property and Works Manager.
8. Fill out appropriate maintenance spreadsheet highlighting identified faults and a service report on completion of scheduled maintenance service.
9. Return all keys and security passes (if issued).
10. Provide a detailed report with a summary of identified faults with a remedy and budget cost.

10.7.5 MISCELLANEOUS EQUIPMENT MAINTENANCE

Undertake the following annual maintenance tasks for the miscellaneous controls:

1. For every site visit sign-in with the School's Property and Works Department, filling out required security forms, sign-out security ID passes and any required keys.
2. Make contact with the School's Property and Works Manager and discuss any identified faults / issues with the Energy Management System.
3. Command each fan in turn to Active, Inactive and then Null. Confirm status matches command.
4. Check all associated time schedules and load shedding software settings.
5. Check the operation of fan status indication, i.e. C/T or air pressure switches.
6. Inspect all associated controllers tighten all connections.
7. Fill out a service report, highlighting any anomalies.
8. Investigate all faults identified by the School's Property and Works Manager.
9. Fill out appropriate maintenance spreadsheet highlighting identified faults and a service report on completion of scheduled maintenance service.
10. Return all keys and security passes (if issued).
11. Provide a detailed report with a summary of identified faults with a remedy and budget cost. Works