



ELECTRICAL DESIGN GROUP

ELECTRICAL BUILDING SERVICES CONSULTANTS

P.O. Box 15, SHERWOOD Q. 4075

Phone: (07) 3278 4375

Website: www.edg.net.au Email: brisbane@edg.net.au

C2387a - 357 LOGAN ROAD, STONES CORNER

C2387a-0009(A).xls

DISTRIBUTION BOARD DB-3

REVISION A - 04 JUNE 2021

FAULT CURRENT: 6kA CHASSIS SIZE: 12 POLE LIGHTING 36 POLE POWER CHASSIS RATING: 250A PHASES: 3							REV
MAIN SWITCH: 100 AMP NON AUTO							A
SUPPLIED FROM: MSB							A
SUPPLY CABLE: 4C 35							A
PROVIDE THE DB WITH AN AS2293 EMERGENCY LIGHTING CONTROL SYSTEM TO CONTROL THE ASSOCIATED TENANCY EMERGENCY LIGHTS. PROVIDE A TYPE M4 METER TO SEPARATELY METER THE SECOND CHASSIS. PROVIDE THE DISTRIBUTION BOARD WITH A DIN RAIL MOUNTED DALI POWER SUPPLY AND DALI CONTROLLER.							A
CIRC	PH	CIRCUIT BREAKER (amps)	CONTROL EQUIPMENT	CABLE SIZE (mm ²)	LOCATION	CIRCUIT USE	A
P1	1	20	RCD	2.5	TENANCY 3	NTU	A
P2	1	20	RCD	2.5	TENANCY 3	GPOs	A
P3	1	20	RCD	2.5	TENANCY 3	WINDOWS	A
P4							A
P5							A
P6							A
P7							A
							A
L1	1	20	RCD	2.5	TENANCY 3	LIGHTS	A
L2	1	20	RCD	2.5	TENANCY 3	LIGHTS	A
L3	1	20	RCD	2.5	TENANCY 3	LIGHTS	A
L4							A
L5							A
L6							A
L7							A
							A
							A
							A
							A