

C2499a - THE BROOK HOTEL, MITCHELTON

C2499a-0004(J).xls

LIGHTING CONTROL SCHEDULE

REVISION J - 15 MARCH 2023

MISCELLANEOUS EQUIPMENT					REV
ITEM	DESCRIPTION				A
SP1	AS DETAILED IN THE EQUIPMENT SCHEDULE 6-BUTTON PROGRAMMABLE SWITCH PANEL C/W CENTRAL LCD DISPLAY DYNALITE ANTUMBRA DISPLAY ALUMINIUM				A
SP2	AS DETAILED IN THE EQUIPMENT SCHEDULE 6-BUTTON PROGRAMMABLE SWITCH PANEL C/W CENTRAL LCD DISPLAY DYNALITE ANTUMBRA DISPLAY ALUMINIUM				A
SP3	AS DETAILED IN THE EQUIPMENT SCHEDULE 6-BUTTON PROGRAMMABLE SWITCH PANEL C/W CENTRAL LCD DISPLAY DYNALITE ANTUMBRA DISPLAY ALUMINIUM				A
SP4	AS DETAILED IN THE EQUIPMENT SCHEDULE 6-BUTTON PROGRAMMABLE SWITCH PANEL C/W CENTRAL LCD DISPLAY DYNALITE ANTUMBRA DISPLAY ALUMINIUM				A
SP5	AS DETAILED IN THE EQUIPMENT SCHEDULE 6-BUTTON PROGRAMMABLE SWITCH PANEL C/W CENTRAL LCD DISPLAY DYNALITE ANTUMBRA DISPLAY ALUMINIUM				A
PE CELL	PROGRAMMABLE PE CELL DUS 90CS CONFIRM THE LOCATION ON SITE WITH THE ARCHITECT				A
TIME CLOCK	PROGRAMMABLE TIME CLOCK ENVISION GATEWAY PDEG C/W INTERNET ACCESS LOCATE DB-1				A
SENSORS	REFER TO THE EQUIPMENT SCHEDULE FOR DETILA OD TH LIGHTING CONTROL SENSORS.				A
CONTROL MODULE 1-1					A
	TYPE:	DYNALITE DDRC1220FR-GL			A
	DESCRIPTION	12 CH SWITCHING CONTROLLER			A
	LOCATION	DIN RAIL MOUNTED WITHIN DB-1			A
	BUS:	A			A
CHANNEL	CONTROL	DESCRIPTION			A
		LOCATION	CIRCUITS	USE	A
1-1	CONTACTOR	GAMING	DB-1 - L1	SIGN	A
1-2	CONTACTOR	GAMING	DB-1 - L2	SIGN	A
1-3	CONTACTOR	GAMING	DB-1 - L3	SIGN	A
1-4	CONTACTOR	GAMING	DB-1 - L4	SIGN	A
1-5	CONTACTOR	EXTERNAL	DB-1 - L11	SIGN	A
1-6	CONTACTOR	AMENITY	DB-1 - L11	SIGN	A
1-7	CONTACTOR	DOSA	DB-1 - L8	HEATER	A
1-8	CONTACTOR	DOSA	DB-1 - L9	HEATER	A
1-9	CONTACTOR	DOSA	DB-1 - L10	FAN	A
1-10	CONTACTOR	ENTRY	DB-1 - L13	SIGN	A
1-11	CONTACTOR	GAMING	DB-1 - L16	PD14	E
1-12					A
CONTROL MODULE 1-2					A
	TYPE:	DYNALITE DDBC1200			A
	DESCRIPTION	12CH BROARD CAST DALI CONTROLLER			A
	LOCATION	DIN RAIL MOUNTED WITHIN DB-1			A
	BUS:	A			A
CHANNEL	CONTROL	DESCRIPTION			A
		LOCATION	CIRCUITS	USE	A
1-25	DALI DIM	AMENITY	DB-1 -L11	RD02	A
1-26	DALI DIM	DOSA	DB-1 -L11	RDO8	A
1-27	DALI DIM	CIRCULATION	DB-1 -L11	WL01	A
1-28	DALI DIM	EXTERNAL	DB-1 -L11	SL02	A
1-29	DALI DIM	CIRCULATION	DB-1 -L12	RD04	A
1-30	DALI DIM	CIRCULATION	DB-1 -L15	RD03	A
1-31	DALI DIM	CIRCULATION	DB-1 -L12	S8	A
1-32	DALI DIM	CIRCULATION	DB-1 -L12	PD01	A
1-33	DALI DIM	CIRCULATION	DB-1 -L12	S6	A
1-34	DALI DIM	LOBBY	DB-1 -L13	RD02 PD02 PD03	A
1-35	DALI DIM	LOBBY	DB-1 -L13	PD04	A
1-36	DALI DIM	LOBBY	DB-1 -L13	RD01 RD02	B




C2499a - THE BROOK HOTEL, MITCHELTON

C2499a-0004(J).xls

LIGHTING CONTROL SCHEDULE

REVISION J - 15 MARCH 2023

CONTROL MODULE 1-3					A
	TYPE:	DYNALITE DDBC1200			A
	DESCRIPTION	12CH BROARD CAST DALI CONTROLLER			A
	LOCATION	DIN RAIL MOUNTED WITHIN DB-1			A
	BUS:	A			A
CHANNEL	CONTROL	DESCRIPTION			A
		LOCATION	CIRCUITS	USE	A
1-37	DALI DIM	LOBBY	DB-1 -L13	S4	A
1-38	DALI DIM	CASHIER	DB-1 -L14	RD01 RD05 S7	A
1-39	DALI DIM	GAMING	DB-1 -L15	S1	B
1-40	DALI DIM	GAMING	DB-1 -L16	WL02	A
1-41	DALI DIM	GAMING	DB-1 -L15	RD01 WL01	B
1-42					E
1-43	DALI DIM	GAMING	DB-1 -L16	RD01	A
1-44	DALI DIM	GAMING	DB-1 -L16	S2	A
1-45	DALI DIM	GAMING	DB-1 -L15	S1	A
1-46	DALI DIM	EXTERNAL	DB-1 -L17	BL01	A
1-47	DALI DIM	EXTERNAL	DB-1 -L17	UL03	A
1-48	DALI DIM	EXTERNAL	DB-1 -L17	UL04	A
CONTROL MODULE 1-4					A
	TYPE:	DYNALITE DDBC1200			A
	DESCRIPTION	12CH BROARD CAST DALI CONTROLLER			A
	LOCATION	DIN RAIL MOUNTED WITHIN DB-1			A
	BUS:	A			A
CHANNEL	CONTROL	DESCRIPTION			A
		LOCATION	CIRCUITS	USE	A
1-49	DALI DIM				E
1-50	DALI DIM	EXTERNAL	DB-1 -L17	UL02	A
1-51	DALI DIM	EXTERNAL	DB-1 -L11	WL12	A
1-52	DALI DIM	EXTERNAL	DB-1 -L11	UL04	A
1-53	DALI DIM	DOSA	DB-1 -L11	WL12	A
1-54	DALI DIM	CIRCULATION	DB-1 -L12	S27	A
1-55	DALI DIM	CASHIER	DB-1 -L14	S26	A
1-56	DALI DIM	CASHIER	DB-1 -L14	S25	A
1-57					A
1-58					A
1-59					A
1-60					A
CONTROL MODULE 2-1					A
	TYPE:	DYNALITE DDRC1220FR-GL			A
	DESCRIPTION	12 CH SWITCHING CONTROLLER			A
	LOCATION	DIN RAIL MOUNTED WITHIN DB-2			A
	BUS:	A			A
CHANNEL	CONTROL	DESCRIPTION			A
		LOCATION	CIRCUITS	USE	A
2-1	CONTACTOR	CIRCULATION	DB-2 - L10	SIGN	A
2-2	CONTACTOR	AMENITY	DB-2 - L12	SIGN	A
2-3	CONTACTOR	EXTERNAL	DB-2 - L38	HEATER	A
2-4	CONTACTOR	EXTERNAL	DB-2 - L39	HEATER	A
2-5	CONTACTOR	EXTERNAL	DB-2 - L40	HEATER	A
2-6	CONTACTOR	EXTERNAL	DB-2 - L41	HEATER	A
2-7	CONTACTOR	EXTERNAL	DB-2 - L42	POLE PL01	A
2-8	CONTACTOR	EXTERNAL	DB-2 - L28	HEATER	A
2-9	CONTACTOR	EXTERNAL	DB-2 - L27	HEATER	A
2-10	CONTACTOR	EXTERNAL	DB-2 - L28	HEATER	H
2-11	CONTACTOR	EXTERNAL	DB-2 - L27	HEATER	H
2-12					G




C2499a - THE BROOK HOTEL, MITCHELTON

C2499a-0004(J).xls

LIGHTING CONTROL SCHEDULE

REVISION J - 15 MARCH 2023

CONTROL MODULE 2-2					A
	TYPE:	DYNALITE DDR1220FR-GL			A
	DESCRIPTION	12 CH SWITCHING CONTROLLER			A
	LOCATION	DIN RAIL MOUNTED WITHIN DB-2			A
	BUS:	A			A
CHANNEL	CONTROL	DESCRIPTION			A
		LOCATION	CIRCUITS	USE	A
2-13	CONTACTOR	EXTERNAL	DB-2 - L38	HEATER	H
2-14	CONTACTOR	EXTERNAL	DB-2 - L39	HEATER	H
2-15	CONTACTOR	EXTERNAL	DB-2 - L40	HEATER	H
2-16	CONTACTOR	EXTERNAL	DB-2 - L41	HEATER	H
2-17	CONTACTOR	DINING	DB-2 - L36	SIGN	A
2-18	CONTACTOR	DINING	DB-2 - L34	SIGN	A
2-19	CONTACTOR	KIDS	DB-2 - L34	SIGN	A
2-20	CONTACTOR	DINING	DB-2 - L19	SIGN	D
2-21	CONTACTOR	SERVERY	DB-2 - L22	SIGN	D
2-22					A
2-23					A
2-24					A
CONTROL MODULE 2-3					A
	TYPE:	DYNALITE DDBC1200			A
	DESCRIPTION	12CH BROARD CAST DALI CONTROLLER			A
	LOCATION	DIN RAIL MOUNTED WITHIN DB-2			A
	BUS:	A			A
CHANNEL	CONTROL	DESCRIPTION			A
		LOCATION	CIRCUITS	USE	A
2-25	DALI DIM	SPORTS BAR	DB-2 - L14	RD02 RD01	A
2-26	DALI DIM	SPORTS BAR	DB-2 - L15	WL05	A
2-27	DALI DIM	SPORTS BAR	DB-2 - L15	S6	A
2-28	DALI DIM	SPORTS BAR	DB-2 - L13	RD01	A
2-29	DALI DIM	SPORTS BAR	DB-2 - L13	PD05	A
2-30	DALI DIM	SPORTS BAR	DB-2 - L13	TL01	A
2-31	DALI DIM	SPORTS BAR	DB-2 - L12	RD01	A
2-32	DALI DIM	SPORTS BAR	DB-2 - L12	S9	A
2-33	DALI DIM	SPORTS BAR	DB-2 - L12	WL01	A
2-34	DALI DIM	AMENITY	DB-2 - L11	RD01 RD02 S5	A
2-35	DALI DIM	AMENITY	DB-2 - L11	RD02 RD01	A
2-36	DALI DIM	AMENITY	DB-2 - L11	S6	A
CONTROL MODULE 2-4					A
	TYPE:	DYNALITE DDBC1200			A
	DESCRIPTION	12CH BROARD CAST DALI CONTROLLER			A
	LOCATION	DIN RAIL MOUNTED WITHIN DB-2			A
	BUS:	A			A
CHANNEL	CONTROL	DESCRIPTION			A
		LOCATION	CIRCUITS	USE	A
2-37	DALI DIM	AMENITY	DB-2 - L11	WL03	A
2-38	DALI DIM	CIRCULATION	DB-2 - L10	RD01	B
2-39	DALI DIM	AMENITY	DB-2 - L9	WL03	A
2-40	DALI DIM	AMENITY	DB-2 - L9	RD01 RD02	B
2-41	DALI DIM	AMENITY	DB-2 - L9	S5	A
2-42	DALI DIM	BAR	DB-2 - L15	RD01	A
2-43	DALI DIM	BAR	DB-2 - L15	RD01	A
2-44	DALI DIM	BAR	DB-2 - L15	TL01	A
2-45	DALI DIM	BAR	DB-2 - L15	S11	A
2-46	DALI DIM	BAR	DB-2 - L15	PD05	A
2-47	DALI DIM	LOUNGE	DB-2 - L16	TL01	A
2-48	DALI DIM	LOUNGE	DB-2 - L16	TL01	A



C2499a - THE BROOK HOTEL, MITCHELTON

C2499a-0004(J).xls

LIGHTING CONTROL SCHEDULE

REVISION J - 15 MARCH 2023

CONTROL MODULE 2-5					A
	TYPE:	DYNALITE DDBC1200			A
	DESCRIPTION	12CH BROARD CAST DALI CONTROLLER			A
	LOCATION	DIN RAIL MOUNTED WITHIN DB-2			A
	BUS:	A			A
CHANNEL	CONTROL	DESCRIPTION			A
		LOCATION	CIRCUITS	USE	A
2-49	DALI DIM	LOUNGE	DB-2 - L17	TL01	A
2-50	DALI DIM	LOUNGE	DB-2 - L17	PD06	A
2-51	DALI DIM	BAR	DB-2 - L21	RD05	A
2-52	DALI DIM	BAR	DB-2 - L21	WL04	A
2-53	DALI DIM	BAR	DB-2 - L22	S10	A
2-54	DALI DIM	LOUNGE	DB-2 - L18	TL01	A
2-55	DALI DIM	BAR	DB-2 - L21	RD01	A
2-56	DALI DIM	LOUNGE	DB-2 - L19	PD07 PD08	B
2-57	DALI DIM	LOUNGE	DB-2 - L20	TL01	A
2-58	DALI DIM	BAR	DB-2 - L21	RD01	A
2-59	DALI DIM	SERVERY	DB-2 - L22	RD01	A
2-60	DALI DIM	SERVERY	DB-2 - L22	WL04	A
CONTROL MODULE 2-6					A
	TYPE:	DYNALITE DDBC1200			A
	DESCRIPTION	12CH BROARD CAST DALI CONTROLLER			A
	LOCATION	DIN RAIL MOUNTED WITHIN DB-2			A
	BUS:	A			A
CHANNEL	CONTROL	DESCRIPTION			A
		LOCATION	CIRCUITS	USE	A
2-61	DALI DIM				E
2-62	DALI DIM	EXTERNAL	DB-2 - L31	WL12	A
2-63	DALI DIM	KIDS	DB-2 - L37	S30	A
2-64	DALI DIM	EXTERNAL	DB-2 - L23	SL05	E
2-65	DALI DIM	DINING	DB-2 - L35	S32	A
2-66	DALI DIM	DINING	DB-2 - L35	GL02	A
2-67	DALI DIM	EXTERNAL	DB-2 - L23	WL12	A
2-68	DALI DIM	EXTERNAL	DB-2 - L25	BOL-L2	B
2-69	DALI DIM	EXTERNAL	DB-2 - L25	GL02	A
2-70	DALI DIM	EXTERNAL	DB-2 - L25	S29	A
2-71	DALI DIM	EXTERNAL	DB-2 - L26	FL01	A
2-72	DALI DIM	EXTERNAL	DB-2 - L26	TB-1	A
CONTROL MODULE 2-7					A
	TYPE:	DYNALITE DDBC1200			A
	DESCRIPTION	12CH BROARD CAST DALI CONTROLLER			A
	LOCATION	DIN RAIL MOUNTED WITHIN DB-2			A
	BUS:	A			A
CHANNEL	CONTROL	DESCRIPTION			A
		LOCATION	CIRCUITS	USE	A
2-73	DALI DIM	EXTERNAL	DB-2 - L26	LMP01	A
2-74	DALI DIM	EXTERNAL	DB-2 - L24	S29	A
2-75	DALI DIM	EXTERNAL	DB-2 - L24	GL02	B
2-76	DALI DIM	EXTERNAL	DB-2 - L24	UL01	A
2-77	DALI DIM	BAR	DB-2 - L30	S26	A
2-78	DALI DIM	BAR	DB-2 - L30	S28	A
2-79	DALI DIM	EXTERNAL	DB-2 - L31	SL02	A
2-80	DALI DIM	EXTERNAL	DB-2 - L31	S12	A
2-81	DALI DIM	EXTERNAL	DB-2 - L31	SL01	A
2-82	DALI DIM	DINING	DB-2 - L34	PD09	A
2-83	DALI DIM	KIDS	DB-2 - L37	RD01	A
2-84	DALI DIM	KIDS	DB-2 - L37	S16	A




C2499a - THE BROOK HOTEL, MITCHELTON

C2499a-0004(J).xls

LIGHTING CONTROL SCHEDULE

REVISION J - 15 MARCH 2023

CONTROL MODULE 2-8					A
	TYPE:	DYNALITE DDBC1200			A
	DESCRIPTION	12CH BROARD CAST DALI CONTROLLER			A
	LOCATION	DIN RAIL MOUNTED WITHIN DB-2			A
	BUS:	A			A
CHANNEL	CONTROL	DESCRIPTION			A
		LOCATION	CIRCUITS	USE	A
2-85	DALI DIM	KIDS	DB-2 - L37	RD03	A
2-86	DALI DIM	KIDS	DB-2 - L37	S15	A
2-87	DALI DIM	DINING	DB-2 - L34	WL01	A
2-88	DALI DIM	DINING	DB-2 - L34	WL08	A
2-89	DALI DIM	DINING	DB-2 - L34	TL01	A
2-90	DALI DIM	DINING	DB-2 - L33	RD01	A
2-91	DALI DIM	DINING	DB-2 - L33	S14	A
2-92	DALI DIM	DINING	DB-2 - L33	RD01	A
2-93	DALI DIM	DINING	DB-2 - L32	TL01	A
2-94	DALI DIM	DINING	DB-2 - L32	S13	A
2-95	DALI DIM	DINING	DB-2 - L33	WL07	A
2-96	DALI DIM	DINING	DB-2 - L36	TL01	A
CONTROL MODULE 2-9					A
	TYPE:	DYNALITE DDBC1200			A
	DESCRIPTION	12CH BROARD CAST DALI CONTROLLER			A
	LOCATION	DIN RAIL MOUNTED WITHIN DB-2			A
	BUS:	A			A
CHANNEL	CONTROL	DESCRIPTION			A
		LOCATION	CIRCUITS	USE	A
2-97	DALI DIM	DINING	DB-2 - L36	S13	A
2-98	DALI DIM	DINING	DB-2 - L35	TL01	A
2-99	DALI DIM	DINING	DB-2 - L35	S13	A
2-100	DALI DIM	DINING	DB-2 - L35	S35	A
2-101	DALI DIM	DINING	DB-2 - L35	WL05	A
2-102	DALI DIM	SPORTS BAR	DB-2 - L12	S6	A
2-103	DALI DIM	SPORTS BAR	DB-2 - L22	SL02	B
2-104	DALI DIM	EXTERNAL	DB-2 - L31	SL06	G
2-105					A
2-106					A
2-107					A
2-108					A
CONTROL MODULE 2-10					H
	TYPE:	DYNALITE DDRC1220FR-GL			H
	DESCRIPTION	12 CH SWITCHING CONTROLLER			H
	LOCATION	DIN RAIL MOUNTED WITHIN DB-2			H
	BUS:	A			H
CHANNEL	CONTROL	DESCRIPTION			H
		LOCATION	CIRCUITS	USE	H
2-109	SWITCH	EXTERNAL	DB-2 - P82	GAS HEATER	H
2-110					J
2-111	SWITCH	EXTERNAL	DB-2 - P82	GAS HEATER	H
2-112	SWITCH	EXTERNAL	DB-2 - P82	GAS HEATER	H
2-113	SWITCH	EXTERNAL	DB-2 - P82	GAS HEATER	H
2-114	SWITCH	EXTERNAL	DB-2 - P82	GAS HEATER	H
2-115	SWITCH	EXTERNAL	DB-2 - P82	GAS HEATER	H
2-116	SWITCH	EXTERNAL	DB-2 - P82	GAS HEATER	H
2-117	SWITCH	EXTERNAL	DB-2 - P82	GAS HEATER	H
2-118	SWITCH	EXTERNAL	DB-2 - P82	GAS HEATER	H
2-119	SWITCH	EXTERNAL	DB-2 - P82	GAS HEATER	H
2-120	SWITCH	EXTERNAL	DB-2 - P82	GAS HEATER	H




C2499a - THE BROOK HOTEL, MITCHELTON

C2499a-0004(J).xls

LIGHTING CONTROL SCHEDULE

REVISION J - 15 MARCH 2023

CONTROL MODULE 2-11					H
	TYPE:	DYNALITE DDR1220FR-GL			H
	DESCRIPTION	12 CH SWITCHING CONTROLLER			H
	LOCATION	DIN RAIL MOUNTED WITHIN DB-2			H
	BUS:	A			H
CHANNEL	CONTROL	DESCRIPTION			H
		LOCATION	CIRCUITS	USE	H
2-121	SWITCH	EXTERNAL	DB-2 - P82	GAS HEATER	H
2-122					H
2-123					H
2-124					H
2-125					H
2-126					H
2-127					H
2-128					H
2-129					H
2-130					H
2-131					H
2-132					H
CONTROL MODULE 3-1					A
	TYPE:	DYNALITE DDR1220FR-GL			A
	DESCRIPTION	12 CH SWITCHING CONTROLLER			A
	LOCATION	DIN RAIL MOUNTED WITHIN DB-3			A
	BUS:	A			A
CHANNEL	CONTROL	DESCRIPTION			A
		LOCATION	CIRCUITS	USE	A
3-1	CONTACTOR	EXTERNAL	DB-3 - L16	PL01	F
3-2	CONTACTOR	CARPARK	DB-3 - L18	L4 L5 L6	A
3-3	CONTACTOR	CARPARK	DB-3 - L17	L5	B
3-4	CONTACTOR	RECEPTION	DB-3 - L8	SIGN	A
3-5	CONTACTOR	LIFT LOBBY	DB-3 - L4	SIGN	A
3-6	CONTACTOR	AMENITY	DB-3 - L3	SIGN	A
3-7	CONTACTOR	AMENITY	DB-3 - L2	SIGN	A
3-8	CONTACTOR	EXTERNAL	DB-3 - L46	HEATER	E
3-9					A
3-10					A
3-11					A
3-12					A




C2499a - THE BROOK HOTEL, MITCHELTON

C2499a-0004(J).xls

LIGHTING CONTROL SCHEDULE

REVISION J - 15 MARCH 2023

CONTROL MODULE 3-2					A
	TYPE:	DYNALITE DDBC1200			A
	DESCRIPTION	12CH BROARD CAST DALI CONTROLLER			A
	LOCATION	DIN RAIL MOUNTED WITHIN DB-3			A
	BUS:	A			A
CHANNEL	CONTROL	DESCRIPTION			A
		LOCATION	CIRCUITS	USE	A
3-25	DALI DIM				A
3-26	DALI DIM	LIFT LOBBY	DB-3 - L5	TL01	A
3-27	DALI DIM	LIFT LOBBY	DB-3 - L5	WL01	A
3-28	DALI DIM	RECEPTION	DB-3 - L8	S24	B
3-29	DALI DIM	RECEPTION	DB-3 - L8	PD11	B
3-30	DALI DIM	STAIR	DB-3 - L12	SL03 WL12	A
3-31	DALI DIM	FOYER	DB-3 - L9	S23	A
3-32	DALI DIM	FOYER	DB-3 - L9	RD01	A
3-33	DALI DIM	FOYER	DB-3 - L9	S21	A
3-34	DALI DIM	FOYER	DB-3 - L9	RD08	A
3-35	DALI DIM	PORTE COCHERE	DB-3 - L11	RD01	A
3-36	DALI DIM	PORTE COCHERE	DB-3 - L11	S22	A
CONTROL MODULE 3-3					A
	TYPE:	DYNALITE DDBC1200			A
	DESCRIPTION	12CH BROARD CAST DALI CONTROLLER			A
	LOCATION	DIN RAIL MOUNTED WITHIN DB-3			A
	BUS:	A			A
CHANNEL	CONTROL	DESCRIPTION			A
		LOCATION	CIRCUITS	USE	A
3-37	DALI DIM	PORTE COCHERE	DB-3 - L11	SL03	B
3-38	DALI DIM	FOYER	DB-3 - L9	WL09	A
3-39	DALI DIM	FOYER	DB-3 - L9	RD01	A
3-40	DALI DIM	FOYER	DB-3 - L9	PD12	A
3-41	DALI DIM	FOYER	DB-3 - L9	S20	A
3-42	DALI DIM	RECEPTION	DB-3 - L8	SL01	B
3-43	DALI DIM	FUNCTION ROOM	DB-3 - L10	RD01	A
3-44	DALI DIM	FUNCTION ROOM	DB-3 - L10	S19	A
3-45	DALI DIM	FUNCTION ROOM	DB-3 - L10	S6	A
3-46	DALI DIM	FUNCTION ROOM	DB-3 - L10	S18	A
3-47	DALI DIM	CIRCULATION	DB-3 - L3	WL06	A
3-48	DALI DIM	CIRCULATION	DB-3 - L3	S17	A
CONTROL MODULE 3-4					A
	TYPE:	DYNALITE DDBC1200			A
	DESCRIPTION	12CH BROARD CAST DALI CONTROLLER			A
	LOCATION	DIN RAIL MOUNTED WITHIN DB-3			A
	BUS:	A			A
CHANNEL	CONTROL	DESCRIPTION			A
		LOCATION	CIRCUITS	USE	A
3-49	DALI DIM	CIRCULATION	DB-3 - L3	RD02	A
3-50	DALI DIM	AMENITY	DB-3 - L3	RD01 RD02 S5	A
3-51	DALI DIM	AMENITY	DB-3 - L2	WL03	A
3-52	DALI DIM	AMENITY	DB-3 - L2	PD10	A
3-53	DALI DIM	AMENITY	DB-3 - L2	RD01 RD02	B
3-54	DALI DIM	AMENITY	DB-3 - L2	S5	A
3-55	DALI DIM	EXTERNAL	DB-3 - L13	UL01	A
3-56	DALI DIM	EXTERNAL	DB-3 - L13	S29	A
3-57	DALI DIM	EXTERNAL	DB-3 - L13	GL02	A
3-58	DALI DIM	EXTERNAL	DB-3 - L14	WL12	A
3-59	DALI DIM	EXTERNAL	DB-3 - L13	GL02	A
3-60	DALI DIM	EXTERNAL	DB-3 - L14	WL12	B



C2499a - THE BROOK HOTEL, MITCHELTON

C2499a-0004(J).xls

LIGHTING CONTROL SCHEDULE

REVISION J - 15 MARCH 2023

CONTROL MODULE 3-5					A
	TYPE:	DYNALITE DDBC1200			A
	DESCRIPTION	12CH BROARD CAST DALI CONTROLLER			A
	LOCATION	DIN RAIL MOUNTED WITHIN DB-3			A
	BUS:	A			A
CHANNEL	CONTROL	DESCRIPTION			A
		LOCATION	CIRCUITS	USE	A
3-61	DALI DIM	EXTERNAL	DB-3 - L15	GL02	A
3-62	DALI DIM	EXTERNAL	DB-3 - L15	BOL-L1	A
3-63	DALI DIM	EXTERNAL	DB-3 - L15	UL05	A
3-64	DALI DIM	EXTERNAL	DB-3 - L14	WL12	A
3-65	DALI DIM	EXTERNAL	DB-3 - L15	UL04	A
3-66	DALI DIM	EXTERNAL	DB-3 - L15	UL03	A
3-67	DALI DIM	EXTERNAL	DB-3 - L15	UL03	A
3-68	DALI DIM	EXTERNAL	DB-3 - L19	PL02	A
3-69	DALI DIM	EXTERNAL	DB-3 - L19	PL02	A
3-70	DALI DIM	EXTERNAL	DB-3 - L19	UL03	A
3-71	DALI DIM	LEVEL 1	DB-3 - L21	RD02 PD03	B
3-72	DALI DIM	LEVEL 1	DB-3 - L20	RD02	B
CONTROL MODULE 3-6					A
	TYPE:	DYNALITE DDBC1200			A
	DESCRIPTION	12CH BROARD CAST DALI CONTROLLER			A
	LOCATION	DIN RAIL MOUNTED WITHIN DB-3			A
	BUS:	A			A
CHANNEL	CONTROL	DESCRIPTION			A
		LOCATION	CIRCUITS	USE	A
3-73	DALI DIM	LEVEL 2	DB-3 - L34	RD02 PD03	B
3-74	DALI DIM	LEVEL 2	DB-3 - L33	RD02	B
3-75	DALI DIM	EXTERNAL	DB-3 - L14	SL05	E
3-76	DALI DIM	EXTERNAL	DB-3 - L16	SL06	G
3-77	DALI DIM	EXTERNAL	DB-3 - L48	SL06	H
3-78					A
3-79					A
3-80					A
3-81					A
3-82					A
3-83					A
2-84					A