

ELECTRICAL DESIGN GROUP

ELECTRICAL BUILDING SERVICES CONSULTANTS

P.O. Box 15, SHERWOOD Q. 4075 Phone: (07) 3278 4375 Fax: (07) 3716 0222 Web Site: www.edg.net.au Email: brisbane@edg.net.au

C2549a - COMMERCIAL HOTEL, KINGAROY - STAGE 1 DISTRIBUTION BOARD DB-B REVISION G - 23 FEBRUARY 2024

C2549a-0005(G).xls

Α

| | | | | REV |
|-----------------|-------------------------|----------------|-----------------------------|-----|
| FAULT CURRENT: | 6KA UTILISING CASCADING | MAIN SWITCH: | 160A NON AUTO LOAD BREAK | Α |
| CHASSIS SIZE: | 74 POLES | SUPPLIED FROM: | MSB | А |
| CHASSIS RATING: | 250A | SUPPLY CABLE: | 4C25 | Α |
| PHASES: | 3 | | | Α |

PROVIDE THE DB WITH A FULL WIDTH EMPTY DIN RAIL TO ACCOMMODATE FUTURE CONTACTORS AND CONTROLS IN ADDITION TO THE INITIAL CONTROLS. PROVIDE THE DB WITH AN AS2293 EMERGENCY LIGHTING CONTROL SYSTEM TO CONTROL THE ASSOCIATED EMERGENCY LIGHTS. PROVIDE THE DB WITH SURGE PROTECTION. PROVIDE THE DB WITH A LOCKABLE FLUSH HANDLE. IN ADDITION TO THE CIRCUITS NOTED BELOW ALLOW FOR ALL NEW SWITCHGEAR AND CONTROLS TO RECONNECT ALL OF THE EXISTING DB-B CIRCUITS THAT REMAINS.

| | BU | CIRCUIT BREAKER (amps) | CONTROL EQUIPMENT | CABLE SIZE (mm ²) | LOCATION | CIRCUIT USE | |
|------|----|---------------------------|----------------------|-----------------------------------|--------------------|----------------|---|
| CIRC | PH | | | | | | |
| P1 | 1 | 20 | RCD | 2.5 | KITCHEN | REF | Α |
| P2 | 1 | 20 | RCD | 2.5 | KITCHEN | REF | Α |
| P3 | 1 | 20 | RCD | 2.5 | BEER GARD. AMENITY | TE FAN | С |
| P4 | 1 | 20 | RCD | 2.5 | KITCHEN | HEAT LAMPS | Α |
| P5 | 1 | 20 | RCD | 2.5 | KITCHEN | MICROWAVE | Α |
| P6 | 1 | 20 | RCD | 2.5 | KITCHEN | STARTERS | Α |
| P7 | 1 | 32 | RCD | 6.0 | KITCHEN | TOASTER | Α |
| P8 | 1 | 20 | RCD | 2.5 | KITCHEN | REF | Α |
| P9 | | | | | | | G |
| P10 | 3 | 20 | RCD | 2.5 | KITCHEN | DISHWASHER | В |
| P11 | 1 | 20 | RCD | 2.5 | KITCHEN | GPOs | Α |
| P12 | 3 | 20 | | 2.5 | KITCHEN | VSD | F |
| P13 | 1 | 20 | RCD | 2.5 | KITCHEN | MICROWAVE | Α |
| P14 | 3 | 20 | RCD | 2.5 | STORE | HWS 3X3.6KW | Α |
| P15 | 1 | 20 | RCD | 2.5 | KITCHEN | REF | Α |
| P16 | 1 | 20 | RCD | 2.5 | BEER GARD. AMENITY | HAND DRYER | С |
| P17 | 3 | 20 | RCD TC ON / OFF | 2.5 | ROOF | TE FAN | D |
| P18 | | | | | | | Е |
| P19 | 1 | 20 | RCD | 2.5 | KITCHEN | GPOs | С |
| P20 | 1 | 20 | RCD | 2.5 | SERVERY | POS | С |
| | | | | | | | |
| L1 | 1 | 20 | RCD | 2.5 | KITCHEN | LIGHTING | А |
| L2 | 1 | 20 | RCD | 2.5 | STORE / AMENITIES | LIGHTING | Α |
| | | | | | | | |
| | | | | | | | |