

## **ELECTRICAL DESIGN GROUP**

**ELECTRICAL BUILDING SERVICES CONSULTANTS** 

P.O. Box 15, SHERWOOD Q. 4075 Phone: (07) 3278 4375 Fax: (07) 3716 0222 Web Site: www.edg.net.au Email: brisbane@edg.net.au

C2549a - COMMERCIAL HOTEL, KINGAROY - STAGE 1 DISTRIBUTION BOARD DB-E REVISION E - 05 FEBRUARY 2024 C2549a-0007(E).xls

							REV
		FAULT CURRENT:	6KA UTILISING		MAIN SWITCH:	100A NON AUTO LOAD BREAK	E
							E
							Е
							E
24 POL TO TH	REMOVE THE EXISTING METERING, MEN ASSOCIATED EARTH STAKE AND CONSUMERS MAINS. PROVIDE A 3 PHASE 100 AMP 24 POLE LOAD CENTRE WITHIN THE EXITING HOUSING TO ACCOMMODATE THE NEW CIRCUITS CONNECT THE LOAD CENTRE TO THE NEW SUPPLY PROVIDE A 63 AMP THREE PHASE CONNECTION FROM THE LOAD CENTRE TO THE EXITING SWITCHGEAR.						
CIRC	PH	CIRCUIT	CONTROL	CABLE	LOCATION	CIRCUIT	
		BREAKER (amps)	<b>EQUIPMENT</b>	SIZE ( mm² )		USE	
P1	1	20	RCD	2.5	BEER GARDEN	TV	В
P2	1	20	RCD	2.5	DINING	GPOs	Α
P3	1	20	RCD	2.5	DINING	GPOs	Α
P4	1	20	RCD	2.5	DINING	TV	В
P5	1	20 D CURVE	RCD	2.5	DINING	LED SCREEN	С
P6	1	20 D CURVE	RCD	2.5	DINING	LED SCREEN	С
P7							Е
P8							Е
P9							Е
P10			<u> </u>			·	Е
P11							Е
P12	1	20	RCD	2.5	STORE	ICE MACHINE	D
P13							Е
L1	1	20	RCD	2.5	STORE	LIGHTING	Α
L2							E
L3							E