

## **ELECTRICAL DESIGN GROUP**

ELECTRICAL BUILDING SERVICES CONSULTANTS P.O. Box 15, SHERWOOD Q. 4075

Phone: (07) 3278 4375

Website: www.edg.net.au Email: brisbane@edg.net.au

## C3351a - REWARD PET FOODS, WILSONTON DISTRIBUTION BOARD DB-1-1 (NORTH NEW)

C3351a-0010(A).xls

**REVISION A - 18 DECEMBER 2024** 

							REV
FAULT CURRENT:			6KA USING CASCADING		MAIN SWITCH:	250A NON AUTO LOAD BREAK	Α
CHASSIS SIZE:			60 POLE		SUPPLIED FROM:	MDB-1	Α
		CHASSIS RATING:	250A		SUPPLY CABLE:	1C95	Α
		PHASES:	3				Α
PROVIDE THE DB WITH A FULL WIDTH EMPTY DIN RAIL TO ACCOMMODATE FUTURE CONTACTORS AND CONTROLS. PROVIDE THE DB WITH SURGE PROTECTION. REFER TO THE NOTES FOR ADDITIONAL REQUIREMENTS. UTILISE THE EXISTING DIN STYLE SWITCHGEAR THAT IS REMOVED FROM THE MDB-1 TO SUPPLY THE EXISTING CIRCUITS THAT ARE RELOCATED FROM THE MDB-1 INTO DB-1-1.							А
OIDO	<b>D</b>	CIRCUIT	CONTROL	CABLE	LOCATION	CIRCUIT	
CIRC	PH	BREAKER (amps)	EQUIPMENT	SIZE ( mm <sup>2</sup> )		USE	