



# ELECTRICAL DESIGN GROUP

ELECTRICAL BUILDING SERVICES CONSULTANTS

P.O. Box 15, SHERWOOD Q. 4075

Phone: (07) 3278 4375

Website: [www.edg.net.au](http://www.edg.net.au) Email: [brisbane@edg.net.au](mailto:brisbane@edg.net.au)

C3354a - ASPLEY LEAGUES CLUB - GAMING REFURBISHMENT

C3354a-0006(B).xls

DISTRIBUTION BOARD DB-E

REVISION B - 31 JULY 2025

							REV
EXISTING DISTRIBUTION BOARD TO BE RETAINED. REMOVE ALL EXISTING SWITCHGEAR THAT BECOMES REDUNDANT. UTILISE EXISTING SWITCHGEAR THAT BECOMES AVAILABLE TO SUPPLY THE FOLLOWING CIRCUITS. UPDATE THE SCHEDULE AT PRACTICAL COMPLETION.							A
CIRC	PH	CIRCUIT BREAKER (amps)	CONTROL EQUIPMENT	CABLE SIZE ( mm <sup>2</sup> )	LOCATION	CIRCUIT USE	
P1	1	20	RCBO	2.5	CASHROOM	COMMS RACK CR-A	A
P2	1	20	RCBO	2.5	BAR	TV	A
P3	1	20	RCBO	2.5	CASHIER	POS	A
P4	1	20	RCBO	2.5	CASHIER	AB GPO	A
P5	1	20	RCBO	2.5	CASHIER	REF	A
P6	1	20	RCBO	2.5	CASHIER	KENO	A
P7	1	20	RCBO	2.5	CASHIER	MONITOR	A
P8	1	20	RCBO	2.5	COUNT ROOM 1	GPOS	B
P9	1	20	RCBO	2.5	COUNT ROOM 1	CASH MACHINES	B
P10	1	20	RCBO	2.5	COUNT ROOM 2	GPOS	B