## **ELECTRICAL DESIGN GROUP**



## C3593a - BREAKFAST CREEK HOTEL - GAMING ROOM DISTRIBUTION BOARD DB-P

## C3593a-0005(A).xls

REVISION A - 11 JULY 2025

PROVIDE ADDITIONAL SWITCHGEAR AND CONTROLS FOR THE FOLLOWING CIRCUITS WITHIN THE EXISTING DB-P DISTRIBUTION BOARD . UPDATE THE SCHEULE AND ENSURE THE SCHEDULE INCLUDES THE CIRCUIT USE AND LOCATION.							A
	PH	CIRCUIT BREAKER (amps)	CONTROL EQUIPMENT	CABLE SIZE ( mm <sup>2</sup> )	LOCATION	CIRCUIT USE	
CIRC							
P1	1	20	RCBO	2.5	GAMING	GAMING MACHINES	A
P2	1	20	RCBO	2.5	GAMING	GAMING MACHINES	A
P3	1	20	RCBO	2.5	GAMING	GAMING MACHINES	A
P4	1	20	RCBO	2.5	GAMING	GAMING MACHINES	A
P5	1	20	RCBO	2.5	GAMING	CRT	A
P6	1	20	RCBO	2.5	GAMING	SIGN	A
P7	1	20	RCBO	2.5	GAMING	SIGN	A
P8	1	20	RCBO	2.5	GAMING	SIGN	A
P9	1	20	RCBO	2.5	GAMING	MODEM	A
P10	1	20	RCBO	2.5	GAMING	CLEANING	A
P11	1	20	RCBO	2.5	BAR	POS	A
P12	1	20	RCBO	2.5	BAR	GAMING TERMINAL	A
P13	1	20	RCBO	2.5	BAR	GLASS WASHER	A
P14	1	20	RCBO	2.5	BAR	REF	A
P15	1	20	RCBO	2.5	BAR	GPO	A
P16	1	20	RCBO	2.5	EXTERNAL	SIGN	A
L1	1	20	RCBO	2.5	GAMING	LIGHTING	A
L2	1	20	RCBO	2.5	GAMING	LIGHTING	A
L3	1	20	RCBO	2.5	GAMING	LIGHTING	A
L4	1	20	RCBO	2.5	GAMING	LIGHTING	A

Pages inc. any attach. 1 of 1