

ELECTRICAL DESIGN GROUP

ELECTRICAL BUILDING SERVICES CONSULTANTS
P.O. Box 15, SHERWOOD Q. 4075

Phone: (07) 3278 4375

Website: www.edg.net.au Email: brisbane@edg.net.au

C3599a - TI-TREE COLLECTIVE DISTRIBUTION BOARD DB-P REVISION A - 14 OCTOBER 2025

C3599a-0005(A).xls

							REV
		FAULT CURRENT:	6KA		MAIN SWITCH:	100A NON AUTO LOAD BREAK	A
CHASSIS SIZE:			30 POLE		SUPPLIED FROM:	MSB	Α
		CHASSIS RATING:	250A		SUPPLY CABLE:	4C+E 10	Α
		PHASES:	3				Α
		DB WITH A FULL WIDTH EM DITIONAL REQUIREMENTS		MMODATE FUTURE CC	NTACTORS AND CONTR	OLS. REFER TO THE	А
CIRC	РН	CIRCUIT	CONTROL	CABLE	LOCATION	CIRCUIT	Α
		BREAKER (amps)	EQUIPMENT	SIZE (mm ²)		USE	Α
P1	1	20	RCBO	2.5	BASEMENT	GPO	Α
P2	1	20	RCBO	2.5	BASEMENT	COMMUNICATIONS	Α
P3	1	20	RCBO	2.5	BASEMENT	JACKING PUMP	Α
P4	1	20	RCBO	2.5		GPO	Α
P5	1	20	RCBO	2.5		GPO	Α
P6	3	20	RCBO EM	2.5	BASEMENT	CFEF-1	Α
P7	1	20	RCBO	2.5		GPO	Α
P8	3	20	RCBO	2.5	BASEMENT	RSD	Α
P9	1	20	RCBO EM	2.5	BASEMENT	GSF-1	Α
P10	1	20	RCBO	2.5		GPO	Α
P11	1	20	RCBO	2.5	BASEMENT	POOL	Α
P12	1	20	RCBO	2.5	BASEMENT	POOL	Α
P13	1	20	RCBO	2.5		GPO	Α
							Α
							Α
							Α
							Α
							Α
							Α
							Α
							Α
							Α
							Α
							Α
							Α
							Α
							Α
				1			Α