

C3674a - BREAKFAST CREEK HOTEL - STAGE 2


C3674a-0002(B).xls

## ELECTRICAL EQUIPMENT SCHEDULE

REVISION B - 23 FEBRUARY 2026

THE LIGHT FITTING SUPPLIER CONTACT DETAILS MAY BE AVAILABLE ON THE EDG WEBSITE VIA THE FOLLOWING LINK  
[www.edg.net.au/Links/Lighting.htm](http://www.edg.net.au/Links/Lighting.htm)

TYPE	LAMPS	DESCRIPTION	COLOUR / ACCESSORY	CATALOGUE No	REV
S1	14.4W/M 2700K LED	LED STRIP WITHIN A SCREW FIXED EXTRUSION C/W DIFFUSER MOUNTED ON THE BAR FRONT AS PER THE ARCHITECTURAL DETAIL. PROVIDE A REMOTE DALI DIMMABLE POWER SUPPLY LOCATED IN A CONCEALED ACCESSIBLE POSITION NOTED ON THE AS CONSTRUCTED DOCUMENTS.	NATURAL	RAPID LED R2334 2700 K PLUS R2381 ALUMINIUM EXTRUSION OPAL DIFFUSER AND DALI DIMMABLE POWER SUPPLY	B
S2	14.4W/M 2700K LED	LED STRIP WITHIN A SCREW FIXED EXTRUSION C/W DIFFUSER MOUNTED UNDER THE BAR TOP TO ILLUMINATE THE WORK SPACE AS PER THE ARCHITECTURAL DETAIL. PROVIDE THE STRIP WITH REMOTE DALI DIMMABLE POWER SUPPLY LOCATED IN A CONCEALED ACCESSIBLE POSITION NOTED ON THE AS CONSTRUCTED DOCUMENTS.	NATURAL	RAPID LED R2334 2700 K PLUS R2380 COERNER MOUNT ALUMINIUM EXTRUSION OPAL DIFFUSER AND POWER SUPPLY & DALI CONTROLLER	B
S3	14.4W/M 2700K LED	TWO PARRALLEL LED STRIPS WITHIN A SCREW FIXED EXTRUSION C/W DIFFUSER MOUNTED WITHIN THE REAR BAR DISPLAY AS PER THE ARCHITECTURAL DETAIL. PROVIDE A REMOTE DALI DIMMABLE POWER SUPPLY LOCATED IN A CONCEALED ACCESSIBLE POSITION NOTED ON THE AS CONSTRUCTED DOCUMENTS.	NATURAL	RAPID LED R2334 2700 K PLUS R2381 ALUMINIUM EXTRUSION OPAL DIFFUSER AND DALI DIMMABLE POWER SUPPLY	B
S4	10W/M 2700K LED	IP67 FLEXIBLE LED STRIP WITHIN A SCREW FIXED MOUNTING MOUNTED ON THE GARDEN EDGE AS PER THE ARCHITECTURAL DETAIL. PROVIDE A REMOTE DALI DIMMABLE POWER SUPPLY LOCATED IN A CONCEALED ACCESSIBLE POSITION NOTED ON THE AS CONSTRUCTED DOCUMENTS. CONFIRM THE BEND DIRECTION ON SITE.	NATURAL	RAPID LED R2321 OR R2322 AND DALI DIMMABLE POWER SUPPLY	B
S5	14.4W/M 2700K LED	LED STRIP WITHIN A SCREW FIXED EXTRUSION C/W DIFFUSER MOUNTED WITHIN THE JOINERY AS PER THE ARCHITECTURAL DETAIL TO ILLUMINATE DOWNWARDS. PROVIDE A REMOTE DALI DIMMABLE POWER SUPPLY LOCATED IN A CONCEALED ACCESSIBLE POSITION NOTED ON THE AS CONSTRUCTED DOCUMENTS.	NATURAL	RAPID LED R2334 2700 K PLUS R2381 ALUMINIUM EXTRUSION OPAL DIFFUSER AND DALI DIMMABLE POWER SUPPLY	B
S6	14.4W/M 2700K LED	LED STRIP WITHIN A SCREW FIXED EXTRUSION C/W DIFFUSER MOUNTED WITHIN THE JOINERY AS PER THE ARCHITECTURAL DETAIL TO ILLUMINATE UPWARDS. PROVIDE A REMOTE DALI DIMMABLE POWER SUPPLY LOCATED IN A CONCEALED ACCESSIBLE POSITION NOTED ON THE AS CONSTRUCTED DOCUMENTS.	NATURAL	RAPID LED R2334 2700 K PLUS R2381 ALUMINIUM EXTRUSION OPAL DIFFUSER AND DALI DIMMABLE POWER SUPPLY	B



C3674a - BREAKFAST CREEK HOTEL - STAGE 2


C3674a-0002(B).xls

## ELECTRICAL EQUIPMENT SCHEDULE

REVISION B - 23 FEBRUARY 2026

THE LIGHT FITTING SUPPLIER CONTACT DETAILS MAY BE AVAILABLE ON THE EDG WEBSITE VIA THE FOLLOWING LINK  
[www.edg.net.au/Links/Lighting.htm](http://www.edg.net.au/Links/Lighting.htm)

TYPE	LAMPS	DESCRIPTION	COLOUR / ACCESSORY	CATALOGUE No	REV
S7	14.4W/M 2700K LED	LED STRIP WITHIN A SCREW FIXED EXTRUSION C/W DIFFUSER MOUNTED WITHIN THE JOINERY AS PER THE ARCHITECTURAL DETAIL TO ILLUMINATE UPWARDS. PROVIDE A REMOTE DALI DIMMABLE POWER SUPPLY LOCATED IN A CONCEALED ACCESSIBLE POSITION NOTED ON THE AS CONSTRUCTED DOCUMENTS.	NATURAL	RAPID LED R2334 2700 K PLUS R2381 ALUMINIUM EXTRUSION OPAL DIFFUSER AND DALI DIMMABLE POWER SUPPLY	B
S8	10W/M 2700K LED	IP67 FLEXIBLE LED STRIP WITHIN A SCREW FIXED MOUNTING RECESSED INTO THE JOINERY AS PER THE ARCHITECTURAL DETAIL. PROVIDE A REMOTE DALI DIMMABLE POWER SUPPLY LOCATED IN A CONCEALED ACCESSIBLE POSITION NOTED ON THE AS CONSTRUCTED DOCUMENTS. CONFIRM THE BEND DIRECTION ON SITE.	NATURAL	RAPID LED R2321 OR R2322 AND DALI DIMMABLE POWER SUPPLY	B
S9	10W/M 2700K LED	IP67 FLEXIBLE LED STRIP WITHIN A SCREW FIXED MOUNTING IN THE SEAT SKIRTING AS PER THE ARCHITECTURAL DETAIL. PROVIDE A REMOTE DALI DIMMABLE POWER SUPPLY LOCATED IN A CONCEALED ACCESSIBLE POSITION NOTED ON THE AS CONSTRUCTED DOCUMENTS. CONFIRM THE BEND DIRECTION ON SITE.	NATURAL	RAPID LED R2321 OR R2322 AND DALI DIMMABLE POWER SUPPLY	B
S10	10W/M 2700K LED	IP67 FLEXIBLE LED STRIP WITHIN A SCREW FIXED MOUNTING RECESSED INTO THE SEAT BACK AS PER THE ARCHITECTURAL DETAIL. PROVIDE A REMOTE DALI DIMMABLE POWER SUPPLY LOCATED IN A CONCEALED ACCESSIBLE POSITION NOTED ON THE AS CONSTRUCTED DOCUMENTS. CONFIRM THE BEND DIRECTION ON SITE.	NATURAL	RAPID LED R2321 OR R2322 AND DALI DIMMABLE POWER SUPPLY	B
S11	PROVIDE THE LED LIGHTING THAT IS SUPPLIED INTEGRAL AS PART OF THE HAND RAIL WITH REMOTE DALI DIMMABLE POWER SUPPLIES AS REQUIRED LOCATE THE POWER SUPPLIES IN A CONCEALED ACCESSIBLE POSITION NOTED ON THE AS CONSTRUCTED DOCUMENTS.				B
S12	14.4W/M 2700K LED	LED STRIP WITHIN A SCREW FIXED EXTRUSION C/W DIFFUSER MOUNTED ON TOP OF THE EXISTING HIGH LEVEL CEILING SPACE FEATURE. PROVIDE A REMOTE DALI DIMMABLE POWER SUPPLY LOCATED IN A CONCEALED ACCESSIBLE POSITION NOTED ON THE AS CONSTRUCTED DOCUMENTS.	NATURAL	RAPID LED R2334 2700 K PLUS R2381 ALUMINIUM EXTRUSION OPAL DIFFUSER AND DALI DIMMABLE POWER SUPPLY	B



C3674a - BREAKFAST CREEK HOTEL - STAGE 2


C3674a-0002(B).xls

## ELECTRICAL EQUIPMENT SCHEDULE

REVISION B - 23 FEBRUARY 2026

THE LIGHT FITTING SUPPLIER CONTACT DETAILS MAY BE AVAILABLE ON THE EDG WEBSITE VIA THE FOLLOWING LINK  
[www.edg.net.au/Links/Lighting.htm](http://www.edg.net.au/Links/Lighting.htm)

TYPE	LAMPS	DESCRIPTION	COLOUR / ACCESSORY	CATALOGUE No	REV
S13	14.4W/M 2700K LED	LED STRIP WITHIN A SCREW FIXED EXTRUSION C/W DIFFUSER MOUNTED ON TOP OF THE EXISTING HIGH LEVEL CEILING SPACE FEATURE. PROVIDE A REMOTE DALI DIMMABLE POWER SUPPLY LOCATED IN A CONCEALED ACCESSIBLE POSITION NOTED ON THE AS CONSTRUCTED DOCUMENTS.	NATURAL	RAPID LED R2334 2700 K PLUS R2381 ALUMINIUM EXTRUSION OPAL DIFFUSER AND DALI DIMMABLE POWER SUPPLY	B
S14	14.4W/M 2700K LED	LED STRIP WITHIN A SCREW FIXED EXTRUSION C/W DIFFUSER MOUNTED ON TOP OF THE EXISTING HIGH LEVEL CEILING SPACE FEATURE. PROVIDE A REMOTE DALI DIMMABLE POWER SUPPLY LOCATED IN A CONCEALED ACCESSIBLE POSITION NOTED ON THE AS CONSTRUCTED DOCUMENTS.	NATURAL	RAPID LED R2334 2700 K PLUS R2381 ALUMINIUM EXTRUSION OPAL DIFFUSER AND DALI DIMMABLE POWER SUPPLY	B
S15	14.4W/M 2700K LED	LED STRIP WITHIN A SCREW FIXED EXTRUSION C/W DIFFUSER MOUNTED ON TOP OF THE EXISTING HIGH LEVEL CEILING SPACE FEATURE. PROVIDE A REMOTE DALI DIMMABLE POWER SUPPLY LOCATED IN A CONCEALED ACCESSIBLE POSITION NOTED ON THE AS CONSTRUCTED DOCUMENTS.	NATURAL	RAPID LED R2334 2700 K PLUS R2381 ALUMINIUM EXTRUSION OPAL DIFFUSER AND DALI DIMMABLE POWER SUPPLY	B
S16	14.4W/M 2700K LED	LED STRIP WITHIN A SCREW FIXED EXTRUSION C/W DIFFUSER SURFACE MOUNTED BEHIND THE TV IN A RECTANGLE TO THE TV MOUNTING BLOCK AS PER THE ARCHITECTURAL DETAIL. PROVIDE A REMOTE DALI DIMMABLE POWER SUPPLY LOCATED IN A CONCEALED ACCESSIBLE POSITION NOTED ON THE AS CONSTRUCTED DOCUMENTS.	NATURAL	RAPID LED R2334 2700 K PLUS R2381 ALUMINIUM EXTRUSION OPAL DIFFUSER AND DALI DIMMABLE POWER SUPPLY	B
S17	10W/M 2700K LED	IP67 FLEXIBLE LED STRIP WITHIN A SCREW FIXED MOUNTING FIXED TO THE TOP EDGE OF THE ANGLED STRUCTUTURAL STEEL TO ILLUMINATE UPWARDS. PROVIDE A REMOTE DALI DIMMABLE POWER SUPPLY LOCATED IN A CONCEALED ACCESSIBLE POSITION NOTED ON THE AS CONSTRUCTED DOCUMENTS.	NATURAL	RAPID LED R2321 AND DALI DIMMABLE POWER SUPPLY	B



# ELECTRICAL DESIGN GROUP

ELECTRICAL BUILDING SERVICES CONSULTANTS

P.O. Box 15, SHERWOOD Q. 4075

Phone: (07) 3278 4375 Fax: (07) 3716 0222

Web Site: [www.edg.net.au](http://www.edg.net.au) Email: [brisbane@edg.net.au](mailto:brisbane@edg.net.au)

C3674a - BREAKFAST CREEK HOTEL - STAGE 2

C3674a-0002(B).xls

## ELECTRICAL EQUIPMENT SCHEDULE


REVISION B - 23 FEBRUARY 2026

THE LIGHT FITTING SUPPLIER CONTACT DETAILS MAY BE AVAILABLE ON THE EDG WEBSITE VIA THE FOLLOWING LINK  
[www.edg.net.au/Links/Lighting.htm](http://www.edg.net.au/Links/Lighting.htm)

TYPE	LAMPS	DESCRIPTION	COLOUR / ACCESSORY	CATALOGUE No	REV
S18	10W/M 2700K LED	IP67 FLEXIBLE LED STRIP WITHIN A SCREW FIXED MOUNTING RECESSED INTO THE WINDOW SILL AS PER THE ARCHITECTURAL DETAIL. PROVIDE A REMOTE DALI DIMMABLE POWER SUPPLY LOCATED IN A CONCEALED ACCESSIBLE POSITION NOTED ON THE AS CONSTRUCTED DOCUMENTS. CONFIRM THE BEND DIRECTION ON SITE.	NATURAL	RAPID LED R2321 OR R2322 AND DALI DIMMABLE POWER SUPPLY	B
S19	10W/M 2700K LED	IP67 FLEXIBLE LED STRIP WITHIN A SCREW FIXED MOUNTING IN THE SEAT SKIRTING AS PER THE ARCHITECTURAL DETAIL. PROVIDE A REMOTE DALI DIMMABLE POWER SUPPLY LOCATED IN A CONCEALED ACCESSIBLE POSITION NOTED ON THE AS CONSTRUCTED DOCUMENTS. CONFIRM THE BEND DIRECTION ON SITE.	NATURAL	RAPID LED R2321 OR R2322 AND DALI DIMMABLE POWER SUPPLY	B
S20	14.4W/M 2700K LED	LED STRIP WITHIN A SCREW FIXED EXTRUSION C/W DIFFUSER MOUNTED BEHIND THE WINDOW AS PER THE ARCHITECTURAL DETAIL TO ILLUMINATE UPWARDS. PROVIDE A REMOTE DALI DIMMABLE POWER SUPPLY LOCATED IN A CONCEALED ACCESSIBLE POSITION NOTED ON THE AS CONSTRUCTED DOCUMENTS.	NATURAL	RAPID LED R2334 2700 K PLUS R2381 ALUMINIUM EXTRUSION OPAL DIFFUSER AND DALI DIMMABLE POWER SUPPLY	B
PD01	2400K LED	CUSTOM SUSPENDED LANEWAY MULTI LAMP FEATURE LIGHT WALL C/W REMOTE DALI DIMMABLE DRIVER LOCATED IN A CONCEALED ACCESSIBLE POSITION NOTED ON THE AS CONSTRUCTED DOCUMENTS. SUSPEND THE FITTING AS DIRECTED BY THE ARCHITECT ON SITE.	BRONZE FINISH	LUMEN 8 L8 BESPOKE-SOLARPDT	B
PD02	2700K LED	CUSTOM SUSPENDED LANEWAY MULTI LAMP FEATURE LIGHT WALL C/W REMOTE DALI DIMMABLE DRIVER LOCATED IN A CONCEALED ACCESSIBLE POSITION NOTED ON THE AS CONSTRUCTED DOCUMENTS. SUSPEND THE FITTING AS DIRECTED BY THE ARCHITECT ON SITE.	BRONZE FINISH	LUMEN 8 L8 BESPOKE-CONDENSERPDT W190 x H950	B
PD03	2700K LED	CUSTOM SUSPENDED LANEWAY MULTI LAMP FEATURE LIGHT WALL C/W REMOTE DALI DIMMABLE DRIVER LOCATED IN A CONCEALED ACCESSIBLE POSITION NOTED ON THE AS CONSTRUCTED DOCUMENTS. SUSPEND THE FITTING AS DIRECTED BY THE ARCHITECT ON SITE.	ALUMINIUM	LUMEN 8 L8 BESPOKE-ARCHES-L	B
PD04	2700K LED	CUSTOM SUSPENDED LANEWAY MULTI LAMP FEATURE LIGHT WALL C/W REMOTE DALI DIMMABLE DRIVER LOCATED IN A CONCEALED ACCESSIBLE POSITION NOTED ON THE AS CONSTRUCTED DOCUMENTS. SUSPEND THE FITTING AS DIRECTED BY THE ARCHITECT ON SITE.	ALUMINIUM	LUMEN 8 L8 BESPOKE-ARCHES-S	B

C3674a-0002(B).xls

Pages inc. any attach. 4 of 10



C3674a - BREAKFAST CREEK HOTEL - STAGE 2


C3674a-0002(B).xls

## ELECTRICAL EQUIPMENT SCHEDULE

REVISION B - 23 FEBRUARY 2026

THE LIGHT FITTING SUPPLIER CONTACT DETAILS MAY BE AVAILABLE ON THE EDG WEBSITE VIA THE FOLLOWING LINK  
[www.edg.net.au/Links/Lighting.htm](http://www.edg.net.au/Links/Lighting.htm)

TYPE	LAMPS	DESCRIPTION	COLOUR / ACCESSORY	CATALOGUE No	REV
WL01	TRAILING EDGE DIMMABLE GU10 240 VOLT 2700K 400LUMEN +/-10% LED	DECORATIVE 305X115 WALL LIGHT MOUNTED AS PER THE ARCHITECTURAL DETAILS SUPPLY THESE FITTINGS VIA SURFACE MOUNTED COPPER CONDUIT FITTINGS AND FIXTURE AS DETILED ON THE ARCHITECTURAL DRAWINGS	BRONZE FINISH	LUMEN 8 BESPOKE - SOLRWL N	B
WL02	TRAILING EDGE DIMMABLE A60 240 VOLT 2700K 400LUMEN +/-10% E27 LED	DECORATIVE 300 DIA WALL LIGHT MOUNTED AS PER THE ARCHITECTURAL DETAILS	BRONZE FINISH	LUMEN 8 BESPOKE- HARBOUR	B
WL03	TRAILING EDGE DIMMABLE E14 240 VOLT 2700K 400LUMEN +/-10% LED	DECORATIVE 120 X 260 WALL LIGHT MOUNTED AS PER THE ARCHITECTURAL DETAILS SUPPLY THESE FITTINGS VIA SURFACE MOUNTED COPPER CONDUIT FITTINGS AND FIXTURE AS DETILED ON THE ARCHITECTURAL DRAWINGS. SUPPLY THESE FITTINGS VIA SURFACE MOUNTED COPPER CONDUIT FITTINGS AND FIXTURE AS DETILED ON THE ARCHITECTURAL DRAWINGS	BRONZE FINISH	LUMEN 8 BESPOKE- INSULATORWLB	B
WL04	2700K LED	CUSTOM WALL LIGHT C/W REMOTE DALI DIMMABLE DRIVER LOCATED IN A CONCEALED ACCESSIBLE POSITION NOTED ON THE AS CONSTRUCTED DOCUMENTS. MOUNT THE FITTINGS AS DIRECTED BY THE ARCHITECT ON SITE. SUPPLY THESE FITTINGS VIA SURFACE MOUNTED COPPER CONDUIT FITTINGS AND FIXTURE AS DETILED ON THE ARCHITECTURAL DRAWINGS	BRONZE FINISH	LUMEN 8 BESPOKE- CONDENSERWLB	B
WL05	2700K LED	WALL MOUNTED UP DOWN LIGHT C/W REMOTE DALI DIMMABLE DRIVER LOCATED IN A CONCEALED ACCESSIBLE POSITION NOTED ON THE AS CONSTRUCTED DOCUMENTS. MOUNT THE FITTINGS AS DIRECTED BY THE ARCHITECT ON SITE.	BRONZE FINISH	LUMEN 8 L8 BESPOKE- WAVERWLB	B
WL06	2700K LED	REPLACE THE EXISTING WALL LIGHTS WITH WALL MOUNTED UP DOWN LIGHT C/W REMOTE DALI DIMMABLE DRIVER LOCATED IN A CONCEALED ACCESSIBLE POSITION NOTED ON THE AS CONSTRUCTED DOCUMENTS. MOUNT THE FITTINGS AS DIRECTED BY THE ARCHITECT ON SITE.	BRONZE FINISH	LUMEN 8 L8 BESPOKE-OMBRE	B
RD01	25W3000K LED	RECESSED DOWNLIGHT C/W 60 DEG BEAM REMOTE DALI DIMMABLE DRIVER	BRONZE FINISH	RAPID R1354-WH- 25W-WW-DALI	B
RD02	12W 2700K LED	RECESSED DOWNLIGHT C/W 24 DEG BEAM REMOTE DALI DIMMABLE DRIVER	BRONZE FINISH	RAPID R1077-WH- 12W-2700k-DALI	B



C3674a - BREAKFAST CREEK HOTEL - STAGE 2


C3674a-0002(B).xls

## ELECTRICAL EQUIPMENT SCHEDULE

REVISION B - 23 FEBRUARY 2026

THE LIGHT FITTING SUPPLIER CONTACT DETAILS MAY BE AVAILABLE ON THE EDG WEBSITE VIA THE FOLLOWING LINK  
[www.edg.net.au/Links/Lighting.htm](http://www.edg.net.au/Links/Lighting.htm)

TYPE	LAMPS	DESCRIPTION	COLOUR / ACCESSORY	CATALOGUE No	REV
SL01	2700K LED	WALL MOUNTED ADJUSTABLE SPOT LIGHT C/W REMOTE DALI DIMMABLE DRIVER LOCATED IN A CONCEALED ACCESSIBLE POSITION NOTED ON THE AS CONSTRUCTED DOCUMENTS. MOUNT THE FITTINGS AS DIRECTED BY THE ARCHITECT ON SITE. SUPPLY THESE FITTINGS VIA SURFACE MOUNTED COPPER CONDUIT FITTINGS AND FIXTURE AS DETILED ON THE ARCHITECTURAL DRAWINGS	BRONZE FINISH	LUMEN 8 MIMANTE M MIM12323.J.52HC	B
SL02	13W 2700K LED	SURFACE MOUNTED DOWNLIGHT C/W INTEGRAL DALI DIMMABLE DRIVER	BRONZE FINISH	GAMMA ILLUMINATION TUBO 1101-FL-2700K-13W	B
SL03	RGBWW LED	SURFACE MOUNTED WIDE BEAM ADJUSTABLE IP66 COLOUR CHANGING FLOOD LIGHT C/W REMOTE RGBWW DALI DRIVER / POWER SUPPLY POSITIONED AND AIMED AS DIRECTED BY THE ARCHITECT ON SITE.	BRONZE FINISH	SUPERLIGHT SL800UA RGBWW DALI DRIVER	B
SL04	2700K LED	WALL MOUNTED ADJUSTABLE SPOT LIGHT C/W REMOTE DALI DIMMABLE DRIVER LOCATED IN A CONCEALED ACCESSIBLE POSITION NOTED ON THE AS CONSTRUCTED DOCUMENTS.	BRONZE FINISH	LUMEN 8 MIMANTE L MIM13323J.52	B
SL05	2700K LED	WALL MOUNTED ADJUSTABLE SPOT LIGHT C/W REMOTE DALI DIMMABLE DRIVER LOCATED IN A CONCEALED ACCESSIBLE POSITION NOTED ON THE AS CONSTRUCTED DOCUMENTS. MOUNT THE FITTINGS AS DIRECTED BY THE ARCHITECT ON SITE.	BRONZE FINISH	LUMEN 8 MIMANTE L MIM13323J.52	B
SL06	2700K LED	REPLACE THE EXISTING WALL MOUNTED ADJUSTABLE SPOT LIGHT C/W REMOTE DALI DIMMABLE DRIVER LOCATED IN A CONCEALED ACCESSIBLE POSITION NOTED ON THE AS CONSTRUCTED DOCUMENTS.	BRONZE FINISH	LUMEN 8 MIMANTE L MIM13323J.52	B
L1	EXISTING KITCHEN TROFFER TO BE RETAINED AND RESUPPLIED / CONTROLLED AS INDICATED				A
L2	EXISTING KITCHEN BATTEN TO BE RETAINED AND RESUPPLIED / CONTROLLED AS INDICATED				A
L3	PROVIDE A NEW RECESSED KITCHEN TROFFER TO MATCH THE EXISTING L1 FITTINGS				A
L4	2700K LED	WALL MOUNTED ILLUMINATED FEATURE. ALLOW TO INSTALL AND POSITION AS DIRECTED BY THE ARCHITECT. ALLOW A PC SUM FOR THE SUPPLY OF THE L4 FITTING.	BRONZE FINISH	LUMEN 8 L8 BESPOKE-OMBRE	B



# ELECTRICAL DESIGN GROUP

ELECTRICAL BUILDING SERVICES CONSULTANTS

P.O. Box 15, SHERWOOD Q. 4075

Phone: (07) 3278 4375 Fax: (07) 3716 0222

Web Site: [www.edg.net.au](http://www.edg.net.au) Email: [brisbane@edg.net.au](mailto:brisbane@edg.net.au)

C3674a - BREAKFAST CREEK HOTEL - STAGE 2


C3674a-0002(B).xls

## ELECTRICAL EQUIPMENT SCHEDULE

REVISION B - 23 FEBRUARY 2026

THE LIGHT FITTING SUPPLIER CONTACT DETAILS MAY BE AVAILABLE ON THE EDG WEBSITE VIA THE FOLLOWING LINK  
[www.edg.net.au/Links/Lighting.htm](http://www.edg.net.au/Links/Lighting.htm)

TYPE	LAMPS	DESCRIPTION	COLOUR / ACCESSORY	CATALOGUE No	REV
L5	2200K LED	PALM TREE BUD LIGHTS. ALLOW A PC SUM FOR THE SUPPLY AND INSTALLATION OF EACH L5 FITTING.	BLACK	ALLOW A PC SUM OF \$5000.00 PLUS GST FOR THE SUPPLY AND INSTALLATION OF EACH L5 FITTING	A
L6	12W 2700K LED	GARDEN ELV SPIKE LIGHT. PROVIDE EACH GROUP OF L6 FITTINGS WITH A REMOTE COMMON DALI DIMMABLE POWER SUPPLY. LOCATE DALI CONTROLLER /POWER SUPPLY IN A CONCEALED ACCESSIBLE POSITION NOTED ON THE AS CONSTRUCTED DOCUMENTS.	BLACK	GAMMA ILLUMINATION RULLO 1373-FL-2700K-12W-24V+ 373	B
L7		REMOVE THE EXISTING SUPPLY AND CONTROLS FROM THE EXISTING LED STRIP LIGHTING AND RESUPPLY / CONTROL THEM FROM THE DYNALITE LIGHTING CONTROL SYSTEM AS INDICATED. REPLACE THE EXISTING LEDS AND DRIVERS WITH NEW DALI DIMMABLE LEDS / DRIVERS. THE LEDS CAN BE RETAINED IF THEY CAN BE DIMMED VIA THE NEW DALI DRIVERS.			B
L8		REMOVE THE EXISTING SUPPLY AND CONTROLS FROM THE EXISTING SIGNS AND RESUPPLY / CONTROL THEM FROM THE DYNALITE LIGHTING CONTROL SYSTEM AS INDICATED. REPLACE THE SIGNS EXISTING LEDS AND DRIVERS WITH NEW DALI DIMMABLE LEDS / DRIVERS. THE LEDS CAN BE RETAINED IF THEY CAN BE DIMMED VIA THE NEW DALI DRIVERS.			B
L9		EXISTING DALI DIMMABLE RECESSED DOWNLIGHTS TO REMAIN AND BE RESUPPLY / CONTROL THEM FROM THE DYNALITE LIGHTING CONTROL SYSTEM AS INDICATED			A
L10		EXISTING WALL LIGHT ALLOW TO CUSTOM MODIFY THE EXISTING 240 VOLT WALL LIGHT AND ITS CONTROL TO BE UP / DOWN 2700K-12 / 24V DC LED C/W A REMOTE DALI DIMMABLE CONTROLLED FROM THE DYNALITE LIGHTING CONTROL SYSTEM AS INDICATED			B
GL01	12W 2700K LED	GARDEN ELV SPIKE LIGHT. PROVIDE EACH GROUP OF GL01 FITTINGS WITH A REMOTE COMMON DALI DIMMABLE POWER SUPPLY. LOCATE DALI CONTROLLER /POWER SUPPLY IN A CONCEALED ACCESSIBLE POSITION NOTED ON THE AS CONSTRUCTED DOCUMENTS.	BLACK	GAMMA ILLUMINATION RULLO 1373-FL-2700K-12W-24V+ 373	A
GL02	31W RGBWW LED	GARDEN MOUNTED WIDE BEAM ADJUSTABLE IP66 COLOUR CHANGING FLOOD LIGHT C/W REMOTE RGBWW DALI DRIVER / POWER SUPPLY POSITIONED AND AIMED AS DIRECTED BY THE ARCHITECT ON SITE.	GUNMETAL	SUPERLIGHT SL600UA RGBWW DALI DRIVER	B
E1	LED	EMERGENCY LIGHT: RECESSED NON-MAINTAINED EMERGENCY LIGHT. AS2293 CLASSIFICATION C0-D40 - C90-D40.	WHITE	CLEVERTRONICS LLIFE	A
E2	LED	EMERGENCY LIGHT: SURFACE MOUNTED NON-MAINTAINED EMERGENCY LIGHT. AS2293 CLASSIFICATION C0-D40 - C90-D40.	BLACK	CLEVERTRONICS LLIFESM-BK	A



C3674a - BREAKFAST CREEK HOTEL - STAGE 2


C3674a-0002(B).xls

## ELECTRICAL EQUIPMENT SCHEDULE

REVISION B - 23 FEBRUARY 2026

THE LIGHT FITTING SUPPLIER CONTACT DETAILS MAY BE AVAILABLE ON THE EDG WEBSITE VIA THE FOLLOWING LINK  
[www.edg.net.au/Links/Lighting.htm](http://www.edg.net.au/Links/Lighting.htm)

TYPE	LAMPS	DESCRIPTION	COLOUR / ACCESSORY	CATALOGUE No	REV
E3	LED	EMERGENCY LIGHT: RECESSED NON-MAINTAINED EMERGENCY LIGHT. AS2293 CLASSIFICATION C0-D40 - C90-D40.	BLACK	CLEVERTRONICS LLIFEBLK	A
EX	LED	EXIT LIGHT: MAINTAINED 24M VIEWING DISTANCE EXIT LIGHT C/W DIFFUSERS & DIRECTIONAL ARROWS AS SHOWN. CEILING SURFACE MOUNT OR WALL MOUNT BETWEEN 2100mm & 2700mm AFFL IF THERE IS NO VERTICAL SURFACE TO MOUNT THE FITTING ON WITHIN THIS RANGE CONFIRM THE MOUNTING HEIGHT WITH THE ENGINEER. AS2293 CLASSIFICATION C0-D1.25- C90-D2	WHITE	CLEVERTRONICS LUBPRO-SM	A
EX BK	LED	EXIT LIGHT: MAINTAINED 24M VIEWING DISTANCE EXIT LIGHT C/W DIFFUSERS & DIRECTIONAL ARROWS AS SHOWN. CEILING SURFACE MOUNT OR WALL MOUNT BETWEEN 2100mm & 2700mm AFFL IF THERE IS NO VERTICAL SURFACE TO MOUNT THE FITTING ON WITHIN THIS RANGE CONFIRM THE MOUNTING HEIGHT WITH THE ENGINEER. AS2293 CLASSIFICATION C0-D1.25- C90-D2	BLACK	CLEVERTRONICS LUBPRO-SM-BLK	A
HL01	100W IR LAMP	HEAT LAMP PENDANT TO BE PROVIDED WITH AN INDIVIDUAL SWITCH. CONFIRM THE SUSPENSION HEIGHT ON SITE WITH THE ARCHITECT.	ANTIQUE COPPER	HATCO DL-2100	A
HL02	1750WATT	2100 LONG LINEAR HEAT LAMP C/W CUSTOM SUPPORT AND INTEGRAL SWITCH MOUNTED AS PER THE ARCHITECTURAL DETAIL ALL CABLING IS TO BE CONCEALED	SILVER	ROBAND HQ2100E	A
HL03	700 WATT	900 LONG LINEAR HEAT LAMP C/W CUSTOM SUPPORT AND INTEGRAL SWITCH MOUNTED AS PER THE ARCHITECTURAL DETAIL ALL CABLING IS TO BE CONCEALED	SILVER	ROBAND HQ900E	A
HL04	1050WATT	1200 LONG LINEAR HEAT LAMP C/W CUSTOM SUPPORT AND INTEGRAL SWITCH MOUNTED AS PER THE ARCHITECTURAL DETAIL ALL CABLING IS TO BE CONCEALED	SILVER	ROBAND HQ1200E	A
HRE		EXISTING HEATER TO BE RETAINED			A
F01	CEILING FAN	15701 DIA CEILING FAN MOUNTED ON THE UNDERSIDE OF THE SHADE SALE STRUCTURE C/W A REMOTE WIRED CONTROLLER.	WHITE	VENTAIR SPY1573NWH	A



C3674a - BREAKFAST CREEK HOTEL - STAGE 2


C3674a-0002(B).xls

## ELECTRICAL EQUIPMENT SCHEDULE

REVISION B - 23 FEBRUARY 2026

THE LIGHT FITTING SUPPLIER CONTACT DETAILS MAY BE AVAILABLE ON THE EDG WEBSITE VIA THE FOLLOWING LINK  
[www.edg.net.au/Links/Lighting.htm](http://www.edg.net.au/Links/Lighting.htm)

TYPE	LAMPS	DESCRIPTION	COLOUR / ACCESSORY	CATALOGUE No	REV
F01 FAN CONTROLLER (FC)		F01 FAN CONTROLLER CONNECTED TO THE NOMINATED FAN VIA A CONCEALED CABLE MOUNTED AT 1000mm AFFL UNLESS NOTED OTHERWISE.	BLACK	CLIPSAL C2000 SERIES FACEPLATE	A
CHANNEL x		CONTROL CHANNEL WITH A NUMERICAL REFERENCE. REFER TO THE POWER AND LIGHTING CONTROL SCHEMATIC / SCHEDULE			A
ONE-WAY LIGHT SWITCH		ONE-WAY LIGHT SWITCH C/W CIRCUIT IDENTIFICATION ON THE FACEPLATE BEHIND THE SURROUND MOUNTED AT 1000mm AFFL UNLESS NOTED OTHERWISE.	WHITE UNLESS NOTED AS BLACK (BK)	CLIPSAL C2000 SERIES FACEPLATE	A
LIGHTING CONTROL SWITCH PANEL (SPx)		6-BUTTON PROGRAMMABLE SWITCH PANEL C/W CENTRAL LCD DISPLAY MOUNTED AT 1000mm AFFL UNLESS NOTED OTHERWISE.	ALUMINIUM	DYNALITE ANTUMBRA DISPLAY	A
CABLE ACCESS DUCT A		REPLACE THE EXISTING CABLE ACCESS WAYS WITH A NEW COPPER DUCT 100 DEEP BY THE WIDTH OF THE COLUMN FROM THE FLOOR TO THE MEZZANINBE CEILING. RELOCATE ALL EXISTING SERVICES AS NECESSARY TO FACILITATE THE DATE.			A
SINGLE POWER OUTLET		SINGLE POWER OUTLET C/W CIRCUIT IDENTIFICATION ON THE FACEPLATE BEHIND THE SURROUND MOUNT AT 300mm AFFL U.N.O. RATING 10A U.N.O.	WHITE UNLESS NOTED AS BLACK (BK)	CLIPSAL C2000 SERIES	A
DOUBLE POWER OUTLET		DOUBLE POWER OUTLET C/W CIRCUIT IDENTIFICATION ON THE FACEPLATE BEHIND THE SURROUND MOUNT AT 300mm AFFL U.N.O. RATING 10A U.N.O.	WHITE UNLESS NOTED AS BLACK (BK)	CLIPSAL C2000 SERIES	A
SIGN CONNECTION		COORDINATE THE LOCATION AND CONNECTION WITH THE SIGN CONTRACTOR ENSURING THE CONNECTION ARE PROVIDED WITH APPROPRIATE WEATHER PROTECTION AND ARE CONCEALED FROM VIEW.			A
SINGLE-PHASE ISOLATOR		SINGLE-PHASE WEATHERPROOF ISOLATOR. MOUNT AT 1350mm AFFL U.N.O. RATING 20A U.N.O. CONNECT TO EQUIPMENT VIA FLEXIBLE CONDUIT.	-	CLIPSAL WHT20	A
THREE-PHASE ISOLATOR		THREE-PHASE WEATHERPROOF ISOLATOR. MOUNT AT 1350mm AFFL U.N.O. RATING 20A U.N.O. CONNECT TO EQUIPMENT VIA FLEXIBLE CONDUIT.	-	CLIPSAL WHT35	A
DB-A		EXISTING DISTRIBUTION BOARD DB-A TO REMAIN. ANY EXISTING CIRCUITS THAT BECOME REDUNDANT DUE TO THE WORKS ARE TO BE REMOVED. PROVIDE DB-A WITH A NEW MCB TO SUPPLY DB-E.			B
DB-B		EXISTING DISTRIBUTION BOARD DB-B TO REMAIN. ANY EXISTING CIRCUITS THAT BECOME REDUNDANT DUE TO THE WORKS ARE TO BE REMOVED.			B



# ELECTRICAL DESIGN GROUP

ELECTRICAL BUILDING SERVICES CONSULTANTS

P.O. Box 15, SHERWOOD Q. 4075

Phone: (07) 3278 4375 Fax: (07) 3716 0222

Web Site: [www.edg.net.au](http://www.edg.net.au) Email: [brisbane@edg.net.au](mailto:brisbane@edg.net.au)

C3674a - BREAKFAST CREEK HOTEL - STAGE 2

C3674a-0002(B).xls

## ELECTRICAL EQUIPMENT SCHEDULE

REVISION B - 23 FEBRUARY 2026

THE LIGHT FITTING SUPPLIER CONTACT DETAILS MAY BE AVAILABLE ON THE EDG WEBSITE VIA THE FOLLOWING LINK  
[www.edg.net.au/Links/Lighting.htm](http://www.edg.net.au/Links/Lighting.htm)

TYPE	LAMPS	DESCRIPTION	COLOUR / ACCESSORY	CATALOGUE No	REV
DB-C		REPLACE THE EXISTING DISTRIBUTION BOARD DB-C AND THE ASSOCIATED ENCLOSURES, CBUS CONTROLS AND LOAD CENTRES AS PER THE DB-C SCHEDULE AND NOTES. PROVIDE A REMOVABLE HAT SECTION FROM THE TOP OF THE DISTRIBUTION BOARD TO THE CEILING. THE HAT SECTION IS TO BE OF THE SAME MATERIAL, COLOUR DEPTH AND WIDTH AS THE DISTRIBUTION BOARD. RECONNECT ALL EXISTING CIRCUITS THAT REMAIN TO THE NEW DISTRIBUTION BOARD WITH NEW AS3000 COMPLIANT SWITCHGEAR.			B
DB-E		PROVIDE A NEW DISTRIBUTION BOARD DB-E AS PER THE DB-E SCHEDULE AND NOTES. MODIFY THE EXISTING SHELVING / JOINERY TO ACCOMMODATE THE MOUNTING OF DB-E.			B
DB-P		EXISTING DISTRIBUTION BOARD TO BE UTILISED TO ACCOMMODATE THE PIZZA KITCHEN LIGHTING CONTROL CHANGES.			B
DB-S		REPLACE THE EXISTING DISTRIBUTION BOARD DB-S AS PER THE DB-C SCHEDULE AND NOTES. PROVIDE A REMOVABLE HAT SECTION FROM THE TOP OF THE DISTRIBUTION BOARD TO THE CEILING. THE HAT SECTION IS TO BE OF THE SAME MATERIAL, COLOUR DEPTH AND WIDTH AS THE DISTRIBUTION BOARD. RECONNECT ALL EXISTING CIRCUITS THAT REMAIN TO THE NEW DISTRIBUTION BOARD WITH NEW AS3000 COMPLIANT SWITCHGEAR.			B
MSB		EXISTING MAIN SWITCHBOARD TO BE PROVIDED WITH A NEW SWITCHGEAR AND ADJUSTMENTS TO THE USE OF THE EXISTING SWITCHGEAR AS PER THE NOTES. UPDATE ALL OF THE SWITCHGEAR LABELS WITH NEW SCREW FIXED LABELS AND UPDATE THE SWITCHBOARD LOCATION NOTES.			B