

ELECTRICAL DESIGN GROUP

ELECTRICAL BUILDING SERVICES CONSULTANTS

P.O. Box 15, SHERWOOD Q. 4075

Phone: (07) 3278 4375 Fax: (07) 3716 0222

Web Site: www.edg.net.au Email: brisbane@edg.net.au

C2864a - DRY DOCK ROAD HOTEL, TWEED HEADS SOUTH

C2864a-0002(A).xls

ELECTRICAL EQUIPMENT SCHEDULE


REVISION A - 31 MAY 2024

THE LIGHT FITTING SUPPLIER CONTACT DETAILS MAY BE AVAILABLE ON THE EDG WEBSITE VIA THE FOLLOWING LINK
www.edg.net.au/Links/Lighting.htm

| TYPE | LAMPS | DESCRIPTION | COLOUR / ACCESSORY | CATALOGUE No | REV |
|------|--------------------|--|------------------------|---|-----|
| L1 | 90W COOL WHITE LED | 9m HIGH POLE C/W ENGINEER CERTIFIED FOOTING AND A CAR PARK LIGHT | BLACK FITTING AND POLE | SUNNY LIGHTING AUSTRALIA SHP305 90CW BK A45 | A |
| L2 | 90W COOL WHITE LED | 7.8m HIGH POLE C/W A CAR PARK LIGHT MOUNTED ON A ENGINEER CERTIFIED 1200 HIGH 600 DIA REINFORCED CONCRETE BOLLARD / FOOTING. | BLACK FITTING AND POLE | SUNNY LIGHTING AUSTRALIA SHP305 90CW BK A45 | A |
| L3 | 36W LED 4000K | SURFACE MOUNTED IP66 1200 LONG BATTEN C/W INTEGRAL DRIVER AND OCCUPANCY SENSOR | LIGHT GREY | GAMMA STORM 1558-CCT-36+SENSOR | A |
| L4 | 36W LED 4000K | SURFACE MOUNTED IP66 1200 LONG BATTEN C/W INTEGRAL DRIVER | LIGHT GREY | GAMMA STORM 1558-CCT-36 | A |
| L5 | 36W LED 4000K | SURFACE MOUNTED IP66 1200 LONG BATTEN C/W INTEGRAL DRIVER AND AN UNSWITCHED AS2293 NON MAINTAINED EMERGENCY PACK CONFIGURED TO ONLY OPERATE UPON MAINS FAILURE | LIGHT GREY | GAMMA STORM 1558-CCT-36 | A |
| L6 | 100W 4000K LED | HIGH BAY C/W INTEGRAL DRIVER CHAIN SUSPENDED | BLACK | GAMMA ILLUMINATION ORBIT 2 881538 | A |
| L7 | 34W 4000K LED | 600 x 600 LAY IN FLAT PLATE LED FITTING C/W REMOTE DRIVER MOUNTED IN THE CEILING T BAR | WHITE TRIM | GAMMA ILLUMINATION AXIS 1549-4K-34W | A |
| L8 | 3000K LED | AMENITY RECESSED DOWNLIGHT C/W REMOTE DRIVER | WHITE | GAMMA ILLUMINATION MYLO 1004-3K-13W | A |
| L9 | 100W 4000K LED | HIGH BAY C/W INTEGRAL DRIVER BRACKET MOUNTED | BLACK | GAMMA ILLUMINATION ORBIT 2 881538 | A |
| L10 | 45W 4000K LED | WALL MOUNTED IP65 DOWN LIGHT C/E INTEGRAL DRIVER | BLACK | GAMMA ILLUMINATION MOLO 1537-4K-45W | A |
| L11 | 13W 4000K LED | RECESSED DOWNLIGHT C/W REMOTE DRIVER | WHITE TRIM | GAMMA ILLUMINATION COBALT 1402-4K-13W | A |
| L12 | 22W 4000K LED | RECESSED DOWNLIGHT C/W REMOTE DRIVER | WHITE TRIM | GAMMA ILLUMINATION COBALT 1441-4K-22W | A |

C2864a-0002(A).xls

Pages inc. any attach. 1 of 10



ELECTRICAL DESIGN GROUP


ELECTRICAL BUILDING SERVICES CONSULTANTS

P.O. Box 15, SHERWOOD Q. 4075

Phone: (07) 3278 4375 Fax: (07) 3716 0222

Web Site: www.edg.net.au Email: brisbane@edg.net.au

| C2864a - DRY DOCK ROAD HOTEL, TWEED HEADS SOUTH | | | | | | C2864a-0002(A).xls |
|---|--------------------|---|---------------------|---|-----|--------------------|
| ELECTRICAL EQUIPMENT SCHEDULE | | | | | | |
| REVISION A - 31 MAY 2024 | | | | | | |
| THE LIGHT FITTING SUPPLIER CONTACT DETAILS MAY BE AVAILABLE ON THE EDG WEBSITE VIA THE FOLLOWING LINK www.edg.net.au/Links/Lighting.htm | | | | | | |
| TYPE | LAMPS | DESCRIPTION | COLOUR / ACCESSORY | CATALOGUE No | REV | |
| L13 | 34W 4000K LED | 1200 x 300 LAY IN FLAT PLATE LED FITTING C/W REMOTE DRIVER MOUNTED IN A FLUSH RECESSED PB MOUNTING KIT | WHITE TRIM | GAMMA ILLUMINATION AXIS 1549-4K-34W C/W FLUSH RECESS PB KIT | A | |
| L14 | 26W 4000K | 600 x 600 LAY IN FLAT PLATE LED FITTING C/W REMOTE DRIVER MOUNTED IN A FLUSH RECESSED PB MOUNTING KIT | WHITE TRIM | GAMMA ILLUMINATION AXIS 1548-4K-26W C/W FLUSH RECESS PB KIT | A | |
| L15 | 100W 3000K LED | 1200 DIA DECORATIVE PENDANT C/W INTEGRAL LED CHIP SET AND REMOTE DALI DIMMABLE DRIVER. PROVIDE THE FITTING WITH A HANG SURE SUSPENSION KIT | BLACK | ALLOW A PC SUM OF \$4000.00 FOR EACH L15 FITTING | A | |
| L16 | 100W 3000K LED | 800 DIA DECORATIVE PENDANT C/W INTEGRAL LED CHIP SET AND REMOTE DALI DIMMABLE DRIVER. PROVIDE THE FITTING WITH A HANG SURE SUSPENSION KIT | BLACK | ALLOW A PC SUM OF \$3500.00 FOR EACH L16 FITTING | A | |
| L17 | 22W 4000K LED | RECESSED DOWNLIGHT C/W REMOTE DRIVER | WHITE TRIM | GAMMA ILLUMINATION COBALT 1441-4K-22W | A | |
| L18 | 22W 4000K LED | RECESSED DOWNLIGHT C/W REMOTE DRIVER | BLACK | GAMMA ILLUMINATION COBALT 1441-4K-22W | A | |
| L19 | 40W 3000K LED | DECORATIVE PENDANT C/W INTEGRAL LED CHIP SET AND REMOTE DALI DIMMABLE DRIVER. PROVIDE THE FITTING WITH A HANG SURE SUSPENSION KIT | COPPER | ALLOW A PC SUM OF \$1000.00 FOR EACH L19 FITTING | A | |
| L20 | 3000K LED | AMENITY RECESSED DOWNLIGHT C/W REMOTE DALI DIMMABLE DRIVER | WHITE | GAMMA ILLUMINATION MYLO 1004-3K-13W | A | |
| L21 | 3W 3000K LED | RECESSED DOWNLIGHT C/W REMOTE DALI DIMMABLE DRIVER IT IS ACCEPTABLE TO SUPPLY MULTIPLE FITTINGS FROM A SUITABLE SIZED SINGLE DRIVER | SILVER | GAMMA ILLUMINATION 1108 | A | |
| L22 | 0.5w 2200K ES LAMP | SUSPENDED 24V AV FESTOON LAMP SYSTEM C/W REMOTE TRANSFORMERS AS REQUIRED 500MM LAMP SPACING PROVIDE A STAINLESS STEEL WIRE SUPPORT SYSTEM | BLACK CABLE & BASES | FIRE FLY FFC-LS-20-24VE27-BK | A | |
| L23 | 3000K 5W LED | GARDEN SPIKE LIGHT. IP65. PROVIDE THE L23 FITTINGS WITH A COMMON DALI DIMMABLE POWER SUPPLY LOCATED IN A CONCEALED ACCESSIBLE POSITION. | BLACK | GAMMA ILLUMINATION 885102 | A | |
| L24 | 3.9W 3000K LED | FLUSH RECESSED WALL LIGHT CENTRED 300 AFFL. PROVIDE THE L24 FITTINGS WITH A COMMON DALI DIMMABLE POWER SUPPLY IN A CONCEALED ACCESSIBLE POSITION. | BLACK | GAMMA ILLUMINATION DUEX 4130-3K-24V | A | |



ELECTRICAL DESIGN GROUP


ELECTRICAL BUILDING SERVICES CONSULTANTS

P.O. Box 15, SHERWOOD Q. 4075

Phone: (07) 3278 4375 Fax: (07) 3716 0222

Web Site: www.edg.net.au Email: brisbane@edg.net.au

| C2864a - DRY DOCK ROAD HOTEL, TWEED HEADS SOUTH | | | | | C2864a-0002(A).xls |
|---|-----------------|--|----------------------------|--|--------------------|
| ELECTRICAL EQUIPMENT SCHEDULE | | | | | |
| REVISION A - 31 MAY 2024 | | | | | |
| THE LIGHT FITTING SUPPLIER CONTACT DETAILS MAY BE AVAILABLE ON THE EDG WEBSITE VIA THE FOLLOWING LINK www.edg.net.au/Links/Lighting.htm | | | | | |
| TYPE | LAMPS | DESCRIPTION | COLOUR / ACCESSORY | CATALOGUE No | REV |
| L25 | 50W 3000K LED | 600 DIA DECORATIVE SURFACE MOUNT BUNKER C/W INTEGRAL LED CHIP SET AND REMOTE DALI DIMMABLE DRIVER. | BLACK | ALLOW A PC SUM OF \$2500.00 FOR EACH L25 FITTING | A |
| BOTTLE SHOP CABLE TRAY | | PROVIDE A BLACK PERFORATED CABLE TRAY SYSTEM SIZED AS PER THE DRAWING. PROVIDE SECURITY AND COMMUNICATIONS CABLING CHANNELS AS PER THE CABLE TRAY SECTIONS. MOUNT THE TRACK, EMERGENCY LIGHTING AND COMMUNICATIONS OUTLETS ON THE UNDERSIDE OF THE CABLE TRAY. ALL COMPONENTS FIXED TO THE CABLE TRAY ARE TO BE BLACK. | | | A |
| BOTTLE SHOP CABLE TRAY TRACK LIGHTING | | 3 CHANNEL TRACK MOUNTED ON THE UNDERSIDE OF THE CABLE TRAY CIRCUIT EACH CHANNEL AS PER THE DRAWING PROVIDE A FITTING FOR EACH 750MM OF TRACK. DISTRIBUTE THE FITTINGS EVENLY ACROSS THE THREE CHANNELS CONFIRM THE FITTING POSITIONS AND AIMING ON SITE WITH THE ARCHITECT | BLACK TRACK BLACK FITTINGS | GAMMA ILLUMINATION 25 SERIES TRACK 1115-VWFL-3K-14W FITTINGS | A |
| S1 | 12W/M 3000K LED | FLEXIBLE LED ROPE FLEX SCREW FIXED IN PLACE ABOVE THE BAR / DINING ROOM WALL PELMET AS PER THE ARCHITECTURAL DETAIL PROVIDE A REMOTE 240-24V POWER SUPPLY AND A DALI DIMMABLE INTERFACE UNIT | WHITE | NPA L-NF-GLOW-WW + POWER SUPPLY & DALI CONTROLLER | A |
| S2 | 12W/M 3000K LED | FLEXIBLE LED ROPE FLEX SCREW FIXED IN PLACE ABOVE THE GAMING ROOM CEILING PELMET AS PER THE ARCHITECTURAL DETAIL PROVIDE A REMOTE 240-24V POWER SUPPLY AND A DALI DIMMABLE INTERFACE UNIT | WHITE | NPA L-NF-GLOW-WW + POWER SUPPLY & DALI CONTROLLER | A |
| S3 | 12W/M 3000K LED | FLEXIBLE LED ROPE FLEX SCREW FIXED IN PLACE ABOVE THE TAB ROOM CEILING PELMET AS PER THE ARCHITECTURAL DETAIL PROVIDE A REMOTE 240-24V POWER SUPPLY AND A DALI DIMMABLE INTERFACE UNIT | WHITE | NPA L-NF-GLOW-WW + POWER SUPPLY & DALI CONTROLLER | A |
| S4 | 12W/M 3000K LED | FLEXIBLE LED ROPE FLEX SCREW FIXED IN PLACE ABOVE THE ENTRY CEILING PELMET AS PER THE ARCHITECTURAL DETAIL PROVIDE A REMOTE 240-24V POWER SUPPLY AND A DALI DIMMABLE INTERFACE UNIT | WHITE | NPA L-NF-GLOW-WW + POWER SUPPLY & DALI CONTROLLER | A |
| S5 | 12W/M 3000K LED | FLEXIBLE LED ROPE FLEX SCREW FIXED IN PLACE WITHIN THE ENTRY PORTAL AS PER THE ARCHITECTURAL DETAIL THE S5 IS TO RISE VERTICALLY FROM THE GROUND TO THE HEAD OF THE PORTAL ACROSS THE PORTAL THEN DOWN TO THE GROUND. PROVIDE A REMOTE 240-24V POWER SUPPLY AND A DALI DIMMABLE INTERFACE UNIT | WHITE | NPA L-NF-GLOW-WW + POWER SUPPLY & DALI CONTROLLER | A |



ELECTRICAL DESIGN GROUP


ELECTRICAL BUILDING SERVICES CONSULTANTS

P.O. Box 15, SHERWOOD Q. 4075

Phone: (07) 3278 4375 Fax: (07) 3716 0222

Web Site: www.edg.net.au Email: brisbane@edg.net.au

| C2864a - DRY DOCK ROAD HOTEL, TWEED HEADS SOUTH | | C2864a-0002(A).xls | | | |
|---|--|---|--------------------|---|-----|
| ELECTRICAL EQUIPMENT SCHEDULE | | | | | |
| REVISION A - 31 MAY 2024 | | | | | |
| THE LIGHT FITTING SUPPLIER CONTACT DETAILS MAY BE AVAILABLE ON THE EDG WEBSITE VIA THE FOLLOWING LINK www.edg.net.au/Links/Lighting.htm | | | | | |
| TYPE | LAMPS | DESCRIPTION | COLOUR / ACCESSORY | CATALOGUE No | REV |
| S6 | 12W/M 3000K LED | FLEXIBLE LED ROPE FLEX SCREW FIXED IN PLACE WITHIN THE GAMING PORTAL AS PER THE ARCHITECTURAL DETAIL THE S5 IS TO RISE VERTICALLY FROM THE GROUND TO THE HEAD OF THE PORTAL ACROSS THE PORTAL THEN DOWN TO THE GROUND. PROVIDE A REMOTE 240-24V POWER SUPPLY AND A DALI DIMMABLE INTERFACE UNIT | WHITE | NPA L-NF-GLOW-WW + POWER SUPPLY & DALI CONTROLLER | A |
| S7 | 12W/M 3000K LED | FLEXIBLE LED ROPE FLEX SCREW FIXED IN PLACE UNDER THE SEAT AS PER THE ARCHITECTURAL DETAIL PROVIDE A REMOTE 240-24V POWER SUPPLY AND A DALI DIMMABLE INTERFACE UNIT | WHITE | NPA L-NF-GLOW-WW + POWER SUPPLY & DALI CONTROLLER | A |
| S8 | 12W/M 3000K LED | FLEXIBLE LED ROPE FLEX SCREW FIXED IN PLACE UNDER THE BAR COUNTER PELMET AS PER THE ARCHITECTURAL DETAIL PROVIDE A REMOTE 240-24V POWER SUPPLY AND A DALI DIMMABLE INTERFACE UNIT | WHITE | NPA L-NF-GLOW-WW + POWER SUPPLY & DALI CONTROLLER | A |
| S9 | 12W/M 3000K LED | FLEXIBLE LED ROPE FLEX SCREW FIXED IN PLACE UNDER THE EXTERNAL SEAT / STAIR AS PER THE ARCHITECTURAL DETAIL PROVIDE A REMOTE 240-24V POWER SUPPLY AND A DALI DIMMABLE INTERFACE UNIT | WHITE | NPA L-NF-GLOW-WW + POWER SUPPLY & DALI CONTROLLER | A |
| S10 | A SINGLE HORIZONTAL RUN OF LED STRIP LIGHT 4000K WHITE LEDS AT 12MM SPACING WITH REMOTE CONTROL GEAR. MOUNT THE LED STRIP UNDER THE OVERHEAD CUPBOARDS HARD AGAINST THE SPLASHBACK AS PER THE ARCHITECTURAL JOINERY DETAILS THE SUPPLIER IS TO CUT / JOIN THE LED STRIPS TO SUIT THE SITE DIMENSIONS. DO NOT CUT THE LED STRIPS ON SITE SCREW FIX THE ALUMINIUM SUPPORT IN PLACE. SUPPLY / SWITCH THE S10 WITH EH ASSOCIATED ROOMS CEILING LIGHTING. | | | NEON PRODUCTS AUSTRALIA LF-DFB-NW-300-12 + PR-LIN172153-F | A |
| E1 | LED | EMERGENCY LIGHT: RECESSED NON-MAINTAINED EMERGENCY LIGHT. AS2293 CLASSIFICATION C0-D63 - C90-D63. | WHITE | CLEVERTRONICS CLIFE-PRO | A |
| E2 | LED | EMERGENCY LIGHT: SURFACE MOUNTED ON THE UNDERSIDE OF THE TABLE TRAY SYSTEM NON-MAINTAINED EMERGENCY LIGHT. AS2293 CLASSIFICATION C0-D63 - C90-D63. | BLACK | CLEVERTRONICS CLIFE-PRO- SM-BLK | A |
| E3 | LED | MAINTAINED 24M VIEWING DISTANCE EXIT LIGHT C/W DIFFUSERS & DIRECTIONAL ARROWS AS SHOWN. MOUNT ON THE UNDERSIDE OF THE CABLE TRAY SYSTEM. AS2293 CLASSIFICATION C0-D1.25- C90-D2 | BLACK | CLEVERTRONICS LUB PRO SM | A |
| E4 | LED | EMERGENCY LIGHT: SURFACE MOUNTED NON-MAINTAINED EMERGENCY LIGHT. AS2293 CLASSIFICATION C0-D63 - C90-D63. | BLACK | CLEVERTRONICS CLIFE-PRO- SM-BLK | A |
| E5 | LED | EMERGENCY LIGHT: RECESSED NON-MAINTAINED EMERGENCY LIGHT. AS2293 CLASSIFICATION C0-D63 - C90-D63. | BLACK | CLEVERTRONICS CLIFE-PRO- BLK | A |



ELECTRICAL DESIGN GROUP


ELECTRICAL BUILDING SERVICES CONSULTANTS

P.O. Box 15, SHERWOOD Q. 4075

Phone: (07) 3278 4375 Fax: (07) 3716 0222

Web Site: www.edg.net.au Email: brisbane@edg.net.au

| C2864a - DRY DOCK ROAD HOTEL, TWEED HEADS SOUTH | | C2864a-0002(A).xls | | | |
|---|-------|--|--------------------|--|-----|
| ELECTRICAL EQUIPMENT SCHEDULE | | | | | |
| REVISION A - 31 MAY 2024 | | | | | |
| THE LIGHT FITTING SUPPLIER CONTACT DETAILS MAY BE AVAILABLE ON THE EDG WEBSITE VIA THE FOLLOWING LINK www.edg.net.au/Links/Lighting.htm | | | | | |
| TYPE | LAMPS | DESCRIPTION | COLOUR / ACCESSORY | CATALOGUE No | REV |
| E6 | LED | WHITE EXIT LIGHT: MAINTAINED 24M VIEWING DISTANCE EXIT LIGHT C/W DIFFUSERS & DIRECTIONAL ARROWS AS SHOWN. CEILING OR WALL MOUNT BETWEEN 2100mm & 2700mm AFFL IF THERE IS NO VERTICAL SURFACE TO MOUNT THE FITTING ON WITHIN THIS RANGE CONFIRM THE MOUNTING HEIGHT WITH THE ENGINEER. AS2293 CLASSIFICATION C0-D1.25- C90-D2 | WHITE | CLEVERTRONICS LUB PRO SM | A |
| EX | LED | BLACK EXIT LIGHT: MAINTAINED 24M VIEWING DISTANCE EXIT LIGHT C/W DIFFUSERS & DIRECTIONAL ARROWS AS SHOWN. CEILING SURFACE MOUNT OR WALL MOUNT BETWEEN 2100mm & 2700mm AFFL IF THERE IS NO VERTICAL SURFACE TO MOUNT THE FITTING ON WITHIN THIS RANGE CONFIRM THE MOUNTING HEIGHT WITH THE ENGINEER. | BLACK | CLEVERTRONICS LUB PRO SM | A |
| EMERGENCY PACK | | LIGHT FITTINGS THAT ARE DESIGNATED AS BEING PROVIDED WITH AN EMERGENCY PACK ARE TO BE PROVIDED WITH AN INTEGRAL AS2293 EMERGENCY PACK. THE FITTINGS ARE TO BE NON MAINTAINED WITH ALL LAMPS SWITCHED AS PER THE LIGHTING CONTROL FOR THAT SPACE UNLESS NOTED OTHERWISE. REFER TO THE SPECIFICATION FOR FURTHER DETAILS OF THE CONFIGURATION AND SWITCHING OF EMERGENCY LIGHTS. | | | A |
| PROXIMITY DETECTOR SWITCH (PD) | | ADJUSTABLE FLUSH RECESSED 360 DEGREE TRIPLE PYRO PIR PRESENCE DETECTOR TO OPERATE THE ASSOCIATED LIGHTS FOR A PRE-SET AMOUNT OF TIME. ADJUST THE TIME AND SENSITIVITY ON SITE AS DIRECTED BY THE ENGINEER. | WHITE | CLIPSAL. SELECTION BY THE CONTRACTOR. SUBMIT DETAILS OF THE PROXIMITY DETECTOR SWITCH FOR APPROVAL PRIOR TO ORDERING | A |
| CEILING FAN 1 (F1) | | 2400 DIA CEILING FAN C/W CUSTOM 250 X 250 TIMBER MOUNTING BLOCK TO ALLOW THE FAN TO BE MOUNTED HORIZONTALLY. CONFIRM THE SUSPENSION HEIGHT OF THE FANS WITH THE ARCHITECT ON SITE. | BLACK | BIG ASS I61-08 | A |
| CEILING FAN 2 (F2) | | 1500 DIA CEILING FAN C/W CUSTOM 250 X 250 TIMBER MOUNTING BLOCK TO ALLOW THE FAN TO BE MOUNTED HORIZONTALLY. CONFIRM THE SUSPENSION HEIGHT OF THE FANS WITH THE ARCHITECT ON SITE. | BLACK | 1500 DIA CALIBO ALULA | A |
| ONE-WAY LIGHT SWITCH | | ONE-WAY LIGHT SWITCH C/W CIRCUIT IDENTIFICATION ON THE FACEPLATE BEHIND THE SURROUND MOUNTED AT 1000mm AFFL UNLESS NOTED OTHERWISE. | WHITE | CLIPSAL C2000 SERIES 30USM | A |
| TWO-WAY LIGHT SWITCH | | TWO -WAY LIGHT SWITCH C/W CIRCUIT IDENTIFICATION ON THE FACEPLATE BEHIND THE SURROUND MOUNTED AT 1000mm AFFL UNLESS NOTED OTHERWISE. | WHITE | CLIPSAL C2000 SERIES 30USM | A |
| LIGHTING CONTROL SWITCH PANEL (SPx) | | 6-BUTTON PROGRAMMABLE SWITCH PANEL C/W CENTRAL LCD DISPLAY MOUNTED AT 1000mm AFFL UNLESS NOTED OTHERWISE. | ALUMINIUM | DYNALITE ANTUMBRA DISPLAY | A |



ELECTRICAL DESIGN GROUP


ELECTRICAL BUILDING SERVICES CONSULTANTS

P.O. Box 15, SHERWOOD Q. 4075

Phone: (07) 3278 4375 Fax: (07) 3716 0222

Web Site: www.edg.net.au Email: brisbane@edg.net.au

| C2864a - DRY DOCK ROAD HOTEL, TWEED HEADS SOUTH | | C2864a-0002(A).xls | | | |
|---|-------|---|----------------------------------|-------------------------------------|-----|
| ELECTRICAL EQUIPMENT SCHEDULE | | | | | |
| REVISION A - 31 MAY 2024 | | | | | |
| THE LIGHT FITTING SUPPLIER CONTACT DETAILS MAY BE AVAILABLE ON THE EDG WEBSITE VIA THE FOLLOWING LINK www.edg.net.au/Links/Lighting.htm | | | | | |
| TYPE | LAMPS | DESCRIPTION | COLOUR / ACCESSORY | CATALOGUE No | REV |
| BOTTLE SHOP LIGHTING CONTROL SWITCH PANEL (SPB) | | MULTI GANG SWITCH PANEL AS PER THE SP-B DETAIL MOUNTED AT 1000mm AFFL UNLESS NOTED OTHERWISE. | STAINLESS STEEL | CLIPSAL B SERIES | A |
| HAND DRYER CONNECTION (HD) | | SINGLE POWER OUTLET C/W CIRCUIT IDENTIFICATION ON THE FACEPLATE BEHIND THE SURROUND FOR THE HAND DRYER MOUNT THE GPO AS PER THE ARCHITECTURAL DETAIL | WHITE UNLESS NOTED AS BLACK (BK) | CLIPSAL C2000 SERIES | A |
| SINGLE POWER OUTLET | | SINGLE POWER OUTLET C/W CIRCUIT IDENTIFICATION ON THE FACEPLATE BEHIND THE SURROUND MOUNT AT 300mm AFFL U.N.O. RATING 10A U.N.O. | WHITE UNLESS NOTED AS BLACK (BK) | CLIPSAL C2000 SERIES | A |
| SINGLE POWER OUTLET AUTO DOOR (AD) | | SINGLE POWER OUTLET C/W CIRCUIT IDENTIFICATION ON THE FACEPLATE BEHIND THE SURROUND MOUNT THE OUTLETS WITH IN THE AUTO DOOR MULLION SUCH THAT THE FLEX IS NOT VISIBLE | WHITE | CLIPSAL C2000 SERIES | A |
| SINGLE POWER OUTLET SUSPENDED (SUS) | | SINGLE 10A POWER OUTLET SUSPENDED TO 1600 AFFL UNLESS NOTED OTHERWISE VIA A 3MM STAINLESS STEEL WIRE ROPE. | WHITE | CLIPSAL "56 SERIES" 56SPO310-RW | A |
| SINGLE 15A POWER OUTLET SUSPENDED (SUS) | | SINGLE 15A POWER OUTLET SUSPENDED TO 1600 AFFL UNLESS NOTED OTHERWISE VIA A 3MM STAINLESS STEEL WIRE ROPE. | WHITE | CLIPSAL "56 SERIES" 56SPO315 | A |
| DOUBLE POWER OUTLET | | DOUBLE POWER OUTLET C/W CIRCUIT IDENTIFICATION ON THE FACEPLATE BEHIND THE SURROUND MOUNT AT 300mm AFFL U.N.O. RATING 10A U.N.O. | WHITE UNLESS NOTED AS BLACK (BK) | CLIPSAL C2000 SERIES | A |
| IP56 SINGLE POWER OUTLET | | SINGLE POWER OUTLET IP56 MOUNT AT 300mm AFFL U.N.O. RATING 10A U.N.O. | GREY | CLIPSAL 56 SERIES | A |
| DOUBLE POWER OUTLET (USB) | | DOUBLE POWER OUTLET C/W USB CHARGER AND CIRCUIT IDENTIFICATION ON THE FACEPLATE BEHIND THE SURROUND MOUNT ABOVE BENCH U.N.O. RATING 10A U.N.O. | WHITE UNLESS NOTED AS BLACK (BK) | CLIPSAL C2000 SERIES + 30USBCM MECH | A |
| IP56 DOUBLE POWER OUTLET | | DOUBLE POWER OUTLET IP56 MOUNT AT 300mm AFFL U.N.O. RATING 10A U.N.O. | GREY | CLIPSAL 56 SERIES | A |
| WEATHERPROOF POWER OUTLET (WP) | | IP54 WEATHERPROOF SINGLE / DOUBLE POWER OUTLET AS NOTED ON DRAWING C/W COVER FLAP OVER SOCKET. MOUNT AT MINIMUM 1100mm AFFL U.N.O. RATING 10A U.N.O. | GREY | CLIPSAL WSC227/1-RG | A |
| 15A WEATHERPROOF POWER OUTLET (WP 15A) | | IP54 WEATHERPROOF 20A SINGLE POWER OUTLET. MOUNT AT MINIMUM 1100mm AFFL U.N.O. RATING 20A U.N.O. | GREY | CLIPSAL WSC227/1/15-RG | A |



ELECTRICAL DESIGN GROUP


ELECTRICAL BUILDING SERVICES CONSULTANTS

P.O. Box 15, SHERWOOD Q. 4075

Phone: (07) 3278 4375 Fax: (07) 3716 0222

Web Site: www.edg.net.au Email: brisbane@edg.net.au

| C2864a - DRY DOCK ROAD HOTEL, TWEED HEADS SOUTH | | C2864a-0002(A).xls | | | |
|---|-------|---|--------------------|-------------------|-----|
| ELECTRICAL EQUIPMENT SCHEDULE | | | | | |
| REVISION A - 31 MAY 2024 | | | | | |
| THE LIGHT FITTING SUPPLIER CONTACT DETAILS MAY BE AVAILABLE ON THE EDG WEBSITE VIA THE FOLLOWING LINK www.edg.net.au/Links/Lighting.htm | | | | | |
| TYPE | LAMPS | DESCRIPTION | COLOUR / ACCESSORY | CATALOGUE No | REV |
| 20A WEATHERPROOF POWER OUTLET (WP 20A) | | IP66 WEATHERPROOF 20A SINGLE POWER OUTLET. MOUNT AT MINIMUM 1100mm AFFL U.N.O. RATING 20A U.N.O. | GREY | CLIPSAL 56 SERIES | A |
| SPECIAL PURPOSE OUTLET | | SPECIAL PURPOSE OUTLET TYPE AS NOTED. MOUNT AT 1350mm AFFL U.N.O. RATING 20A U.N.O. CONNECT TO EQUIPMENT VIA FLEXIBLE CONDUIT. | | | A |
| SINGLE-PHASE ISOLATOR | | SINGLE-PHASE WEATHERPROOF ISOLATOR. MOUNT AT 1350mm AFFL U.N.O. RATING 20A U.N.O. CONNECT TO EQUIPMENT VIA FLEXIBLE CONDUIT. | - | CLIPSAL WHT20 | A |
| THREE-PHASE ISOLATOR | | THREE-PHASE WEATHERPROOF ISOLATOR. MOUNT AT 1350mm AFFL U.N.O. RATING 20A U.N.O. CONNECT TO EQUIPMENT VIA FLEXIBLE CONDUIT. | - | CLIPSAL WHT35 | A |
| THREE-PHASE ISOLATOR RSD | | THREE-PHASE ISOLATOR. MOUNT AT HIGH LEVEL ADJACENT THE ROLLER SHUTTER DOOR CONTROLLER / MOTOR. COORDINATE THE POSITION ON SITE WITH THE ROLLER SHUTTER DOOR SUPPLIER CONNECT TO EQUIPMENT VIA FLEXIBLE CONDUIT. | - | CLIPSAL WHT35 | A |
| SIGN CONNECTION | | COORDINATE THE LOCATION AND CONNECTION WITH THE SIGN CONTRACTOR ENSURING THE GPO / ISOLATORS ARE PROVIDED WITH APPROPRIATE WEATHER PROTECTION AND ARE CONCEALED FROM VIEW. | | | A |
| DB-1 | | DISTRIBUTION BOARD DB-1 AS PER THE DB-1 SCHEDULE, POWER SCHEMATICS AND THE SPECIFICATION. PROVIDE A SHOP DRAWING OF DB-1 FOR APPROVAL. | | | A |
| DB-2 | | DISTRIBUTION BOARD DB-2 AS PER THE DB-2 SCHEDULE, POWER SCHEMATICS AND THE SPECIFICATION. PROVIDE A SHOP DRAWING OF DB-2 FOR APPROVAL. | | | A |
| DB-B | | DISTRIBUTION BOARD DB-B AS PER THE DB-B SCHEDULE, POWER SCHEMATICS AND THE SPECIFICATION. PROVIDE A SHOP DRAWING OF DB-B FOR APPROVAL. | | | A |
| MSB | | MAIN SWITCHBOARD AS PER THE POWER SCHEMATIC AND THE SPECIFICATION. PROVIDE A SHOP DRAWING OF THE MAIN SWITCHBOARD FOR APPROVAL. | | | A |
| MSSB-H | | HOTEL MECHANICAL SERVICES SWITCHBOARD PROVIDED BY THE MECHANICAL SUB CONTRACTOR. COORDINATE THE SUBMAIN CONNECTION WITH THE MECHANICAL SUB CONTRACTOR ON SITE. | | | A |
| MSSB-B | | BOTTLE SHOP MECHANICAL SERVICES SWITCHBOARD PROVIDED BY THE MECHANICAL SUB CONTRACTOR. COORDINATE THE SUBMAIN CONNECTION WITH THE MECHANICAL SUB CONTRACTOR ON SITE. | | | A |
| DB-REF | | HOTEL REFRIGERATION SERVICES SWITCHBOARD PROVIDED BY THE REFRIGERATION SUB CONTRACTOR. COORDINATE THE SUBMAIN CONNECTION WITH THE REFRIGERATION SUB CONTRACTOR ON SITE. | | | A |



ELECTRICAL DESIGN GROUP


ELECTRICAL BUILDING SERVICES CONSULTANTS

P.O. Box 15, SHERWOOD Q. 4075

Phone: (07) 3278 4375 Fax: (07) 3716 0222

Web Site: www.edg.net.au Email: brisbane@edg.net.au

| C2864a - DRY DOCK ROAD HOTEL, TWEED HEADS SOUTH | | C2864a-0002(A).xls | | | |
|---|-------|---|--------------------|-------------------------------|-----|
| ELECTRICAL EQUIPMENT SCHEDULE | | | | | |
| REVISION A - 31 MAY 2024 | | | | | |
| THE LIGHT FITTING SUPPLIER CONTACT DETAILS MAY BE AVAILABLE ON THE EDG WEBSITE VIA THE FOLLOWING LINK www.edg.net.au/Links/Lighting.htm | | | | | |
| TYPE | LAMPS | DESCRIPTION | COLOUR / ACCESSORY | CATALOGUE No | REV |
| DB-BR | | BOTTLE SHOP REFRIGERATION SERVICES SWITCHBOARD PROVIDED BY THE MECHANICAL SUB CONTRACTOR. COORDINATE THE SUBMAIN CONNECTION WITH THE MECHANICAL SUB CONTRACTOR ON SITE. | | | A |
| GENERATOR CONNECTION CUBICLE (GCC) | | PROVIDE THE GENERATOR CONNECTION CUBICAL AS A LOCKABLE EXTERNAL GRADE STAINLESS STEEL HOUSING WALL MOUNTED AT LOW LEVEL. PROVIDE THE CUBICAL WITH PRE DRILLED LINKS TO ALLOW TEMPORARY GENERATOR MAIN TO BE CONNECTED. CONNECT THE PERMANENT GENERATOR MAINS TO THE LINKS. PROVIDE THE CUBICAL WITH FACILITY SO THE DOOR CAN BE CLOSED WITH THE TEMPORARY MAINS CONNECTED. SUBMIT A SHOP DRAWING OF THE CUBICAL FOR APPROVAL. | | | A |
| REVENUE METER (M1) | | CODE COMPLIANT RETAIL METER INCLUDING ALL ASSOCIATED COMPONENTS INCLUDING THE METERS AND CTS ETC. | | | A |
| PRIVATE METER (M2) | | PROVIDE A MULTIFUNCTION METER THAT LOGS THE FOLLOWING ACROSS EACH PHASE, DEMANDS , VOLTAGES, POWER FACTORS, AND HARMONICS. | | | A |
| MANUAL TRANSFER SWITCH (MTS) | | MANUAL ELECTRICAL AND MECHANICAL INTERLOCKED LOAD TRANSFER SWITCH. | | | A |
| COMMUNICATIONS RACK (CR-1) | | IT FREE STANDING 42 RU MINIMUM 800 DEEP 800 WIDE COMMUNICATIONS RACK CR-1 PROVIDE A SHOP DRAWING OF THE RACK INCLUDING THE ARRANGEMENT OF EQUIPMENT PROVIDED WITHIN IT AS PART OF THE CONTRACT FOR APPROVAL. PROVIDE THE RACK WITH THE REQUIRED CAT 6 PATCH PANELS, CABLE MANAGEMENT AS PER THE SPECIFICATION. PROVIDE THE RACK WITH CASTERS. REFER TO THE SPECIFICATION FOR ADDITIONAL REQUIREMENTS. | | 4 CABLING SKU 002.001.4280 | A |
| COMMUNICATIONS RACK (CR-2) | | GAMING FREE STANDING 42 RU MINIMUM 600 DEEP 600 WIDE COMMUNICATIONS RACK CR-2 PROVIDE A SHOP DRAWING OF THE RACK INCLUDING THE ARRANGEMENT OF EQUIPMENT PROVIDED WITHIN IT AS PART OF THE CONTRACT FOR APPROVAL. PROVIDE THE RACK WITH THE REQUIRED CAT 6 PATCH PANELS, CABLE MANAGEMENT AS PER THE SPECIFICATION. PROVIDE THE RACK WITH CASTERS. REFER TO THE SPECIFICATION FOR ADDITIONAL REQUIREMENTS. | | 4 CABLING SKU 002.001.4280 | A |
| COMMUNICATIONS RACK (CR-3) | | AV SECURITY FREE STANDING 42 RU MINIMUM 600 DEEP 600 WIDE RACK CR-3 PROVIDE A SHOP DRAWING OF THE RACK. PROVIDE THE RACK WITH CASTERS. REFER TO THE SPECIFICATION FOR ADDITIONAL REQUIREMENTS. | | 4 CABLING SKU 002.001.4280 | A |
| COMMUNICATIONS RACK (CR-4) | | AV SECURITY FREE STANDING 42 RU MINIMUM 600 DEEP 600 WIDE RACK CR-4. PROVIDE A SHOP DRAWING OF THE RACK. PROVIDE THE RACK WITH CASTERS. REFER TO THE SPECIFICATION FOR ADDITIONAL REQUIREMENTS. | | 4 CABLING SKU 002.001.4280 | A |
| COMMUNICATIONS RACK (CR-B) | | BOTTLE SHOP COMMUNICATIONS AV SECURITY WALL MOUNTED HINGED 18 RU MINIMUM 600 DEEP 600 WIDE RACK CR-B PROVIDE A SHOP DRAWING OF THE RACK. REFER TO THE SPECIFICATION FOR ADDITIONAL REQUIREMENTS. | | 4 CABLING SKU 002.001.4280 | A |



ELECTRICAL DESIGN GROUP


ELECTRICAL BUILDING SERVICES CONSULTANTS

P.O. Box 15, SHERWOOD Q. 4075

Phone: (07) 3278 4375 Fax: (07) 3716 0222

Web Site: www.edg.net.au Email: brisbane@edg.net.au

| C2864a - DRY DOCK ROAD HOTEL, TWEED HEADS SOUTH | | C2864a-0002(A).xls | | | |
|---|-------|--|----------------------------------|----------------------|-----|
| ELECTRICAL EQUIPMENT SCHEDULE | | | | | |
| REVISION A - 31 MAY 2024 | | | | | |
| THE LIGHT FITTING SUPPLIER CONTACT DETAILS MAY BE AVAILABLE ON THE EDG WEBSITE VIA THE FOLLOWING LINK www.edg.net.au/Links/Lighting.htm | | | | | |
| TYPE | LAMPS | DESCRIPTION | COLOUR / ACCESSORY | CATALOGUE No | REV |
| COMMUNICATIONS OUTLET | | RJ45 CAT-6 COMMUNICATIONS OUTLET, CABLED BACK TO CAT 6 PATCH PANELS IN RACK CR-1 VIA 4-PAIR CAT-6 UTP CABLE. MOUNT UP TO 3 RJ45 OUTLETS PER MULTI-GANG FACEPLATE WITH SEPARATE PERMANENT LABELLING FOR EACH OUTLET. MOUNT AT 300 AFFL UNLESS NOTED OTHERWISE | WHITE UNLESS NOTED AS BLACK (BK) | CLIPSAL C2000 SERIES | A |
| CAT 6 GAMING OUTLET | | RJ45 CAT-6 COMMUNICATIONS OUTLET, CABLED BACK TO CAT 6 DEDICATED GAMING PATCH PANELS IN RACK CR-2 VIA 4-PAIR CAT-6 UTP CABLE. MOUNT UP TO 3 RJ45 OUTLETS PER MULTI-GANG FACEPLATE WITH SEPARATE PERMANENT LABELLING FOR EACH OUTLET. MOUNT AT 300 AFFL UNLESS NOTED OTHERWISE | WHITE UNLESS NOTED AS BLACK (BK) | CLIPSAL C2000 SERIES | A |
| GAMING FIBRE (GF) | | INSTALL DUPLEX FIBRE OPTIC CABLE BETWEEN THE POKER MACHINE BASES AND FROM THE POKER MACHINE BASES BACK TO RACK CR-2 AS INDICATED. THE DUPLEX FIBRE OPTIC CABLE WILL BE SUPPLIED AND TERMINATED BY OTHERS. | | | A |
| NBN PREMISE CONNECTION DEVICE (PCD) | | NBN COMPLIANT PREMISES CONNECTION DEVICE TO BE CONNECTED TO THE NTD VIA AN NBN COMPLIANT DROP CONDUIT. CONNECT THE PCD TO THE TELSTRA PIT VIA AN NBN COMPLIANT LEAD-IN CONDUIT. | | | A |
| NBN NETWORK TERMINATION UNIT (NTD) | | NBN COMPLIANT NETWORK TERMINATION UNIT TO BE PROVIDED IN ACCORDANCE WITH THE NBN REQUIREMENTS | | | A |
| (A1) CABLE ACCESS POINT | | PROVIDE THE A1 AS A CONCEALED CONDUIT ACCESS POINT WITHIN THE JOINERY. PROVIDE 2 X 50 DIA INSITU CONDUITS BETWEEN THE A1 POINTS AND THE RISER AS SHOWN ON THE DRAWING.. | | | A |
| (A2) CABLE ACCESS POINT | | FLUSH RECESSED 50DIA CONDUIT DRAW IN BOX FOR THE RFID CABLING. PROVIDE A 25 DIA INSITU CONDUIT FROM THE A2 BOX TO THE ASSOCIATED A1 / A2 BOX / RISER AS SHOWN ON THE DRAWING. | | | A |
| RISER | | PROVIDE THE RISER AS A BLACK 2 CHANNEL 150 X 75 PER CHANNEL ALUMINIUM DUCT WITH A SCREW FIXED REMOVABLE LID WALL MOUNTED FROM THE FLOOR TO THE CEILING SPACE ABOVE. PROVIDE DETAILS OF THE PROPOSED RISER FOR APPROVAL | | | A |
| PIT P1 | | PROVIDE A REINFORCED MASONRY INSITU PIT / TRENCH BELOW MSB FOR THE FULL LENGTH OF THE MSB AS PER THE MSB SECTION DETAIL. PROVIDE AS PART OF THE ELECTRICAL WORKS THE SWITCHBOARD AND LID SUPPORT SYSTEM AND THE TRENCH LIDS. PROVIDE THE TRENCH LIDS AND STRUCTURAL SUPPORT SYSTEM AS HOT DIPPED GALVANISED STEEL. PROVIDE THE TRENCH LIDS WITH LIFTING HOLES CHECKER PLATE R10 ANTI SLIP PATTERNING WITH EACH PART NO HEAVIER THAN 20 kg. FIX THE LIDS IN PLACE SUCH THAT A TOOL IS REQUIRED TO REMOVE THEM. PROVIDE THE TRENCH WITH AN AUTOMATIC SUMP PUMP TO DRAIN TO THE STORMWATER SYSTEM. PROVIDE CABLE SUPPORTS WITHIN THE TRENCH TO ENSURE THAT THERE ARE NO CABLES WITHIN 50MM OF THE TRENCH FLOOR. | | | A |
| PIT P2 | | 900 X 900 CLEAR INTERNAL X 1000 DEEP INSITU POWER PIT C/W A REINFORCED CONCRETE SURROUND AND A CLASS C STEEL LID WITH A SLIP RESISTANCE OF R10 SUBMIT DETAILS OF THE PIT, LID AND AN INSTALLATION SECTION FOR APPROVAL. | | | A |
| PIT P3 | | 900 X 900 CLEAR INTERNAL X 1000 DEEP INSITU POWER PIT C/W A REINFORCED CONCRETE SURROUND AND A CLASS C STEEL LID WITH A SLIP RESISTANCE OF R10 SUBMIT DETAILS OF THE PIT, LID AND AN INSTALLATION SECTION FOR APPROVAL. | | | A |



ELECTRICAL DESIGN GROUP

ELECTRICAL BUILDING SERVICES CONSULTANTS

P.O. Box 15, SHERWOOD Q. 4075

Phone: (07) 3278 4375 Fax: (07) 3716 0222

Web Site: www.edg.net.au Email: brisbane@edg.net.au

| C2864a - DRY DOCK ROAD HOTEL, TWEED HEADS SOUTH | | C2864a-0002(A).xls | | | |
|---|-------|--|--------------------|--------------|-----|
| ELECTRICAL EQUIPMENT SCHEDULE | | | | | |
| REVISION A - 31 MAY 2024 | | | | | |
| THE LIGHT FITTING SUPPLIER CONTACT DETAILS MAY BE AVAILABLE ON THE EDG WEBSITE VIA THE FOLLOWING LINK www.edg.net.au/Links/Lighting.htm | | | | | |
| TYPE | LAMPS | DESCRIPTION | COLOUR / ACCESSORY | CATALOGUE No | REV |
| PIT P4 | | 600 X 600 CLEAR INTERNAL X 700 DEEP INSITU POWER PIT C/W A REINFORCED CONCRETE SURROUND AND A CLASS C STEEL LID WITH A SLIP RESISTANCE OF R10 SUBMIT DETAILS OF THE PIT, LID AND AN INSTALLATION SECTION FOR APPROVAL. | | | A |
| PIT C1 | | 600 X 600 CLEAR INTERNAL X 700 DEEP PLASTIC POWER PIT C/W A REINFORCED CONCRETE SURROUND AND A CLASS C STEEL LID WITH A SLIP RESISTANCE OF R10 SUBMIT DETAILS OF THE PIT, LID AND AN INSTALLATION SECTION FOR APPROVAL. | | | A |
| PIT C2 | | 450 X 450 CLEAR INTERNAL X 700 DEEP PLASTIC COMMUNICATIONS PIT C/W A REINFORCED CONCRETE SURROUND AND A CLASS C INFILL LID SUBMIT DETAILS OF THE PIT, LID AND AN INSTALLATION SECTION FOR APPROVAL. | | | A |
| TELSTRA / NBN PIT | | EXISTING TELSTRA PIT CONFIRM THE POSITION ON SITE | | | A |
| GALVANIZED OUTLET SUPPORT BOLLARD | | CUSTOM MADE FULLY WELDED HOT DIPPED GALVANIZED STEEL BOLLARD C/W MOUNTING PLATE BOLTED TO A REINFORCED CONCRETE FOOTING. SIZE THE BOLLARD TO ACCOMMODATE THE NOMINATED OUTLETS WITH THE CABLE ACCESS TO THE OUTLETS RISING UP THROUGH THE BOLLARD. PROVIDE A SHOP DRAWING OF THE BOLLARD INCLUDING THE OUTLETS FOR APPROVAL. CONFIRM THE POSITION OF THE BOLLARD ON SITE WITH THE ARCHITECT. | | | A |