



ELECTRICAL DESIGN GROUP

ELECTRICAL BUILDING SERVICES CONSULTANTS

P.O. Box 15, SHERWOOD Q. 4075

Phone: (07) 3278 4375

Website: www.edg.net.au Email: brisbane@edg.net.au

C3179a - SUNNYBANK COMMUNITY SPORTS CLUB

C3179a-0010(A).xls

DISTRIBUTION BOARD DB-G-4 (KITCHEN)

REVISION A - 31 JULY 2024

							REV
PROVIDE DB-G4 WITH THE FOLLOWING SWITCHGEAR TO ACCOMMODATE THE NEW CIRCUITS. REMOVE ALL EXISTING CABLING AND SWITCHGEAR MADE REDUNDANT BY THE WORKS. UPDATE THE SWITCHBOARD SCHEDULE INCLUDING ADDRESSING ALL EXISTING CIRCUITS WITH THE CIRCUIT USE AND POSITION .							A
CIRC	PH	CIRCUIT BREAKER (amps)	CONTROL EQUIPMENT	CABLE SIZE (mm ²)	LOCATION	CIRCUIT USE	
P1	1	20	RCBO	2.5	AMENITY	GPOs	A
P2	1	20	RCBO	2.5	FUNCTION	GPOs	A
P3	1	20	RCBO	2.5	FUNCTION	GPOs	A
P4	1	20	RCBO	2.5	SERVERY	SERVERY HEATERS	A
P5	1	20	RCBO	2.5	SERVERY	SERVERY HEATERS	A
L1	1	20	RCBO	2.5	FUNCTION	LIGHTS	A
L2	1	20	RCBO	2.5	FUNCTION	LIGHTS	A
L3	1	20	RCBO	2.5	FUNCTION	LIGHTS	A
L4	1	20	RCBO	2.5	BAR	LIGHTS	A