



ELECTRICAL DESIGN GROUP

ELECTRICAL BUILDING SERVICES CONSULTANTS

P.O. Box 15, SHERWOOD Q. 4075

Phone: (07) 3278 4375

Website: www.edg.net.au Email: brisbane@edg.net.au

C3179a - SUNNYBANK COMMUNITY SPORTS CLUB

C3179a-0011(A).xls

DISTRIBUTION BOARD DB-G5 (AV ROOM)

REVISION A - 31 JULY 2024

							REV
PROVIDE DB-G5 WITH THE FOLLOWING SWITCHGEAR TO ACCOMMODATE THE NEW CIRCUITS. REMOVE ALL EXISTING CABLING AND SWITCHGEAR MADE REDUNDANT BY THE WORKS. UPDATE THE SWITCHBOARD SCHEDULE INCLUDEING ADDRESSING ALL EXISTING CIRCUITS WITH THE CIRCUIT USE AND POSITION .							A
CIRC	PH	CIRCUIT BREAKER (amps)	CONTROL EQUIPMENT	CABLE SIZE (mm ²)	LOCATION	CIRCUIT USE	
P1	1	20	RCBO	2.5	AMENITY	LIFT	A
P2	1	20	RCBO	2.5	FUNCTION	GPOs	A
L1	1	20	RCBO	2.5	BISTRO ENTRY	LIGHTS	A
L2	1	20	RCBO	2.5	BISTRO ENTRY	SIGN	A