



ELECTRICAL DESIGN GROUP

ELECTRICAL BUILDING SERVICES CONSULTANTS

P.O. Box 15, SHERWOOD Q. 4075

Phone: (07) 3278 4375

Website: www.edg.net.au Email: brisbane@edg.net.au

C3234a - 185 SAMFORD ROAD, ENOGGERA

C3234a-0009(1).xls

DISTRIBUTION BOARD DB-E (INTEGRAL TO THE MSB)

REVISION 1 - 09 MAY 2025

							REV
FAULT CURRENT: 6KA USING CASCADING							A
MAIN SWITCH: 100A NON AUTO LOAD BREAK							A
CHASSIS SIZE: 60 POLES							A
SUPPLIED FROM: MSB							A
CHASSIS RATING: 250A							A
SUPPLY CABLE: 4C25							A
PHASES: 3							A
PROVIDE THE DB WITH TWO FULL WIDTH EMPTY DIN RAIL TO ACCOMMODATE FUTURE CONTACTORS AND CONTROLS.							A
CIRC	PH	CIRCUIT BREAKER (amps)	CONTROL EQUIPMENT	CABLE SIZE (mm ²)	LOCATION	CIRCUIT USE	
P1							A
P2							A
P3							A
P4							A
P5							A