



THE FOLLOWING CIRCUITS ARE EXISTING TO BE MODIFIED / EXTENDED AS NECESSARY TO  
SUPPLY THE NOMINATED OUTLETS:

DB-1 - P3  
DB-2 - L7  
DB-2 - L15  
db-4 - 16  
DB-4 - P8  
DB-4 - P9

PROVIDE THE FOLLOWING NEW CIRCUITS AS 20 AMP RCBO PROTECTED 2.5MM SINGLE PHASE TO  
SUPPLY THE NOMINATED OUTLETS:

DB-4 - L22  
DB-4 - L24

THE FOLLOWING PHILIPS DYNALITE CHANNELS ARE EXISTING TO BE MODIFIED / EXTENDED AS NECESSARY TO CONTROL THE NOMINATED SERVICES:

CHANNEL 131 - SWITCHED.

UTILISE THE FOLLOWING EXISTING SPARE PHILIPS DYNALITE CHANNELS TO CONTROL THE NOMINATED SERVICES:

CHANNEL 123 - DALI.  
CHANNEL 236 - DALI.

PROVIDE THE FOLLOWING NEW PHILIPS DYNALITE CHANNELS TO CONTROL THE NOMINATED SERVICES:

CHANNEL 247 - SWITCHED.  
CHANNEL 248 - SWITCHED.  
CHANNEL 249 - SWITCHED.  
CHANNEL 250 - SWITCHED.  
CHANNEL 251 - SWITCHED.

B	TENDER	19/07/2024
REV:	DESCRIPTION:	DATE:
DRAWING:		
<b>ELECTRICAL SERVICES</b> <b>GROUND LEVEL FLOOR PLAN</b>		
SCALE: 1:100	PROJECT NO: <b>C3269a</b>	DRAWING NO: <b>E04</b>
AT A1	REVISION: <b>B</b>	