



ELECTRICAL DESIGN GROUP

ELECTRICAL BUILDING SERVICES CONSULTANTS

P.O. Box 15, SHERWOOD Q. 4075

Phone: (07) 3278 4375 Fax: (07) 3716 0222

Web Site: www.edg.net.au Email: brisbane@edg.net.au

C3284a - EAGERS MT GRAVATT - MITSUBISHI & KIA

C3284a-0005(C).xls

DISTRIBUTION BOARD DB-2

REVISION C - 18 NOVEMBER 2024

							REV
MODIFY THE EXISTING DISTRIBUTION BOARD TO ACCOMMODATE THE FOLLOWING CIRCUITS. REMOVE ALL SWITCHGEAR THAT BECOMES REDUNDANT AND UPDATE THE SCHEDULE AT PRACTICAL COMPLETION. IT IS ACCEPTABLE TO UTILISE EXISTING CIRCUITS IF THEY ARE IN APPROPRIATE CONDITION AND HAVE SUFFICIENT SPARE CAPACITY							A
CIRC	PH	CIRCUIT BREAKER (amps)	CONTROL EQUIPMENT	CABLE SIZE (mm2)	LOCATION	CIRCUIT USE	
P1	1	20	RCBO	2.5	KIA	FLOOR BOXES	A
P2	1	20	RCBO	2.5	KIA	FLOOR BOXES	A
P3	1	20	RCBO	2.5	KIA	AUTO DOOR	A
P4	1	20	RCBO	2.5	KIA	CLEANING	A
P5	1	20	RCBO	2.5	KIA	CLEANING	A
P6	1	20	RCBO	2.5	KIA	TV	A
P7	1	20	RCBO	2.5	KIA	OFFICES	A
P8	1	20	RCBO	2.5	KIA	OFFICES	A
P9	1	20	RCBO	2.5	KIA	FLOOR BOXES	B
P10	1	20	RCBO	2.5	KIA	KITCHENETTE	A
P11	1	20	RCBO	2.5	KIA	APPLIANCES	A
P12	1	20	RCBO	2.5	KIA	AUTO BOILER	A
P13	1	20	RCBO	2.5	KIA	DISPLAY	B
L1	1	20	RCBO PE ON DUSK OFF DAWN	2.5	EXTERNAL	SIGNS	A
L2	1	20	RCBO	2.5	KIA	LIGHTS	A
L3	1	20	RCBO	2.5	KIA	LIGHTS	A
L4	1	20	RCBO	2.5	KIA	LIGHTS	A
L5	1	20	RCBO	2.5	KIA	LIGHTS	A
L6	1	20	RCBO	2.5	KIA	LIGHTS	A
L7	1	20	RCBO	2.5	KIA	LIGHTS	A
L8	1	20	RCBO	2.5	KIA	LIGHTS	A
L9	1	20	RCBO	2.5	KIA	LIGHTS	A
L10	1	20	RCBO PE ON DUSK OFF DAWN	4.0	EXTERNAL	POLE LIGHTS	C