



# ELECTRICAL DESIGN GROUP

ELECTRICAL BUILDING SERVICES CONSULTANTS

P.O. Box 15, SHERWOOD Q. 4075

Phone: (07) 3278 4375 Fax: (07) 3716 0222

Web Site: www.edg.net.au Email: brisbane@edg.net.au

C3284a - EAGERS MT GRAVATT - MITSUBISHI & KIA

C3284a-0006(C).xls

DISTRIBUTION BOARD DB-3

REVISION C - 16 OCTOBER 2024

							REV
MODIFY THE EXISTING BASEMENT DISTRIBUTION BOARD TO ACCOMMODATE THE FOLLOWING CIRCUITS. REMOVE ALL SWITCHGEAR THAT BECOMES REDUNDANT AND UPDATE THE SCHEDULE AT PRACTICAL COMPLETION. IT IS ACCEPTABLE TO UTILISE EXISTING CIRCUITS IF THEY ARE IN APPROPRIATE CONDITION AND HAVE SUFFICIENT SPARE CAPACITY							A
CIRC	PH	CIRCUIT BREAKER (amps)	CONTROL EQUIPMENT	CABLE SIZE ( mm2 )	LOCATION	CIRCUIT USE	
P1	1	20	RCBO	2.5	SERVICE	PRINTER	A
P2	1	20	RCBO	2.5	SERVICE	REF	A
P3	1	20	RCBO	2.5	SERVICE	CLEANING	A
P4	1	20	RCBO	2.5	SERVICE	TV	A
P5	1	20	RCBO	2.5	SERVICE	FLOOR BOXES	A
P6	1	20	RCBO	2.5	SERVICE	BRAND DISPLAY	A
P7	1	20	RCBO	2.5	SERVICE	WORK SPACE	A
P8	1	20	RCBO	2.5	SERVICE	KITCHENETTE	A
P9	1	20	RCBO	2.5	SERVICE	AUTO BOILER	A
P10	1	20	RCBO	2.5	SERVICE	HOT DESK	B
L1	1	20	RCBO PE CELL ON DUSK TC OFF 10.00 PM	2.5	EXTERNAL	SIGNS	A
L2	1	20	RCBO PE CELL ON DUSK TC OFF 10.00 PM	2.5	EXTERNAL	SIGNS	C