



ELECTRICAL DESIGN GROUP

ELECTRICAL BUILDING SERVICES CONSULTANTS

P.O. Box 15, SHERWOOD Q. 4075

Phone: (07) 3278 4375 Fax: (07) 3716 0222

Web Site: www.edg.net.au Email: brisbane@edg.net.au

C3316a - MOTORAMA - HILLCREST NISSAN

C3316a-0002(C).xls

ELECTRICAL EQUIPMENT SCHEDULE

REVISION C - 06 AUGUST 2025

THE EQUIPMENT SUPPLIER CONTACT DETAILS MAY BE AVAILABLE ON THE EDG WEBSITE VIA THE FOLLOWING LINK
www.edg.net.au/links.html

TYPE	LAMPS	DESCRIPTION	COLOUR / ACCESSORY	CATALOGUE No	REV
L1	NO LONGER REQUIRED				C
L2	45W 3000K LED	RECESSED DOWNLIGHT C/W REMOTE DRIVER	WHITE	EQUAL TO GAMMA ILLUMINATION MERCURY 1288-3K-45W	A
L3	34W 4000K LED	REPLACE THE EXISTING TBAR TROFFER WITH A NEW 600 X 600 T BAR LED FLAT PANEL TROFFER.	WHITE	EQUAL TO GAMMA ILLUMINATION AXIS G3 1548- 4K-34W	A
L4	22W LED 3000K	NEW CUSTOMER LOUNGE RECESSED LED DOWNLIGHT.	WHITE	EQUAL TO GAMMA ILLUMINATION COBALT 1402-3K-22W	A
L5	13W 4000K LED	NEW CORRIDOR RECESSED LED DOWNLIGHT TO MATCH THE D1 FITTING.	WHITE	EQUAL TO GAMMA ILLUMINATION MYLO 1004-FL-4K-13W	A
L6	24W 4000K LED	NEW DELIVERY STORE RECESSED LED DOWNLIGHT.	WHITE	EQUAL TO SAL LIGHTING RENMARK S9083R35TC/DP - 24/35W	A
L7	NO LONGER REQUIRED				C
L8	28W LED 3000K	NEW MITSUBISHI SALES RECESSED LED DOWNLIGHT TO MATCH THE D2 FITTING.	WHITE	EQUAL TO GAMMA ILLUMINATION COBALT 1403-3K-28W	A
L9	NO LONGER REQUIRED				C
L10	PROVIDE A POWER SUPPLY IN A CONCEALED ACCESSIBLE POSITION FOR THE FEATURE MITSUBISHI RED LED STRIPS COORDINATE THE POSITION ON SITE WITH EH SIGNAGE SUPPLIER				A
L11	36W 3000K LED	REPLACE THE EXISTING RECESSED DOWNLIGHT WITH A NEW FITTING C/W REMOTE DRIVER	WHITE	EQUAL TO GAMMA ILLUMINATION COBALT 1717-3K-36W	C
L12	36W 3000K LED	NEW RECESSED DOWNLIGHT C/W REMOTE DRIVER	WHITE	EQUAL TO GAMMA ILLUMINATION COBALT 1717-3K-36W	C
F1	34W 4000K LED	REPLACE THE EXISTING FLUORESCENT PB RECESSED TROFFER WITH AN LED FLAT PLATE TROFFER	WHITE TRIM	EQUAL TO GAMMA ILLUMINATION AXIS 1549-4K-34W C/W FLUSH RECESS PB KIT	A



ELECTRICAL DESIGN GROUP

ELECTRICAL BUILDING SERVICES CONSULTANTS

P.O. Box 15, SHERWOOD Q. 4075

Phone: (07) 3278 4375 Fax: (07) 3716 0222

Web Site: www.edg.net.au Email: brisbane@edg.net.au

C3316a - MOTORAMA - HILLCREST NISSAN

C3316a-0002(C).xls

ELECTRICAL EQUIPMENT SCHEDULE

REVISION C - 06 AUGUST 2025

THE EQUIPMENT SUPPLIER CONTACT DETAILS MAY BE AVAILABLE ON THE EDG WEBSITE VIA THE FOLLOWING LINK
www.edg.net.au/links.html

TYPE	LAMPS	DESCRIPTION	COLOUR / ACCESSORY	CATALOGUE No	REV
F2	34W 4000K LED	REPLACE THE EXISTING FLUORESCENT T BAR RECESSED TROFFER WITH AN LED FLAT PLATE TROFFER	WHITE TRIM	EQUAL TO GAMMA ILLUMINATION AXIS 1549-4K-34W	A
F4	36W LED 4000K	REPLACE THE EXISTING FLUORESCENT SURFACE BATTEN C/W NON MAINTAINED AS2293 PACK WITH AN LED BATTEN C/W NON MAINTAINED AS2293 PACK.	LIGHT GREY	EQUAL TO GAMMA ILLUMINATION STORM 1558-CCT- 36W	A
F5	36W LED 4000K	REPLACE THE EXISTING WALL MOUNTED FLUORESCENT BATTEN WITH AN LED BATTEN.	LIGHT GREY	EQUAL TO GAMMA ILLUMINATION STORM 1558-CCT- 36W	A
D1	13W 4000K LED	REPLACE THE EXISTING AMENITY / CIRCULATION FLUORESCENT RECESSED DOWNLIGHT WITH AN LED RECESSED DOWNLIGHT.	WHITE	EQUAL TO GAMM ILLUMINATION MYLO 1004-FL-4K-13W	A
D2	28W LED 3000K	REPLACE THE EXISTING SALES FLUORESCENT RECESSED DOWNLIGHT WITH AN LED RECESSED DOWNLIGHT.	WHITE	EQUAL TO GAMMA ILLUMINATION COBALT 1403-3K-28W	A
D5	24W 4000K LED	REPLACE THE EXISTING EXTERNAL SOFFIT FLUORESCENT RECESSED DOWNLIGHT WITH AN LED RECESSED DOWNLIGHT.	WHITE	EQUAL TO SAL LIGHTING RENMARK S9083R35TC/DP - 24/35W	A
D6	45W 3000K LED	REPLACE THE EXISTING DRIVE THROUGH FLUORESCENT RECESSED DOWNLIGHT WITH AN LED RECESSED DOWNLIGHT.	WHITE	EQUAL TO GAMMA ILLUMINATION MERCURY 1288-3K- 45W	A
W2	36W 4000K LED	REPLACE THE EXISTING EXTERNAL WALL LIGHT WITH AN LED WALL LIGHT.	SILVER	EQUAL TO WE EF OLV340S	A
E1	LED	EMERGENCY LIGHT: RECESSED NON-MAINTAINED EMERGENCY LIGHT. AS2293 CLASSIFICATION C0-D40 - C90-D40.	WHITE	CLEVERTRONICS CLIFE	A
E2	LED	EMERGENCY LIGHT: RECESSED NON-MAINTAINED EMERGENCY LIGHT. AS2293 CLASSIFICATION C0-D40 - C90-D40.	WHITE	CLEVERTRONICS CLIFE	A



ELECTRICAL DESIGN GROUP

ELECTRICAL BUILDING SERVICES CONSULTANTS

P.O. Box 15, SHERWOOD Q. 4075

Phone: (07) 3278 4375 Fax: (07) 3716 0222

Web Site: www.edg.net.au Email: brisbane@edg.net.au

C3316a - MOTORAMA - HILLCREST NISSAN

C3316a-0002(C).xls

ELECTRICAL EQUIPMENT SCHEDULE

REVISION C - 06 AUGUST 2025

THE EQUIPMENT SUPPLIER CONTACT DETAILS MAY BE AVAILABLE ON THE EDG WEBSITE VIA THE FOLLOWING LINK
www.edg.net.au/links.html

TYPE	LAMPS	DESCRIPTION	COLOUR / ACCESSORY	CATALOGUE No	REV
EX	LED	EXIT LIGHT: MAINTAINED 24M VIEWING DISTANCE EXIT LIGHT C/W DIFFUSERS & DIRECTIONAL ARROWS AS SHOWN AND A IP56 HOUSING CEILING OR WALL MOUNT BETWEEN 2100mm & 2700mm AFFL IF THERE IS NO VERTICAL SURFACE TO MOUNT THE FITTING ON WITHIN THIS RANGE CONFIRM THE MOUNTING HEIGHT WITH THE ENGINEER. AS2293 CLASSIFICATION C0-D3.2 - C90-E2.	WHITE LOGO GREEN BACKGROUND WHITE BODY	CLEVERTRONICS LUB PRO SM	A
ONE-WAY LIGHT SWITCH		ONE-WAY LIGHT SWITCH C/W CIRCUIT IDENTIFICATION ON THE FACEPLATE BEHIND THE SURROUND MOUNTED AT 1000mm AFFL UNLESS NOTED OTHERWISE.	WHITE	CLIPSAL C2000 SERIES FACEPLATE	A
LIGHTING CONTROL SWITCH PANEL (SP1)		WALL MOUNTED MULTI GANG SWITCH PANEL MOUNTED AT 1000mm AFFL UNLESS NOTED OTHERWISE.	WHITE	CLIPSAL C2000 SERIES	A
LIGHTING CONTROL SWITCH PANEL (SP2)		WALL MOUNTED MULTI GANG SWITCH PANEL MOUNTED AT 1000mm AFFL UNLESS NOTED OTHERWISE.	WHITE	CLIPSAL C2000 SERIES	A
SINGLE POWER OUTLET		SINGLE POWER OUTLET C/W CIRCUIT IDENTIFICATION ON THE FACEPLATE BEHIND THE SURROUND MOUNT AT 300 AFFL U.N.O.	WHITE	CLIPSAL C2000 SERIES	A
DOUBLE POWER OUTLET		DOUBLE POWER OUTLET C/W CIRCUIT IDENTIFICATION ON THE FACEPLATE BEHIND THE SURROUND MOUNT AT 300 AFFL U.N.O.	WHITE	CLIPSAL C2000 SERIES	A
CAT 6 COMMUNICATIONS OUTLET		RJ45 CAT-6 COMMUNICATIONS OUTLET, CABLED BACK TO THE COMMUNICATIONS RACK CR-K TERMINATED ONTO FACILITY PATCH PANELS VIA 4-PAIR CAT-6 UTP CABLE. MOUNT UP TO 3 RJ45 OUTLETS PER MULTI-GANG FACEPLATE WITH SEPARATE PERMANENT LABELLING FOR EACH OUTLET. MOUNT AT 300 AFFL U.N.O.	WHITE	CLIPSAL C2000 SERIES KRONE JACK C/W SHUTTER	A
DB-K		UPGRADE THE EXISTING DISTRIBUTION BOARD DB-K AS NECESSARY TO ACCOMMODATE THE CIRCUIT MODIFICATIONS AND ADDITIONS REFER TO THE NOTES AND DISTRIBUTION BOARD DB-K SCHEDULE FOR ADDITIONAL INFORMATION AND REQUIREMENTS. REMOVE ALL EXISTING CIRCUITS AND CABLING MADE REDUNDANT BY THE WORKS.			A
FLOOR BOX (FB1)		EXISTING FLOOR BOX TO REMAIN AS IS			A
FLOOR BOX (FB2)		INSITU FLUSH FLOOR BOX C/W A DOUBLE GPOS+ 2 COMMUNICATIONS OUTLETS ON THE SAME FACEPLATE. PROVIDE A 32 DIA CONDUIT C/W A SPARE DRAW WIRE FROM THE REAR OF THE COMMUNICATIONS FACEPLATE TO THE CEILING SPACE ABOVE THE COMMUNICATIONS RACK CR-A. PROVIDE THE GPOS AND COMMUNICATIONS OUTLETS AS PER THE STANDARD DESCRIPTIONS.	STAINLESS STEEL	ECD FB2SHD	A

C3316a-0002(C).xls

Pages inc. any attach. 3 of 4



ELECTRICAL DESIGN GROUP

ELECTRICAL BUILDING SERVICES CONSULTANTS

P.O. Box 15, SHERWOOD Q. 4075

Phone: (07) 3278 4375 Fax: (07) 3716 0222

Web Site: www.edg.net.au Email: brisbane@edg.net.au

C3316a - MOTORAMA - HILLCREST NISSAN

C3316a-0002(C).xls

ELECTRICAL EQUIPMENT SCHEDULE

REVISION C - 06 AUGUST 2025

THE EQUIPMENT SUPPLIER CONTACT DETAILS MAY BE AVAILABLE ON THE EDG WEBSITE VIA THE FOLLOWING LINK
www.edg.net.au/links.html

TYPE	LAMPS	DESCRIPTION	COLOUR / ACCESSORY	CATALOGUE No	REV
SIGN CONNECTION		COORDINATE THE LOCATION AND CONNECTION WITH THE SIGN CONTRACTOR ENSURING THE GPO / ISOLATORS ARE PROVIDED WITH APPROPRIATE WEATHER PROTECTION AND ARE CONCEALED FROM VIEW.			A
COMMUNICATIONS RACK CR-K		EXISTING COMMUNICATIONS RACK TO BE UPGRADED AS NECESSARY AND PROVIDED WITH ADDITIONAL PATCH PANELS TO ACCOMMODATE THE ADDITIONAL COMMUNICATIONS OUTLETS. REMOVE ALL REDUNDANT CABLING AND UPDATE THE PORT NUMBERING.			A
MOTION SENSOR (MS)		EXISTING LIGHTNG MOTION SENSOR SWITCH TO REMAIN AS IS.			B