



ELECTRICAL DESIGN GROUP

ELECTRICAL BUILDING SERVICES CONSULTANTS

P.O. Box 15, SHERWOOD Q. 4075

Phone: (07) 3278 4375

Website: www.edg.net.au Email: brisbane@edg.net.au

C3358a - BRACKEN RIDGE TAVERN

C3358a-0006(C).xls

DISTRIBUTION BOARD DB-B (GROUND SOUTH)

REVISION C - 13 MAY 2025

							REV	
FAULT CURRENT:		6KA USING CASCADING			MAIN SWITCH:		250A NON AUTO LOAD BREAK MSB 4C70	A
CHASSIS SIZE:		2 X 60 POLES			SUPPLIED FROM:			A
CHASSIS RATING:		250A			SUPPLY CABLE:			A
PHASES:		3						A
PROVIDE THE DB WITH A FULL WIDTH EMPTY DIN RAIL TO ACCOMMODATE FUTURE CONTACTORS AND CONTROLS IN ADDITION TO THE INITIAL PHILIPS DYNALITE CONTROLS .								A
CIRC	PH	CIRCUIT BREAKER (amps)	CONTROL EQUIPMENT	CABLE SIZE (mm ²)	LOCATION	CIRCUIT USE		
P1	1	20	RCBO	2.5		CLEANING	B	
P2	1	20	RCBO	2.5		STAGE	B	
P3	1	20	RCBO	2.5		STAGE	B	
P4	1	20	RCBO	2.5		STAGE	B	
P5	1	20	RCBO	2.5		CLEANING	B	
P6	1	20	RCBO	2.5		TV	B	
P7	1	20	RCBO	2.5		AUTO DOOR	B	
P8	1	20	RCBO	2.5		MEET & GREET	B	
P9	1	20	RCBO	2.5		CLEANING	B	
P10	1	20	RCBO	2.5		KENO	B	
P11	1	20	RCBO	2.5		TV	B	
P12	1	20	RCBO	2.5		WAIT STATION	B	
P13	1	20	RCBO	2.5		STAGE	B	
P14	1	20	RCBO	2.5		STAGE	B	
P15	1	20	RCBO	2.5		STAGE	B	
P16	1	20	RCBO	2.5	BAR	PANINI PRESS	B	
P17	1	20	RCBO	2.5	BAR	PANINI PRESS	B	
P18	1	20	RCBO	2.5	BAR	GPO	B	
P19	1	20	RCBO	2.5	BAR	DISPLAY	B	
P20	1	20	RCBO	2.5	BAR	REF	B	
P21	1	20	RCBO	2.5	BAR	POS	B	
P22	1	20	RCBO	2.5	BAR	COFFEE	B	
P23	1	20	RCBO	2.5	BAR	TV	B	
P24	1	20	RCBO	2.5	BAR	REF	B	
P25	1	20	RCBO	2.5	BAR	REF	B	
P26	1	20	RCBO	2.5	BAR	REF	B	
P27	1	20	RCBO	2.5	BAR	REF	B	
P28	1	20	RCBO	2.5	BAR	REF	B	
P29	1	20	RCBO	2.5	BAR	POS	B	
P30	1	20	RCBO	2.5	BAR	WASH	B	
P31	1	20	RCBO	2.5	BAR	WASH	B	
P32	1	20	RCBO	2.5	BAR	WASH	B	
P33	1	20	RCBO	2.5	BAR	GPO	B	

C3358a - BRACKEN RIDGE TAVERN

C3358a-0006(C).xls

DISTRIBUTION BOARD DB-B (GROUND SOUTH)

REVISION C - 13 MAY 2025

[illegible]