



ELECTRICAL DESIGN GROUP

ELECTRICAL BUILDING SERVICES CONSULTANTS

P.O. Box 15, SHERWOOD Q. 4075

Phone: (07) 3278 4375 Fax: (07) 3716 0222

Web Site: www.edg.net.au Email: brisbane@edg.net.au

C3413a - EDEN BREWHOUSE, REDBANK PLAINS

C3413a-0002(A).xls

ELECTRICAL EQUIPMENT SCHEDULE

REVISION A - 12 MAY 2025

THE LIGHT FITTING SUPPLIER CONTACT DETAILS MAY BE AVAILABLE ON THE EDG WEBSITE VIA THE FOLLOWING LINK
www.edg.net.au/Links/Lighting.htm

TYPE	LAMPS	DESCRIPTION	COLOUR / ACCESSORY	CATALOGUE No	REV
L1	12W/M 2700K CRI MIN 90+ LED	FLEXIBLE LED ROPE FLEX SCREW FIXED RECESSED BEHIND THE MIRROR AS PER THE ARCHITECTURAL DETAIL. PROVIDE THE L1 STRIP WITH REMOTE DALI DIMMABLE POWER SUPPLIES AS REQUIRED LOCATE THE POWER SUPPLIES IN A CONCEALED ACCESSIBLE POSITION NOTED ON THE AS CONSTRUCTED DOCUMENTS. IT IS ACCEPTABLE TO SUPPLY MULTIPLE L1 RUNS WITHIN THE SAME ROOM FROM A COMMON SUITABLY SIZED POWER SUPPLY.	WHITE	SELECTION BY CONTRACTOR SUBMIT DETAILS FOR APPROVAL	A
L2	12W/M 2700K CRI MIN 90+ LED	FLEXIBLE LED ROPE FLEX SCREW FIXED RECESSED INTO THE PLANTER RECESS AS PER THE ARCHITECTURAL DETAIL. PROVIDE THE L2 STRIP WITH REMOTE DALI DIMMABLE POWER SUPPLIES AS REQUIRED LOCATE THE POWER SUPPLIES IN A CONCEALED ACCESSIBLE POSITION NOTED ON THE AS CONSTRUCTED DOCUMENTS. IT IS ACCEPTABLE TO SUPPLY MULTIPLE L2 RUNS WITHIN THE SAME ROOM FROM A COMMON SUITABLY SIZED POWER SUPPLY.	WHITE	SELECTION BY CONTRACTOR SUBMIT DETAILS FOR APPROVAL	A
L3	3000K LED	AMENITY RECESSED DOWNLIGHT C/W REMOTE DALI DIMMABLE DRIVER	WHITE	EQUAL TO GAMMA ILLUMINATION MYLO 1004-3K-13W	A
L4	EXISTING LIGHT TO BE RETAINED AS IS				A
L5	TRAILING EDGE DIMMABLE 240 VOLT 2700K E27 FILAMENT LED 400 LUMENS +/- 10% 40,000 HOUR LIFE	SURFACE MOUNTED IP55 FITTING	BLACK	LIGHTING COLLECTIVE SKU LCN0100CL-1	A
L6	PROVIDE NEW PENDANT LIGHTS TO MATCH THE EXISTING DINING ROOM PENDANTS				A
L7	20W 3000K LED	REPLACE THE EXISTING WALL MOUNTED BATTEN WITH A NEW IP54 FITTING UTILISING THE EXISTING CIRCUIT AND CONTROLS	BLACK	EQUAL TO GAMMA ILLUMINATION TOMMASO 1775-3K-20W	A
L8	22W 3000K LED	RECESSED DOWNLIGHT C/W REMOTE DRIVER	WHITE TRIM	EQUAL TO GAMMA ILLUMINATION COBALT 1441-3K-22W	A
L9	13W 3000K LED	RECESSED 40DEG DOWNLIGHT C/W REMOTE DALI DIMMABLE DRIVER	WHITE	EQUAL TO GAMMA ILLUMINATION RHO 1001-3K-13W	A



ELECTRICAL DESIGN GROUP

ELECTRICAL BUILDING SERVICES CONSULTANTS

P.O. Box 15, SHERWOOD Q. 4075

Phone: (07) 3278 4375 Fax: (07) 3716 0222

Web Site: www.edg.net.au Email: brisbane@edg.net.au

C3413a - EDEN BREWHOUSE, REDBANK PLAINS

C3413a-0002(A).xls

ELECTRICAL EQUIPMENT SCHEDULE

REVISION A - 12 MAY 2025

THE LIGHT FITTING SUPPLIER CONTACT DETAILS MAY BE AVAILABLE ON THE EDG WEBSITE VIA THE FOLLOWING LINK
www.edg.net.au/Links/Lighting.htm

TYPE	LAMPS	DESCRIPTION	COLOUR / ACCESSORY	CATALOGUE No	REV
PL1	3 X TRAILING EDGE DIMMABLE 240 VOLT 2700K E27 FILAMENT LED 400 LUMENS +/- 10% 40,000 HOUR LIFE	DECORATIVE PENDANT CONFIRM THE SUSPENSION HEIGHT ON SITE WITH THE ARCHITECT	ANTIQUE BLACK	LIGHTING COLLECTIVE EXTRA LARGE WOVEN IRON STRIPES	A
PL2	3 X TRAILING EDGE DIMMABLE 240 VOLT 2700K E27 FILAMENT LED 400 LUMENS +/- 10% 40,000 HOUR LIFE	DECORATIVE PENDANT CONFIRM THE SUSPENSION HEIGHT ON SITE WITH THE ARCHITECT	ANTIQUE BLACK	LIGHTING COLLECTIVE LARGE WOVEN IRON STRIPES	A
E1	LED	EMERGENCY LIGHT: RECESSED NON-MAINTAINED EMERGENCY LIGHT. AS2293 CLASSIFICATION C0-D63 - C90-D63.	WHITE	CLEVERTRONICS CLIFE-PRO	A
E2	LED	EMERGENCY LIGHT: SURFACE MOUNTED ON THE UNDERSIDE OF THE TABLE TRAY SYSTEM NON- MAINTAINED EMERGENCY LIGHT. AS2293 CLASSIFICATION C0-D63 - C90-D63.	BLACK	CLEVERTRONICS CLIFE-PRO- SM-BLK	A
EX	LED	BLACK EXIT LIGHT: MAINTAINED 24M VIEWING DISTANCE EXIT LIGHT C/W DIFFUSERS & DIRECTIONAL ARROWS AS SHOWN. CEILING SURFACE MOUNT OR WALL MOUNT BETWEEN 2100mm & 2700mm AFFL IF THERE IS NO VERTICAL SURFACE TO MOUNT THE FITTING ON WITHIN THIS RANGE CONFIRM THE MOUNTING HEIGHT WITH THE ENGINEER.	BLACK	CLEVERTRONICS LUB PRO SM	A
CEILING FAN 1 (CF1)		NEW CEILING FAN TO MATCH THE EXISTING ADJACENT CF3 OUTDOOR DINING CEILING FANS LOCATE THE CONTROLS WITHIN THE OFFICE ADJACENT THE EXISTING CONTROLS.			A
CEILING FAN 2 (CF2)		750 DIA WALL MOUNTED FAN. CONFIRM THE MOUNTING HIGHT ON SITE WITH THE ARCHITECT.	BLACK	CEILING FANS DIRECT MERCATOR AIRBOND SKU 223329	A
CEILING FAN 3 (CF3)		EXISTING CEILING FAN TO REMAIN AS IS			A
CEILING FAN 4 (CF4)		1780 DIA CEILING FAN C/W RAKED CEILING MOUNT. CONFIRM THE DROP LENGTH WITH THE ARCHITECT	BLACK & KOA	CEILING FANS DIRECT 277491	A
HAND DRYER CONNECTION (HD)		SINGLE POWER OUTLET C/W CIRCUIT IDENTIFICATION ON THE FACEPLATE BEHIND THE SURROUND FOR THE HAND DRYER MOUNT THE GPO AS PER THE ARCHITECTURAL DETAIL	WHITE UNLESS NOTED AS BLACK (BK)	CLIPSAL C2000 SERIES	A
SINGLE POWER OUTLET		SINGLE POWER OUTLET C/W CIRCUIT IDENTIFICATION ON THE FACEPLATE BEHIND THE SURROUND MOUNT AT 300mm AFFL U.N.O. RATING 10A U.N.O.	WHITE UNLESS NOTED AS BLACK (BK)	CLIPSAL C2000 SERIES	A



ELECTRICAL DESIGN GROUP

ELECTRICAL BUILDING SERVICES CONSULTANTS

P.O. Box 15, SHERWOOD Q. 4075

Phone: (07) 3278 4375 Fax: (07) 3716 0222

Web Site: www.edg.net.au Email: brisbane@edg.net.au

C3413a - EDEN BREWHOUSE, REDBANK PLAINS

C3413a-0002(A).xls

ELECTRICAL EQUIPMENT SCHEDULE

REVISION A - 12 MAY 2025

THE LIGHT FITTING SUPPLIER CONTACT DETAILS MAY BE AVAILABLE ON THE EDG WEBSITE VIA THE FOLLOWING LINK
www.edg.net.au/Links/Lighting.htm

TYPE	LAMPS	DESCRIPTION	COLOUR / ACCESSORY	CATALOGUE No	REV
DOUBLE POWER OUTLET		DOUBLE POWER OUTLET C/W CIRCUIT IDENTIFICATION ON THE FACEPLATE BEHIND THE SURROUND MOUNT AT 300mm AFFL U.N.O. RATING 10A U.N.O.	WHITE UNLESS NOTED AS BLACK (BK)	CLIPSAL C2000 SERIES	A
SINGLE-PHASE ISOLATOR		SINGLE-PHASE WEATHERPROOF ISOLATOR. MOUNT AT 1350mm AFFL U.N.O. RATING 20A U.N.O. CONNECT TO EQUIPMENT VIA FLEXIBLE CONDUIT.	-	CLIPSAL WHT20	A
THREE-PHASE ISOLATOR		THREE-PHASE WEATHERPROOF ISOLATOR. MOUNT AT 1350mm AFFL U.N.O. RATING 20A U.N.O. CONNECT TO EQUIPMENT VIA FLEXIBLE CONDUIT.	-	CLIPSAL WHT35	A
DB-K		EXISTING DISTRIBUTION BOARD DB-K TO BE PROVIDED AN ADDITIONAL CIRCUIT AS DETAILED. UPDATE THE SCHEDULE ACCORDINGLY			A
DB-G		EXISTING DISTRIBUTION BOARD DB-G TO BE PROVIDED WITH AN ADDITIONAL CUBICAL AS PER THE NOTES AND DB-G SCHEDULE. THE SWITCHGEAR FOR THE EXISTING DB-G CIRCUITS THAT BECOME REDUNDANT ARE TO BE REMOVED. UPDATE THE SCHEDULE AT PRACTICAL COMPLETION SUCH THAT THE USE AND LOCATION CAN BE SIMPLY IDENTIFIED.			A
MDB		EXISTING mdb TO REMAIN AS IS			A
MSSB		EXISTING MECHANICAL SERVICES SWITCHBOARD TO REMAIN AS IS			A
DIMMERS		EXISTING PHILIPS DYNALITE DIMMERS TO REMAIN AS IS			A
CIRCUIT DB-K - P1		PROVIDE CIRCUIT DB-K - P1 AS A 20 AMP RCBO PROTECTED 2.5MM CIRCUIT SUPPLIED FROM DB-K			A
COMMUNICATIONS RACK (CR-A)		EXISTING SECURITY RACK TO REMAIN AS IS			A
COMMUNICATIONS RACK (CR-B)		EXISTING AV RACK TO REMAIN AS IS			A
COMMUNICATIONS RACK (CR-C)		EXISTING COMMUNICATIONS RACK TO BE UPGRADED WITH NEW PATCH PANELS TO ACCOMMODATE THE ADDITIONAL COMMUNICATIONS OUTS AS REQUIRED.			A
COMMUNICATIONS RACK (CR-E)		EXISTING GAMING RACK TO BE REMOVED. ALL EXISTING SERVICES WITHIN CR-E THAT REMAIN ARE TO BE RELOCATED INTO CR-G			A



ELECTRICAL DESIGN GROUP

ELECTRICAL BUILDING SERVICES CONSULTANTS

P.O. Box 15, SHERWOOD Q. 4075

Phone: (07) 3278 4375 Fax: (07) 3716 0222

Web Site: www.edg.net.au Email: brisbane@edg.net.au

C3413a - EDEN BREWHOUSE, REDBANK PLAINS

C3413a-0002(A).xls

ELECTRICAL EQUIPMENT SCHEDULE

REVISION A - 12 MAY 2025

THE LIGHT FITTING SUPPLIER CONTACT DETAILS MAY BE AVAILABLE ON THE EDG WEBSITE VIA THE FOLLOWING LINK
www.edg.net.au/Links/Lighting.htm

TYPE	LAMPS	DESCRIPTION	COLOUR / ACCESSORY	CATALOGUE No	REV
COMMUNICATIONS RACK (CR-G)		PROVIDE A NEW GAMING COMMUNICATIONS RACK 42RU 600WIDE X 600DEEP C/W CASTERS. PROVIDE ALL NECESSARY FIBERS AND PATCH PANELS TO ACCOMMODATE THE GAMING CABLING THIS INCLUDES SEPARATE E-BET, LINK AND CMS PATCH PANELS. PROVIDE THE RACK WITH FOUR TOP MOUNTED VENTILATION FANS A 10 PORT POWER RAIL AND THREE HALF DEPTH SHELVES. RELOCATE / REPLACE THE EXISTING LEAD-IN AND TIE CABLES TO CR-E TO CR-G.		4 CABLING SKU 002.001.4260	A
COMMUNICATIONS OUTLET		RJ45 CAT-6 COMMUNICATIONS OUTLET, CABLED BACK TO CAT 6 PATCH PANELS IN RACK CR-C VIA 4-PAIR CAT-6 UTP CABLE. MOUNT UP TO 3 RJ45 OUTLETS PER MULTI-GANG FACEPLATE WITH SEPARATE PERMANENT LABELLING FOR EACH OUTLET. MOUNT AT 300 AFFL UNLESS NOTED OTHERWISE	WHITE UNLESS NOTED AS BLACK (BK)	CLIPSAL C2000 SERIES	A
GAMING OUTLETS		PROVIDE EACH BANK OF GAMING MACHINES WITH: <ul style="list-style-type: none">• THREE CAT 6 OUTLETS LABELLED S1, S2, AND S3 CABLED TO A E-BET PATCH PANEL IN CR-G VIA GREEN CAT 6 UTP CABLE.• FOUR CAT 6 OUTLETS LABELLED L1, L2, L3, AND L4 CABLED TO A LINK PATCH PANEL IN CR-G VIA RED CAT 6 UTP CABLE.• A CAT 6 OUTLET LABELLED CMS CABLED TO A CMS PATCH PANEL IN CR-G VIA YELLOW AMP CERTIFIED CAT 6 UTP CABLE. THE GAMING MACHINE BANK OUTLETS MUST NOT PASS THROUGH ANY OTHER GAMING MACHINE BANKS.			A
GAMING FIBRE (GF)		PROVIDE A HPELL PLASTIC 2X DUPLEX FIBRE OPTIC CABLE BETWEEN THE POKER MACHINE BASES AND FROM THE POKER MACHINE BASES BACK TO RACK CR-G AS INDICATED. RUN ALL FIBRE CABLING OUTSIDE OF THE POKER MACHINE BASES IN 25MM DIA CONDUIT. OTHER THAN FIBRE CONNECTING ADJACENT BASES, UNIQUELY IDENTIFY EACH FIBRE DURABLE CABLE AT EACH END. PROVIDE EACH FIBRE CABLE WITH A 4M. TERMINATION WILL BE BY OTHERS.			A
FIRE INDICATOR PANEL (FIP)		EXISTING FIP TO BE UPGRADED AS REQUIRED TO ACCOMMODATE THE DETECTOR AND SPEAKER CHANGES.			A
SMOKE DETECTOR		AS1670.1 SURFACE MOUNTED SMOKE DETECTOR			A
THERMAL DETECTOR		SURFACE MOUNTED THERMAL DETECTOR TO AS1670.1.			A
RECESSED FIRE ALARM SPEAKER		AS1670.1 RECESSED FIRE ALARM SPEAKER C/W WHITE GRILL			A