

ELECTRICAL DESIGN GROUP


ELECTRICAL BUILDING SERVICES CONSULTANTS

P.O. Box 15, SHERWOOD Q. 4075

Phone: (07) 3278 4375 Fax: (07) 3716 0222

Web Site: www.edg.net.au Email: brisbane@edg.net.au

C3457a - THE LION RICHLANDS - STAGE 2					C3457a-0002(C).xls
ELECTRICAL EQUIPMENT SCHEDULE					
REVISION C - 16 SEPTEMBER 2026					
THE LIGHT FITTING SUPPLIER CONTACT DETAILS MAY BE AVAILABLE ON THE EDG WEBSITE VIA THE FOLLOWING LINK www.edg.net.au/Links/Lighting.htm					
TYPE	LAMPS	DESCRIPTION	COLOUR / ACCESSORY	CATALOGUE No	REV
L1	26W 4000K	600 x 600 LAY IN FLAT PLATE LED FITTING C/W REMOTE DRIVER T-BAR MOUNTED	WHITE TRIM	GAMMA ILLUMINATION AXIS 1548-4K-26W C/W FLUSH RECESS PB KIT	A
L2	20W LED 4000K	SURFACE MOUNTED IP66 600 LONG BATTEN C/W INTEGRAL DRIVER AND OCCUPANCY SENSOR	LIGHT GREY	RAPID LED R3520-S-TRI	A
L3	40W LED 4000K	SURFACE MOUNTED IP66 1200 LONG BATTEN C/W INTEGRAL DRIVER AND OCCUPANCY SENSOR	LIGHT GREY	RAPID LED R3540-S-TRI	A
L4	22W 4000K LED	SURFACE MOUNTED BUNKER C/W INTEGRAL DRIVER	WHITE	RAPID LED R6240	A
L5	15W 3000K LED	90 DIA RECESSED DOWNLIGHT C/W 24 DEG BEAM REMOTE DIMMABLE DRIVER	WHITE	RAPID R1078-WH-15W-WW-DALI	A
L6	ALLOW A PC SUM OF \$30,000.00 FOR THE SUPPLY AND INSTALLATION OF THE L6 FITTING. PROVIDE THE L6 FITTING WITH DALI CONTROL.				A
L7	NO LONGR REQUIRED				B
L8	26W 4000K	600 x 600 LAY IN FLAT PLATE LED FITTING C/W REMOTE DALI DIMMABLE DRIVER MOUNTED IN A FLUSH RECESSED PB MOUNTING KIT	WHITE TRIM	GAMMA ILLUMINATION AXIS 1548-4K-26W C/W FLUSH RECESS PB KIT	A
L9	26W 4000K	600 x 600 LAY IN FLAT PLATE LED FITTING C/W REMOTE DRIVER MOUNTED IN A FLUSH RECESSED PB MOUNTING KIT	WHITE TRIM	GAMMA ILLUMINATION AXIS 1548-4K-26W C/W FLUSH RECESS PB KIT	A
L10	2.0W 4000K LED	RECESSED DOWNLIGHTS C/W ASYMMETRICAL REFLECTOR MOUNTED WITHIN THE STAIR HAND REMOTE DALI DIMMABLE DRIVER / POWER SUPPLY	SILVER	KLIK SYSTEMS LEDPOD 50	B
LMP01	3 X 3000K LED	FLOOR LAMP TO BE MECHANICALLY FIXED IN POSITION WITH CONCEALED FIXINGS AND CABLING	BRUSHED GOLD	COCO REPUBLIC ELISE FLOOR LAMP LUP18008-4B	C



ELECTRICAL DESIGN GROUP

ELECTRICAL BUILDING SERVICES CONSULTANTS

P.O. Box 15, SHERWOOD Q. 4075

Phone: (07) 3278 4375 Fax: (07) 3716 0222

Web Site: www.edg.net.au Email: brisbane@edg.net.au

C3457a - THE LION RICHLANDS - STAGE 2


C3457a-0002(C).xls

ELECTRICAL EQUIPMENT SCHEDULE

REVISION C - 16 SEPTEMBER 2026

THE LIGHT FITTING SUPPLIER CONTACT DETAILS MAY BE AVAILABLE ON THE EDG WEBSITE VIA THE FOLLOWING LINK
www.edg.net.au/Links/Lighting.htm

TYPE	LAMPS	DESCRIPTION	COLOUR / ACCESSORY	CATALOGUE No	REV
LP01	50W 4000K LED	9M POLE AND CARPARK LIGHT C/W INTEGRAL DRIVER ALL CONDUITS ARE TO HAVE A SPARE DRAW WIRE AND BE SHOWN ON THE AS CONSTRUCTED DOCUMENTS.	BLACK FITTING BLACK POLE	MELEC ML-ROX-50-4K- BK	A
LP02	50W 4000K LED	7.8m HIGH POLE AND CARPARK LIGHT C/W INTEGRAL DRIVER MOUNTED ON A ENGINEER CERTIFIED 1200 HIGH 600 DIA REINFORCED CONCRETE BOLLARD / FOOTING. ALL CONDUITS ARE TO HAVE A SPARE DRAW WIRE AND BE SHOWN ON THE AS CONSTRUCTED DOCUMENTS.	BLACK FITTING BLACK POLE	MELEC ML-ROX-50-4K- BK	A
LP03	100W 4000K LED	9M POLE AND CARPARK LIGHT C/W INTEGRAL DRIVER ALL CONDUITS ARE TO HAVE A SPARE DRAW WIRE AND BE SHOWN ON THE AS CONSTRUCTED DOCUMENTS.	BLACK FITTING BLACK POLE	MELEC ML-ROX-100- 4K-BK	A
PF01	ALLOW A PC SUM OF \$50,000.00 FOR THE SUPPLY AND INSTALLATION OF THE PF01 FITTING. PROVIDE THE PF01 FITTING WITH DALI CONTROL.				A
PD01	INTEGRAL 16W TRAILING EDGE DIMMABLE 240 VOLT 27000K LED	DECORATIVE 1200 LONG PENDANT TO BE CENTRED OVER THE TABLE AND SUSPENDED WITH THE UNDERSIDE OF THE FITTING 1000 ABOVE THE TABLE TOP	WHITE	LIGHTERIOR STIL.8686 LARGE	C
PD02	105W TRAILING EDGE DIMMABLE 240 VOLT 27000K LED	DECORATIVE PENDANT ALLOW TO INSTALL. ALLOW A PC SUM FOR THE SUPPLY OF EACH FITTING	WHITE	ALLOW A PC SUM OF \$2000.00 FOR THE SUPPLY OF EACH PD02	C
PD03	TRAILING EDGE DIMMABLE 240 VOLT 2200K E14 LED 200 LUMENS +/- 10% 15,000 HOUR LIFE LAMPS AS REQUIRED	DECORATIVE PENDANT CONFIRM THE SUSPENSION HEIGHT ON SITE WITH THE ARCHITECT	OPAL	LUCRETIA LIGHTING SOLVIA 800 LUP96836/800	A
PD04	TRAILING EDGE DIMMABLE 240 VOLT 2200K E27 LED 400 LUMENS +/- 10% 15,000 HOUR LIFE LAMP	DECORATIVE PENDANT CONFIRM THE SUSPENSION HEIGHT ON SITE WITH THE ARCHITECT	WHITE	LIGHTING COLLECTIVE ELEGANT WHITE FIBREGLASS CHANDELIER LCKAR069WL-001	A
PD05	TRAILING EDGE DIMMABLE 240 VOLT 2200K E27 LED 400 LUMENS +/- 10% 15,000 HOUR LIFE LAMP	DECORATIVE PENDANT CONFIRM THE SUSPENSION HEIGHT ON SITE WITH THE ARCHITECT	WHITE	LIGHTING COLLECTIVE ELEGANT WHITE FIBREGLASS CHANDELIER LCKAR069WL-002	A
PD06	TRAILING EDGE DIMMABLE 240 VOLT 2200K G9 LED 200 LUMENS +/- 10% 15,000 HOUR LIFE LAMP	DECORATIVE PENDANT CONFIRM THE SUSPENSION HEIGHT ON SITE WITH THE ARCHITECT	BRASS ONYX	MARZ LIGHTING AURELIA PENDANT	A



ELECTRICAL DESIGN GROUP


ELECTRICAL BUILDING SERVICES CONSULTANTS

P.O. Box 15, SHERWOOD Q. 4075

Phone: (07) 3278 4375 Fax: (07) 3716 0222

Web Site: www.edg.net.au Email: brisbane@edg.net.au

C3457a - THE LION RICHLANDS - STAGE 2					C3457a-0002(C).xls
ELECTRICAL EQUIPMENT SCHEDULE					
REVISION C - 16 SEPTEMBER 2026					
THE LIGHT FITTING SUPPLIER CONTACT DETAILS MAY BE AVAILABLE ON THE EDG WEBSITE VIA THE FOLLOWING LINK www.edg.net.au/Links/Lighting.htm					
TYPE	LAMPS	DESCRIPTION	COLOUR / ACCESSORY	CATALOGUE No	REV
PD07	102W 2700K LED	DECORATIVE PENDANT CONFIRM THE SUSPENSION HEIGHT ON SITE WITH THE ARCHITECT REMOTE DALI DIMMABLE DRIVER	TITANIUM GOLD	LUCRETIA LUP6061A-13A DALI	C
PD08	TRAILING EDGE DIMMABLE 240 VOLT 2200K G4 3W LED LAMP	DECORATIVE PENDANT CONFIRM THE SUSPENSION HEIGHT ON SITE WITH THE ARCHITECT	BRASS	ILANEL PIPI PENDANT 600/300	A
PD09	NO LONGR REQUIRED				B
PD10	NO LONGR REQUIRED				B
PD11	NO LONGR REQUIRED				B
PD12	TRAILING EDGE DIMMABLE 240 VOLT 2200K E27 LED 400 LUMENS +/- 10% 15,000 HOUR LIFE LAMP	DECORATIVE PENDANT CONFIRM THE SUSPENSION HEIGHT ON SITE WITH THE ARCHITECT	WHITE	ABOUT SPACE 300DIA SKYBALL PENDANT	A
PD13	TRAILING EDGE DIMMABLE 240 VOLT 2200K E27 LED 400 LUMENS +/- 10% 15,000 HOUR LIFE LAMP	DECORATIVE PENDANT CONFIRM THE SUSPENSION HEIGHT ON SITE WITH THE ARCHITECT	WHITE	LIGHTING COLLECTIVE NL114PL-2	C
PD14	TRAILING EDGE DIMMABLE 240 VOLT 2200K G9 LED 200 LUMENS +/- 10% 15,000 HOUR LIFE LAMP	DECORATIVE PENDANT CONFIRM THE SUSPENSION HEIGHT ON SITE WITH THE ARCHITECT	BRASS	MARZ LIGHTING ORB PENDANT 200DIA	A
PD15	INTEGRAL 3W TRAILING EDGE DIMMABLE 240 VOLT 2700 LED	DECORATIVE 25MM DIA 450 LONG PENDANT CONFIRM THE SUSPENSION HEIGHT ON SITE WITH THE ARCHITECT	GOLD	LIGHTING COLLECTIVE ARLC101PL-2	C
WL01	TRAILING EDGE DIMMABLE 240 VOLT 3W 2200K G9 LED LAMP	DECORATIVE WALL LIGHT TO BE POSITIONED AS PER THE ARCHITECTURAL ELEVATION	SALTBUSH	LIGHTING COLLECTIVE RG010WL-1	A
WL02	TRAILING EDGE DIMMABLE 240 VOLT 2200K E27 CANDLE LED 400 LUMENS +/- 10% 15,000 HOUR LIFE LAMP	DECORATIVE WALL LIGHT TO BE POSITIONED AS PER THE ARCHITECTURAL ELEVATION	BLACK	LIGHTING COLLECTIVE FNOR729WL-2	A



ELECTRICAL DESIGN GROUP

ELECTRICAL BUILDING SERVICES CONSULTANTS

P.O. Box 15, SHERWOOD Q. 4075

Phone: (07) 3278 4375 Fax: (07) 3716 0222

Web Site: www.edg.net.au Email: brisbane@edg.net.au

C3457a - THE LION RICHLANDS - STAGE 2


C3457a-0002(C).xls

ELECTRICAL EQUIPMENT SCHEDULE

REVISION C - 16 SEPTEMBER 2026

THE LIGHT FITTING SUPPLIER CONTACT DETAILS MAY BE AVAILABLE ON THE EDG WEBSITE VIA THE FOLLOWING LINK
www.edg.net.au/Links/Lighting.htm

TYPE	LAMPS	DESCRIPTION	COLOUR / ACCESSORY	CATALOGUE No	REV
WL03	INTEGRAL 12W 3000K LED	DECORATIVE WALL LIGHT TO BE POSITIONED AS PER THE ARCHITECTURAL ELEVATION REMOTE DALI DIMMABLE DRIVER	NA	LUCRETIA LIGHTING LUWAW-96399-L DALI	A
WL04	2 X TRAILING EDGE DIMMABLE 240 VOLT 2200K G9 LED 200 LUMENS +/- 10% 15,000 HOUR LIFE LAMPS	DECORATIVE WALL LIGHT TO BE POSITIONED AS PER THE ARCHITECTURAL ELEVATION	BRASS	MARZ LIGHTING POLARIS WALL LIGHT MEDIUM	A
WL05	NO LONGR REQUIRED				B
WL06	2.5W TRAILING EDGE DIMMABLE 240 VOLT 2200K G9 LED	DECORATIVE WALL LIGHT TO BE POSITIONED AS PER THE ARCHITECTURAL ELEVATION	BRASS	MARZ LIGHTING AURELIA SURFACE SCONCE CAST GLASS	C
WL07	4W TRAILING EDGE DIMMABLE 240 VOLT 2200K G9 LED	DECORATIVE WALL LIGHT TO BE POSITIONED AS PER THE ARCHITECTURAL ELEVATION	BRASS	MARZ LIGHTING AURELIA WALL LIGHT CAST GLASS	C
WL08	2 X TRAILING EDGE DIMMABLE 240 VOLT 2200K E14 LED 200 LUMENS +/- 10% 15,000 HOUR LIFE LAMP	DECORATIVE WALL LIGHT TO BE POSITIONED AS PER THE ARCHITECTURAL ELEVATION	BRUSHED GOLD	LUCRETIA LIGHTING LUP18008-4B	A
WL09	TRAILING EDGE DIMMABLE 240 VOLT 2200K E27 G45 LED 200 LUMENS +/- 10% 15,000 HOUR LIFE LAMP	DECORATIVE WALL LIGHT TO BE POSITIONED AS PER THE ARCHITECTURAL ELEVATION	BROWN METALLIC	LIGHTING COLLECTIVE RIBBED EXTERIOR ORB 150DIA	A
WL10	TRAILING EDGE DIMMABLE 240 VOLT 2200K GU10 LED 200 LUMENS +/- 10% 15,000 HOUR LIFE LAMP	DECORATIVE WALL LIGHT TO BE POSITIONED AS PER THE ARCHITECTURAL ELEVATION	KHAKI 93	LIGHTING COLLECTIVE TUSCAN CERAMIC OUTDOOR 150 DIA	A
WF01	TBA	DECORATIVE WALL LIGHT ALLOW TO INSTALL. ALLOW A PC SUM FOR THE SUPPLY OF EACH FITTING	TBA	ALLOW A PC SUM OF \$500.00 FOR THE SUPPLY OF EACH WF01	B
RD01	15W 3000K LED	90 DIA RECESSED DOWNLIGHT C/W 24 DEG BEAM REMOTE DALI DIMMABLE DRIVER	WHITE	RAPID R1078-WH-15W-WW-DALI	A
RD02	15W 3000K LED	90 DIA RECESSED DOWNLIGHT C/W 24 DEG BEAM REMOTE DALI DIMMABLE DRIVER	BLACK	RAPID R1078-WH-15W-WW-DALI	A



ELECTRICAL DESIGN GROUP

ELECTRICAL BUILDING SERVICES CONSULTANTS

P.O. Box 15, SHERWOOD Q. 4075

Phone: (07) 3278 4375 Fax: (07) 3716 0222

Web Site: www.edg.net.au Email: brisbane@edg.net.au

C3457a - THE LION RICHLANDS - STAGE 2


C3457a-0002(C).xls

ELECTRICAL EQUIPMENT SCHEDULE

REVISION C - 16 SEPTEMBER 2026

THE LIGHT FITTING SUPPLIER CONTACT DETAILS MAY BE AVAILABLE ON THE EDG WEBSITE VIA THE FOLLOWING LINK
www.edg.net.au/Links/Lighting.htm

TYPE	LAMPS	DESCRIPTION	COLOUR / ACCESSORY	CATALOGUE No	REV
RD03	15W 3000K LED	75 DIA RECESSED DOWNLIGHT C/W 24 DEG BEAM REMOTE DALI DIMMABLE DRIVER	WHITE	RAPID R1077-WH- 15W-WW-DALI	A
RD04	15W 3000K LED	75 DIA RECESSED DOWNLIGHT C/W 24 DEG BEAM REMOTE DALI DIMMABLE DRIVER	BLACK	RAPID R1077-WH- 15W-WW-DALI	A
RD05	30W 3000K LED	200 DIA RECESSED DOWNLIGHT C/W 24 DEG BEAM REMOTE DALI DIMMABLE DRIVER	WHITE	RAPID R1074-TRI-30W- DALI	A
RD06	15W 3000K LED	90 DIA RECESSED DOWNLIGHT C/W 24 DEG BEAM REMOTE DALI DIMMABLE DRIVER	WHITE	RAPID R1073-WH- 15W-WW-DALI	B
RD07	15W 3000K LED	90 DIA RECESSED DOWNLIGHT C/W 24 DEG BEAM REMOTE DALI DIMMABLE DRIVER	WHITE	RAPID R1073-WH- 15W-WW-DALI	A
RD08	NO LONGR REQUIRED				B
RD09	15W 3000K LED	80 DIA RECESSED ADJUSTABLE DOWNLIGHT C/W 24 DEG BEAM REMOTE DALI DIMMABLE DRIVER	WHITE	RAPID R1074-WH- 15W-WW-DALI	C
RD10	NO LONGR REQUIRED				B
RD11	15W 3000K LED	90 DIA RECESSED DOWNLIGHT C/W 24 DEG BEAM REMOTE DALI DIMMABLE DRIVER	WHITE	RAPID R1073-WH- 15W-WW-DALI	B
RD12	15W 3000K LED	90 DIA RECESSED DOWNLIGHT C/W 24 DEG BEAM REMOTE DALI DIMMABLE DRIVER	WHITE	RAPID R1073-WH- 15W-WW-DALI	B
RD13	15W 3000K LED	124 DIA 126 DEEP SURFACE MOUNTED CAN DOWNLIGHT C/W 60 DEG BEAM REMOTE DALI DIMMABLE DRIVER	BLACK	RAPID R1166-BK-15W- WW-DALI	C



ELECTRICAL DESIGN GROUP


ELECTRICAL BUILDING SERVICES CONSULTANTS

P.O. Box 15, SHERWOOD Q. 4075

Phone: (07) 3278 4375 Fax: (07) 3716 0222

Web Site: www.edg.net.au Email: brisbane@edg.net.au

C3457a - THE LION RICHLANDS - STAGE 2					C3457a-0002(C).xls
ELECTRICAL EQUIPMENT SCHEDULE					
REVISION C - 16 SEPTEMBER 2026					
THE LIGHT FITTING SUPPLIER CONTACT DETAILS MAY BE AVAILABLE ON THE EDG WEBSITE VIA THE FOLLOWING LINK www.edg.net.au/Links/Lighting.htm					
TYPE	LAMPS	DESCRIPTION	COLOUR / ACCESSORY	CATALOGUE No	REV
RT01	40W 4000K LED	1200 X 300 LAY IN FLAT PLATE LED FITTING C/W REMOTE DRIVER MOUNTED IN A FLUSH RECESSED PLASTER BOARD KIT	WHITE TRIM	EQUAL TO GAMMA ILLUMINATION PHANTOM 884501	A
SL01	40W LED 4000K	SURFACE MOUNTED IP66 1200 LONG BATTEN C/W INTEGRAL DRIVER	LIGHT GREY	RAPID LED R3540-TRI	A
SL02	15W 3000K LED	SURFACE MOUNTED 62 DIA 172 HIGH CAN DOWNLIGHT C/W 40DEG BEAM REMOTE DALI DIMMABLE DRIVER	WHITE	LUMEN 8 SOLIS SOROSU15930TR WHITE 15W 40DEG	A
UL01	2700K LED	INGROUND UP LIGHT C/W REMOTE DALI DIMMABLE DRIVER / POWER SUPPLY. IT IS ACCEPTABLE TO SUPPLY MULTIPLE FITTINGS FROM A COMMON SUITABLE SIZED DRIVE / POWER SUPPLY. LOCATE THE DRIVER / POWER SUPPLY IN A CONCEALED ACCESSIBLE POSITION NOTED ON THE AS CONSTRUCTED DOCUMENTS	STAINLESS STEEL	LUMEN 8 RAY MINI LLD	C
UL02	2700K LED	WALL RECESSED LIGHT C/W REMOTE DALI DIMMABLE DRIVER / POWER SUPPLY. IT IS ACCEPTABLE TO SUPPLY MULTIPLE FITTINGS FROM A COMMON SUITABLE SIZED DRIVE / POWER SUPPLY. LOCATE THE DRIVER / POWER SUPPLY IN A CONCEALED ACCESSIBLE POSITION NOTED ON THE AS CONSTRUCTED DOCUMENTS	WHITE	LUMEN 8 DEDALO LED	A
UL03	7W 2700L LED	GARDEN ADJUSTABLE SPIKE LIGHT C/W REMOTE DALI DIMMABLE DRIVER / POWER SUPPLY. IT IS ACCEPTABLE TO SUPPLY MULTIPLE FITTINGS FROM A COMMON SUITABLE SIZED DRIVE / POWER SUPPLY. LOCATE THE DRIVER / POWER SUPPLY IN A CONCEALED ACCESSIBLE POSITION NOTED ON THE AS CONSTRUCTED DOCUMENTS	BLACK	LUMEN 8 SPIKE	A
G1	14.4W/M 2700K LED	LED STRIP WITHIN A SCREW FIXED EXTRUSION C/W DIFFUSER FIXED INTO THE GAMING MACHINE BASE AS PER THE ARCHITECTURAL DETAIL. PROVIDE THE STRIP WITH REMOTE DALI DIMMABLE POWER SUPPLIES AS REQUIRED LOCATE THE POWER SUPPLIES IN A CONCEALED ACCESSIBLE POSITION NOTED ON THE AS CONSTRUCTED DOCUMENTS.	NATURAL	RAPID LED R2334 2700 K PLUS ALUMINIUM EXTRUSION OPAL DIFFUSER AND POWER SUPPLY & DALI CONTROLLER	B
GL01	TRAILING EDGE DIMMABLE 240 VOLT 2200K E27 LED 400 LUMENS +/- 10% 15,000 HOUR LIFE LAMP	GROUND MOUNTED IP76 300 DIA SPHERE	NA	ABOUT SPACE 300DIA SKYBALL SPIKE	A



ELECTRICAL DESIGN GROUP


ELECTRICAL BUILDING SERVICES CONSULTANTS

P.O. Box 15, SHERWOOD Q. 4075

Phone: (07) 3278 4375 Fax: (07) 3716 0222

Web Site: www.edg.net.au Email: brisbane@edg.net.au

C3457a - THE LION RICHLANDS - STAGE 2					C3457a-0002(C).xls
ELECTRICAL EQUIPMENT SCHEDULE					
REVISION C - 16 SEPTEMBER 2026					
THE LIGHT FITTING SUPPLIER CONTACT DETAILS MAY BE AVAILABLE ON THE EDG WEBSITE VIA THE FOLLOWING LINK www.edg.net.au/Links/Lighting.htm					
TYPE	LAMPS	DESCRIPTION	COLOUR / ACCESSORY	CATALOGUE No	REV
GL02	TRAILING EDGE DIMMABLE 240 VOLT 2200K E27 LED 800 LUMENS +/- 10% 15,000 HOUR LIFE LAMP	GROUND MOUNTED IP76 500 DIA SPHERE	NA	ABOUT SPACE 500DIA SKYBALL SPIKE	A
GL03	NO LONGR REQUIRED				B
GL04	NO LONGR REQUIRED				B
GL05	3W 2770 K LED	GARDEN LIGHT PROVIDE THE GLO5 WITH REMOTE DALI DIMMABLE POWER SUPPLIES AS REQUIRED IT IS ACCEPTABLE TO SUPPLY MULTIPLE GL05 FITTINGS FROM A SUITABLE SIZED COMMON POWER SUPPLY. LOCATE THE POWER SUPPLIES IN A CONCEALED ACCESSIBLE POSITION NOTED ON THE AS CONSTRUCTED DOCUMENTS.	AGED BRASS	NOCTURNAL LIGHTING BUNYIP	C
GL06	4W 2770 K LED	GARDEN LIGHT PROVIDE THE GLO6 WITH REMOTE DALI DIMMABLE POWER SUPPLIES AS REQUIRED IT IS ACCEPTABLE TO SUPPLY MULTIPLE GL06 FITTINGS FROM A SUITABLE SIZED COMMON POWER SUPPLY. LOCATE THE POWER SUPPLIES IN A CONCEALED ACCESSIBLE POSITION NOTED ON THE AS CONSTRUCTED DOCUMENTS.	BRUSHED BRASS	NOCTURNAL LIGHTING DINGO	C
S1	10W/M 2700K LED	IP67 LED FLEX SCREW FIXED BEHIND THE MIRROR AS PER THE ELEVATION. MOUNT AS PER THE ARCHITECTURAL DETAIL. PROVIDE THE STRIP WITH REMOTE DALI DIMMABLE POWER SUPPLIES AS REQUIRED LOCATE THE POWER SUPPLIES IN A CONCEALED ACCESSIBLE POSITION NOTED ON THE AS CONSTRUCTED DOCUMENTS. CONFIRM THE BEND PLANE (TOP OR SIDE) ON SITE WITH THE ARCHITECT.	WHITE	RAPID LED R2321 OR R2322 - 2700K + POWER SUPPLY & DALI CONTROLLER	A
S2	14.4W/M 2700K LED	LED STRIP WITHIN A SCREW FIXED EXTRUSION C/W DIFFUSER FIXED TO THE UNDERSIDE OF THE OVERHEAD CUPBOARD AGAINST THE SPLASHBACK. PROVIDE THE STRIP WITH REMOTE DALI DIMMABLE POWER SUPPLIES AS REQUIRED LOCATE THE POWER SUPPLIES IN A CONCEALED ACCESSIBLE POSITION NOTED ON THE AS CONSTRUCTED DOCUMENTS.	NATURAL	RAPID LED R2334 2700 K PLUS ALUMINIUM EXTRUSION OPAL DIFFUSER AND POWER SUPPLY & DALI CONTROLLER	A
S3	14.4W/M 2700K LED	LED STRIP WITHIN A SCREW FIXED EXTRUSION C/W DIFFUSER MOUNTED AS PER THE ARCHITECTURAL DETAIL. PROVIDE THE STRIP WITH REMOTE DALI DIMMABLE POWER SUPPLIES AS REQUIRED LOCATE THE POWER SUPPLIES IN A CONCEALED ACCESSIBLE POSITION NOTED ON THE AS CONSTRUCTED DOCUMENTS.	NATURAL	RAPID LED R2334 2700 K PLUS ALUMINIUM EXTRUSION OPAL DIFFUSER AND POWER SUPPLY & DALI CONTROLLER	A



ELECTRICAL DESIGN GROUP

ELECTRICAL BUILDING SERVICES CONSULTANTS

P.O. Box 15, SHERWOOD Q. 4075

Phone: (07) 3278 4375 Fax: (07) 3716 0222

Web Site: www.edg.net.au Email: brisbane@edg.net.au

C3457a - THE LION RICHLANDS - STAGE 2


C3457a-0002(C).xls

ELECTRICAL EQUIPMENT SCHEDULE

REVISION C - 16 SEPTEMBER 2026

THE LIGHT FITTING SUPPLIER CONTACT DETAILS MAY BE AVAILABLE ON THE EDG WEBSITE VIA THE FOLLOWING LINK
www.edg.net.au/Links/Lighting.htm

TYPE	LAMPS	DESCRIPTION	COLOUR / ACCESSORY	CATALOGUE No	REV
S4	14.4W/M 2700K LED	LED STRIP WITHIN A SCREW FIXED EXTRUSION C/W DIFFUSER MOUNTED BEHIND THE TV AS PER THE ELEVATION. MOUNT AS PER THE ARCHITECTURAL DETAIL. PROVIDE THE STRIP WITH REMOTE DALI DIMMABLE POWER SUPPLIES AS REQUIRED LOCATE THE POWER SUPPLIES IN A CONCEALED ACCESSIBLE POSITION NOTED ON THE AS CONSTRUCTED DOCUMENTS.	NATURAL	RAPID LED R2334 2700K PLUS ALUMINIUM EXTRUSION OPAL DIFFUSER AND POWER SUPPLY & DALI CONTROLLER	A
S5	10W/M 2700K LED	EIGHT IP67 LED FLEX SCREW FIXED RECESSED ONTO THE COLUMN AS PER THE DETAIL. MOUNT AS PER THE ARCHITECTURAL DETAIL. PROVIDE THE STRIP WITH REMOTE DALI DIMMABLE POWER SUPPLIES AS REQUIRED LOCATE THE POWER SUPPLIES IN A CONCEALED ACCESSIBLE POSITION NOTED ON THE AS CONSTRUCTED DOCUMENTS. CONFIRM THE BEND PLANE (TOP OR SIDE) ON SITE WITH THE ARCHITECT.	WHITE	RAPID LED R2321 OR R2322 - 2700K + POWER SUPPLY & DALI CONTROLLER	A
S6	14.4W/M 2700K LED	ROD SUSPENDED 50 X 70 EXTRUSION CW OPAL DIFFUSER AND REMOTE DALI DIMMABLE DRIVER CONFIRM THE SUSPENSION HEIGHT WITH THE ARCHITECT ON SITE	BLACK	RAPID LED R2170 CUSTOM LENGTH DALI	A
S7	10W/M 2700K LED	IP67 LED FLEX SCREW FIXED WITHIN THE CEILING PELMET MOUNTED AS PER THE ARCHITECTURAL DETAIL. PROVIDE THE STRIP WITH REMOTE DALI DIMMABLE POWER SUPPLIES AS REQUIRED LOCATE THE POWER SUPPLIES IN A CONCEALED ACCESSIBLE POSITION NOTED ON THE AS CONSTRUCTED DOCUMENTS. CONFIRM THE BEND PLANE (TOP OR SIDE) ON SITE WITH THE ARCHITECT.	WHITE	RAPID LED R2321 OR R2322 - 2700K + POWER SUPPLY & DALI CONTROLLER	A
S8	14.4W/M 2700K LED	ROD SUSPENDED 50 X 70 EXTRUSION CW OPAL DIFFUSER AND REMOTE DALI DIMMABLE DRIVER CONFIRM THE SUSPENSION HEIGHT WITH THE ARCHITECT ON SITE	BLACK	RAPID LED R2170 CUSTOM LENGTH DALI	A
S9	10W/M 2700K LED	TWO RUNS OF IP67 LED FLEX SCREW FIXED WITHIN THE EXTERNAL FEATURE FACIA AS PER THE SECTION. ONE STRIP IS TO ILLUMINATE UPWARDS AND ONE STRIP IS TO ILLUMINATE DOWNWARDS. PROVIDE THE STRIP WITH REMOTE DALI DIMMABLE POWER SUPPLIES AS REQUIRED LOCATE THE POWER SUPPLIES IN A CONCEALED ACCESSIBLE POSITION NOTED ON THE AS CONSTRUCTED DOCUMENTS. CONFIRM THE BEND PLANE (TOP OR SIDE) ON SITE WITH THE ARCHITECT.	WHITE	RAPID LED R2321 OR R2322 - 2700K + POWER SUPPLY & DALI CONTROLLER	A



ELECTRICAL DESIGN GROUP


ELECTRICAL BUILDING SERVICES CONSULTANTS

P.O. Box 15, SHERWOOD Q. 4075

Phone: (07) 3278 4375 Fax: (07) 3716 0222

Web Site: www.edg.net.au Email: brisbane@edg.net.au

C3457a - THE LION RICHLANDS - STAGE 2					C3457a-0002(C).xls
ELECTRICAL EQUIPMENT SCHEDULE					
REVISION C - 16 SEPTEMBER 2026					
THE LIGHT FITTING SUPPLIER CONTACT DETAILS MAY BE AVAILABLE ON THE EDG WEBSITE VIA THE FOLLOWING LINK www.edg.net.au/Links/Lighting.htm					
TYPE	LAMPS	DESCRIPTION	COLOUR / ACCESSORY	CATALOGUE No	REV
S10	10W/M 2700K LED	IP67 LED FLEX SCREW FIXED RECESSED ONTO THE UNDERSIDE OF THE PLANTER AS PER THE ARCHITECTURAL DETAIL. PROVIDE THE STRIP WITH REMOTE DALI DIMMABLE POWER SUPPLIES AS REQUIRED LOCATE THE POWER SUPPLIES IN A CONCEALED ACCESSIBLE POSITION NOTED ON THE AS CONSTRUCTED DOCUMENTS. CONFIRM THE BEND PLANE (TOP OR SIDE) ON SITE WITH THE ARCHITECT.	WHITE	RAPID LED R2321 OR R2322 - 2700K + POWER SUPPLY & DALI CONTROLLER	A
S11	14.4W/M 2700K LED	MULTIPLE RUNS OF LED STRIP WITHIN A SCREW FIXED EXTRUSION C/W DIFFUSER RECESSED INTO THE REAR BAR DISPLAY AS PER THE ELEVATION. MOUNT THE STRIP AS PER THE ARCHITECTURAL DETAIL. PROVIDE THE STRIP WITH REMOTE DALI DIMMABLE POWER SUPPLIES AS REQUIRED LOCATE THE POWER SUPPLIES IN A CONCEALED ACCESSIBLE POSITION NOTED ON THE AS CONSTRUCTED DOCUMENTS.	NATURAL	RAPID LED R2334 2700 K PLUS ALUMINIUM EXTRUSION OPAL DIFFUSER AND POWER SUPPLY & DALI CONTROLLER	A
S12	10W/M 2700K LED	IP67 LED FLEX SCREW FIXED RECESSED ONTO THE REAR BAR JOINERY AS PER THE ELEVATION. MOUNT AS PER THE ARCHITECTURAL DETAIL. PROVIDE THE STRIP WITH REMOTE DALI DIMMABLE POWER SUPPLIES AS REQUIRED LOCATE THE POWER SUPPLIES IN A CONCEALED ACCESSIBLE POSITION NOTED ON THE AS CONSTRUCTED DOCUMENTS. CONFIRM THE BEND PLANE (TOP OR SIDE) ON SITE WITH THE ARCHITECT.	WHITE	RAPID LED R2321 OR R2322 - 2700K + POWER SUPPLY & DALI CONTROLLER	A
S13	ALLOW A PC SUM OF \$10,000.00 FOR THE SUPPLY AND INSTALLATION OF THE S13 FITTING. PROVIDE THE S13 FITTING WITH DALI CONTROL.				A
S14	12W/M +/- 10% 3000K 24V LED	STEP TREAD EXTRUSION C/W IP65 LED STRIP AND DIFFUSER REMOTE DALI DIMMABLE DRIVER LOCATED IN A CONCEALED ACCESSIBLE POSITION. ENSURE THE DRIVER IS LOCATED ON THE AS CONSTRUCTED DRAWINGS.	ANODISED SILVER	SUPERLIGHT SL8488-00 + SL8488-12 + 24 V LED STRIP	A
S15	ALLOW A PC SUM OF \$10,000.00 FOR THE SUPPLY AND INSTALLATION OF THE S15 FITTING. PROVIDE THE S15 FITTING WITH DALI CONTROL.				A



ELECTRICAL DESIGN GROUP


ELECTRICAL BUILDING SERVICES CONSULTANTS

P.O. Box 15, SHERWOOD Q. 4075

Phone: (07) 3278 4375 Fax: (07) 3716 0222

Web Site: www.edg.net.au Email: brisbane@edg.net.au

C3457a - THE LION RICHLANDS - STAGE 2					C3457a-0002(C).xls
ELECTRICAL EQUIPMENT SCHEDULE					
REVISION C - 16 SEPTEMBER 2026					
THE LIGHT FITTING SUPPLIER CONTACT DETAILS MAY BE AVAILABLE ON THE EDG WEBSITE VIA THE FOLLOWING LINK www.edg.net.au/Links/Lighting.htm					
TYPE	LAMPS	DESCRIPTION	COLOUR / ACCESSORY	CATALOGUE No	REV
S16	10W/M 2700K LED	IP67 LED FLEX SCREW FIXED RECESSED ONTO THE WALL AS PER THE ARCHITECTURAL DETAIL. PROVIDE THE STRIP WITH REMOTE DALI DIMMABLE POWER SUPPLIES AS REQUIRED LOCATE THE POWER SUPPLIES IN A CONCEALED ACCESSIBLE POSITION NOTED ON THE AS CONSTRUCTED DOCUMENTS. CONFIRM THE BEND PLANE (TOP OR SIDE) ON SITE WITH THE ARCHITECT.	WHITE	RAPID LED R2321 OR R2322 - 2700K + POWER SUPPLY & DALI CONTROLLER	A
S17	10W/M 2700K LED	IP67 LED FLEX SCREW FIXED RECESSED ONTO THE WALL FEATURE AS PER THE ELEVATION. MOUNT AS PER THE ARCHITECTURAL DETAIL. PROVIDE THE STRIP WITH REMOTE DALI DIMMABLE POWER SUPPLIES AS REQUIRED LOCATE THE POWER SUPPLIES IN A CONCEALED ACCESSIBLE POSITION NOTED ON THE AS CONSTRUCTED DOCUMENTS. CONFIRM THE BEND PLANE (TOP OR SIDE) ON SITE WITH THE ARCHITECT.	WHITE	RAPID LED R2321 OR R2322 - 2700K + POWER SUPPLY & DALI CONTROLLER	A
S18	10W/M 2700K LED	IP67 LED FLEX SCREW FIXED RECESSED ONTO THE WALL FEATURE AS PER THE ELEVATION. MOUNT AS PER THE ARCHITECTURAL DETAIL. PROVIDE THE STRIP WITH REMOTE DALI DIMMABLE POWER SUPPLIES AS REQUIRED LOCATE THE POWER SUPPLIES IN A CONCEALED ACCESSIBLE POSITION NOTED ON THE AS CONSTRUCTED DOCUMENTS. CONFIRM THE BEND PLANE (TOP OR SIDE) ON SITE WITH THE ARCHITECT.	WHITE	RAPID LED R2321 OR R2322 - 2700K + POWER SUPPLY & DALI CONTROLLER	A
S19	14.4W/M 2700K LED	TWO LED STRIPS WITHIN A SCREW FIXED EXTRUSION C/W DIFFUSER AS PER THE ELEVATION. MOUNT THE STRIPS WITHIN THE WALL DISPLAY AS PER THE ARCHITECTURAL DETAILS. PROVIDE THE STRIP WITH REMOTE DALI DIMMABLE POWER SUPPLIES AS REQUIRED LOCATE THE POWER SUPPLIES IN A CONCEALED ACCESSIBLE POSITION NOTED ON THE AS CONSTRUCTED DOCUMENTS.	NATURAL	RAPID LED R2334 2700 K PLUS ALUMINIUM EXTRUSION OPAL DIFFUSER AND POWER SUPPLY & DALI CONTROLLER	A
S20	14.4W/M 2700K LED	THREE LED STRIPS WITHIN A SCREW FIXED EXTRUSION C/W DIFFUSER AS PER THE ELEVATION. MOUNT THE STRIPS WITHIN THE WALL DISPLAY AS PER THE ARCHITECTURAL DETAILS.. PROVIDE THE STRIP WITH REMOTE DALI DIMMABLE POWER SUPPLIES AS REQUIRED LOCATE THE POWER SUPPLIES IN A CONCEALED ACCESSIBLE POSITION NOTED ON THE AS CONSTRUCTED DOCUMENTS.	NATURAL	RAPID LED R2334 2700 K PLUS ALUMINIUM EXTRUSION OPAL DIFFUSER AND POWER SUPPLY & DALI CONTROLLER	A



ELECTRICAL DESIGN GROUP


ELECTRICAL BUILDING SERVICES CONSULTANTS

P.O. Box 15, SHERWOOD Q. 4075

Phone: (07) 3278 4375 Fax: (07) 3716 0222

Web Site: www.edg.net.au Email: brisbane@edg.net.au

C3457a - THE LION RICHLANDS - STAGE 2					C3457a-0002(C).xls
ELECTRICAL EQUIPMENT SCHEDULE					
REVISION C - 16 SEPTEMBER 2026					
THE LIGHT FITTING SUPPLIER CONTACT DETAILS MAY BE AVAILABLE ON THE EDG WEBSITE VIA THE FOLLOWING LINK www.edg.net.au/Links/Lighting.htm					
TYPE	LAMPS	DESCRIPTION	COLOUR / ACCESSORY	CATALOGUE No	REV
S21	10W/M 2700K LED	IP67 LED FLEX SCREW FIXED ON THE WALL AS PER THE ELEVATION. MOUNT AS PER THE ARCHITECTURAL DETAIL. PROVIDE THE STRIP WITH REMOTE DALI DIMMABLE POWER SUPPLIES AS REQUIRED. LOCATE THE POWER SUPPLIES IN A CONCEALED ACCESSIBLE POSITION NOTED ON THE AS CONSTRUCTED DOCUMENTS. CONFIRM THE BEND PLANE (TOP OR SIDE) ON SITE WITH THE ARCHITECT.	WHITE	RAPID LED R2321 OR R2322 - 2700K + POWER SUPPLY & DALI CONTROLLER	A
S22	10W/M 2700K LED	LED STRIP WITHIN A SCREW FIXED EXTRUSION C/W DIFFUSER MOUNTED UNDER THE BAR TOP TO ILLUMINATE THE WORK SPACE AS PER THE ARCHITECTURAL DETAIL. PROVIDE THE STRIP WITH REMOTE DALI DIMMABLE POWER SUPPLY LOCATED IN A CONCEALED ACCESSIBLE POSITION NOTED ON THE AS CONSTRUCTED DOCUMENTS.	NATURAL	RAPID LED R2321 OR R2322 - 2700K + POWER SUPPLY & DALI CONTROLLER	A
S23	10W/M 2700K LED	LED STRIP WITHIN A SCREW FIXED EXTRUSION C/W DIFFUSER MOUNTED WITHIN THE BAR FRONT PER THE ARCHITECTURAL DETAIL. PROVIDE THE STRIP WITH REMOTE DALI DIMMABLE POWER SUPPLY LOCATED IN A CONCEALED ACCESSIBLE POSITION NOTED ON THE AS CONSTRUCTED DOCUMENTS.	NATURAL	RAPID LED R2321 OR R2322 - 2700K + POWER SUPPLY & DALI CONTROLLER	A
S24	10W/M 2700K LED	IP67 LED FLEX SCREW FIXED RECESSED UNDER THE SEAT MOUNTED AS PER THE ARCHITECTURAL DETAIL. PROVIDE THE STRIP WITH REMOTE DALI DIMMABLE POWER SUPPLIES AS REQUIRED. LOCATE THE POWER SUPPLIES IN A CONCEALED ACCESSIBLE POSITION NOTED ON THE AS CONSTRUCTED DOCUMENTS. CONFIRM THE BEND PLANE (TOP OR SIDE) ON SITE WITH THE ARCHITECT.	WHITE	RAPID LED R2321 OR R2322 - 2700K + POWER SUPPLY & DALI CONTROLLER	A
S25	ALLOW A PC SUM OF \$10,000.00 FOR THE SUPPLY AND INSTALLATION OF THE S25 FITTING. PROVIDE THE S25 FITTING WITH DALI CONTROL.				A
S26	10W/M 2700K LED	IP67 LED FLEX SCREW FIXED RECESSED ONTO THE WALL AS PER THE ARCHITECTURAL DETAIL. PROVIDE THE STRIP WITH REMOTE DALI DIMMABLE POWER SUPPLIES AS REQUIRED. LOCATE THE POWER SUPPLIES IN A CONCEALED ACCESSIBLE POSITION NOTED ON THE AS CONSTRUCTED DOCUMENTS. CONFIRM THE BEND PLANE (TOP OR SIDE) ON SITE WITH THE ARCHITECT.	WHITE	RAPID LED R2321 OR R2322 - 2700K + POWER SUPPLY & DALI CONTROLLER	A
S27	ALLOW A PC SUM OF \$30,000.00 FOR THE SUPPLY AND INSTALLATION OF THE S27 FITTING. PROVIDE THE S27 FITTING WITH DALI CONTROL.				A



ELECTRICAL DESIGN GROUP


ELECTRICAL BUILDING SERVICES CONSULTANTS

P.O. Box 15, SHERWOOD Q. 4075

Phone: (07) 3278 4375 Fax: (07) 3716 0222

Web Site: www.edg.net.au Email: brisbane@edg.net.au

C3457a - THE LION RICHLANDS - STAGE 2					C3457a-0002(C).xls
ELECTRICAL EQUIPMENT SCHEDULE					
REVISION C - 16 SEPTEMBER 2026					
THE LIGHT FITTING SUPPLIER CONTACT DETAILS MAY BE AVAILABLE ON THE EDG WEBSITE VIA THE FOLLOWING LINK www.edg.net.au/Links/Lighting.htm					
TYPE	LAMPS	DESCRIPTION	COLOUR / ACCESSORY	CATALOGUE No	REV
S28	NO LONGR REQUIRED				B
S29	10W/M 2700K LED	MULTIPLE VERTICAL RUNS OF IP67 LED FLEX SCREW FIXED RECESSED INTO THE COLUMN WITH THE MOUNTING AND QUANTITY AS PER THE ARCHITECTURAL DETAIL. PROVIDE THE STRIP WITH REMOTE DALI DIMMABLE POWER SUPPLIES AS REQUIRED LOCATE THE POWER SUPPLIES IN A CONCEALED ACCESSIBLE POSITION NOTED ON THE AS CONSTRUCTED DOCUMENTS. CONFIRM THE BEND PLANE (TOP OR SIDE) ON SITE WITH THE ARCHITECT.	WHITE	RAPID LED R2321 OR R2322 - 2700K + POWER SUPPLY & DALI CONTROLLER	A
S30	10W/M 2700K LED	IP67 LED FLEX SCREW FIXED RECESSED ONTO THE CEILING COFFER AS PER THE ARCHITECTURAL DETAIL. PROVIDE THE STRIP WITH REMOTE DALI DIMMABLE POWER SUPPLIES AS REQUIRED LOCATE THE POWER SUPPLIES IN A CONCEALED ACCESSIBLE POSITION NOTED ON THE AS CONSTRUCTED DOCUMENTS. CONFIRM THE BEND PLANE (TOP OR SIDE) ON SITE WITH THE ARCHITECT.	WHITE	RAPID LED R2321 OR R2322 - 2700K + POWER SUPPLY & DALI CONTROLLER	A
S31	10W/M 2700K LED	IP67 LED FLEX SCREW FIXED RECESSED ONTO THE CEILING COFFER AS PER THE ARCHITECTURAL DETAIL. PROVIDE THE STRIP WITH REMOTE DALI DIMMABLE POWER SUPPLIES AS REQUIRED LOCATE THE POWER SUPPLIES IN A CONCEALED ACCESSIBLE POSITION NOTED ON THE AS CONSTRUCTED DOCUMENTS. CONFIRM THE BEND PLANE (TOP OR SIDE) ON SITE WITH THE ARCHITECT.	WHITE	RAPID LED R2321 OR R2322 - 2700K + POWER SUPPLY & DALI CONTROLLER	A
S32	10W/M 2700K LED	MULTIPLE VERTICAL RUNS OF IP67 LED FLEX SCREW FIXED RECESSED INTO THE GAMING ENTRY WALL WITH THE MOUNTING AND QUANTITY AS PER THE ARCHITECTURAL DETAIL. PROVIDE THE STRIP WITH REMOTE DALI DIMMABLE POWER SUPPLIES AS REQUIRED LOCATE THE POWER SUPPLIES IN A CONCEALED ACCESSIBLE POSITION NOTED ON THE AS CONSTRUCTED DOCUMENTS. CONFIRM THE BEND PLANE (TOP OR SIDE) ON SITE WITH THE ARCHITECT.	WHITE	RAPID LED R2321 OR R2322 - 2700K + POWER SUPPLY & DALI CONTROLLER	A
S33	2.2w 2700K LED	18DEG DOWNLIGHT C/W REMOTE DALI DIMMABLE DRIVER / POWER SUPPLY. MOUNT THE FITTINGS WITHIN THE UNDERSIDE OF THE VERTICAL FIN TO ILLUMINATE DOWNWARDS. AS PER THE ARCHITECTURAL DETAIL IT IS ACCEPTABLE TO SUPPLY MULTIPLE FITTINGS FROM A COMMON SUITABLE SIZED DRIVE / POWER SUPPLY. LOCATE THE DRIVER / POWER SUPPLY IN A CONCEALED ACCESSIBLE POSITION NOTED ON THE AS CONSTRUCTED DOCUMENTS	STAINLESS STEEL	LUMEN 8 LLD ALTEA MINI	B



ELECTRICAL DESIGN GROUP


ELECTRICAL BUILDING SERVICES CONSULTANTS

P.O. Box 15, SHERWOOD Q. 4075

Phone: (07) 3278 4375 Fax: (07) 3716 0222

Web Site: www.edg.net.au Email: brisbane@edg.net.au

C3457a - THE LION RICHLANDS - STAGE 2					C3457a-0002(C).xls
ELECTRICAL EQUIPMENT SCHEDULE					
REVISION C - 16 SEPTEMBER 2026					
THE LIGHT FITTING SUPPLIER CONTACT DETAILS MAY BE AVAILABLE ON THE EDG WEBSITE VIA THE FOLLOWING LINK www.edg.net.au/Links/Lighting.htm					
TYPE	LAMPS	DESCRIPTION	COLOUR / ACCESSORY	CATALOGUE No	REV
S34	10W/M 2700K LED	TWO RUNS OF IP67 LED FLEX SCREW FIXED RECESSED ONTO THE WALL AS PER THE ELEVATION. MOUNT AS PER THE ARCHITECTURAL DETAIL. PROVIDE THE STRIP WITH REMOTE DALI DIMMABLE POWER SUPPLIES AS REQUIRED LOCATE THE POWER SUPPLIES IN A CONCEALED ACCESSIBLE POSITION NOTED ON THE AS CONSTRUCTED DOCUMENTS. CONFIRM THE BEND PLANE (TOP OR SIDE) ON SITE WITH THE ARCHITECT.	WHITE	RAPID LED R2321 OR R2322 - 2700K + POWER SUPPLY & DALI CONTROLLER	A
S35	10W/M 2700K LED	IP67 LED FLEX SCREW FIXED RECESSED ONTO THE CEILING COFFER AS PER THE ARCHITECTURAL DETAIL. PROVIDE THE STRIP WITH REMOTE DALI DIMMABLE POWER SUPPLIES AS REQUIRED LOCATE THE POWER SUPPLIES IN A CONCEALED ACCESSIBLE POSITION NOTED ON THE AS CONSTRUCTED DOCUMENTS. CONFIRM THE BEND PLANE (TOP OR SIDE) ON SITE WITH THE ARCHITECT.	WHITE	RAPID LED R2321 OR R2322 - 2700K + POWER SUPPLY & DALI CONTROLLER	A
S36	10W/M 2700K LED	IP67 LED FLEX SCREW FIXED RECESSED ONTO THE CEILING COFFER AS PER THE ARCHITECTURAL DETAIL. PROVIDE THE STRIP WITH REMOTE DALI DIMMABLE POWER SUPPLIES AS REQUIRED LOCATE THE POWER SUPPLIES IN A CONCEALED ACCESSIBLE POSITION NOTED ON THE AS CONSTRUCTED DOCUMENTS. CONFIRM THE BEND PLANE (TOP OR SIDE) ON SITE WITH THE ARCHITECT.	WHITE	RAPID LED R2321 OR R2322 - 2700K + POWER SUPPLY & DALI CONTROLLER	A
S37	10W/M 2700K LED	IP67 LED FLEX SCREW FIXED RECESSED ONTO THE CEILING COFFER AS PER THE ARCHITECTURAL DETAIL. PROVIDE THE STRIP WITH REMOTE DALI DIMMABLE POWER SUPPLIES AS REQUIRED LOCATE THE POWER SUPPLIES IN A CONCEALED ACCESSIBLE POSITION NOTED ON THE AS CONSTRUCTED DOCUMENTS. CONFIRM THE BEND PLANE (TOP OR SIDE) ON SITE WITH THE ARCHITECT.	WHITE	RAPID LED R2321 OR R2322 - 2700K + POWER SUPPLY & DALI CONTROLLER	A
S38	10W/M 2700K LED	IP67 LED FLEX SCREW FIXED RECESSED ONTO THE CURTAIN COFFER AS PER THE ARCHITECTURAL DETAIL. PROVIDE THE STRIP WITH REMOTE DALI DIMMABLE POWER SUPPLIES AS REQUIRED LOCATE THE POWER SUPPLIES IN A CONCEALED ACCESSIBLE POSITION NOTED ON THE AS CONSTRUCTED DOCUMENTS. CONFIRM THE BEND PLANE (TOP OR SIDE) ON SITE WITH THE ARCHITECT.	WHITE	RAPID LED R2321 OR R2322 - 2700K + POWER SUPPLY & DALI CONTROLLER	A
S39	ALLOW A PC SUM OF \$50,000.00 FOR THE SUPPLY AND INSTALLATION OF THE S39 FITTING. PROVIDE THE S39 FITTING WITH DALI CONTROL.				A



ELECTRICAL DESIGN GROUP

ELECTRICAL BUILDING SERVICES CONSULTANTS

P.O. Box 15, SHERWOOD Q. 4075

Phone: (07) 3278 4375 Fax: (07) 3716 0222

Web Site: www.edg.net.au Email: brisbane@edg.net.au

C3457a - THE LION RICHLANDS - STAGE 2


C3457a-0002(C).xls

ELECTRICAL EQUIPMENT SCHEDULE

REVISION C - 16 SEPTEMBER 2026

THE LIGHT FITTING SUPPLIER CONTACT DETAILS MAY BE AVAILABLE ON THE EDG WEBSITE VIA THE FOLLOWING LINK
www.edg.net.au/Links/Lighting.htm

TYPE	LAMPS	DESCRIPTION	COLOUR / ACCESSORY	CATALOGUE No	REV
S40	10W/M 2700K LED	IP67 LED FLEX SCREW FIXED RECESSED ONTO THE CEILING COFFER AS PER THE ARCHITECTURAL DETAIL. PROVIDE THE STRIP WITH REMOTE DALI DIMMABLE POWER SUPPLIES AS REQUIRED LOCATE THE POWER SUPPLIES IN A CONCEALED ACCESSIBLE POSITION NOTED ON THE AS CONSTRUCTED DOCUMENTS. CONFIRM THE BEND PLANE (TOP OR SIDE) ON SITE WITH THE ARCHITECT.	WHITE	RAPID LED R2321 OR R2322 - 2700K + POWER SUPPLY & DALI CONTROLLER	A
S41	10W/M 2700K LED	IP67 LED FLEX SCREW FIXED RECESSED ONTO THE CEILING COFFER AS PER THE ARCHITECTURAL DETAIL. PROVIDE THE STRIP WITH REMOTE DALI DIMMABLE POWER SUPPLIES AS REQUIRED LOCATE THE POWER SUPPLIES IN A CONCEALED ACCESSIBLE POSITION NOTED ON THE AS CONSTRUCTED DOCUMENTS. CONFIRM THE BEND PLANE (TOP OR SIDE) ON SITE WITH THE ARCHITECT.	WHITE	RAPID LED R2321 OR R2322 - 2700K + POWER SUPPLY & DALI CONTROLLER	A
S42	10W/M 2700K LED	IP67 LED FLEX SCREW FIXED RECESSED ONTO THE CEILING COFFER AS PER THE ARCHITECTURAL DETAIL. PROVIDE THE STRIP WITH REMOTE DALI DIMMABLE POWER SUPPLIES AS REQUIRED LOCATE THE POWER SUPPLIES IN A CONCEALED ACCESSIBLE POSITION NOTED ON THE AS CONSTRUCTED DOCUMENTS. CONFIRM THE BEND PLANE (TOP OR SIDE) ON SITE WITH THE ARCHITECT.	WHITE	RAPID LED R2321 OR R2322 - 2700K + POWER SUPPLY & DALI CONTROLLER	A
S43	10W/M 2700K LED	IP67 LED FLEX SCREW FIXED RECESSED ONTO THE CEILING COFFER AS PER THE ARCHITECTURAL DETAIL. PROVIDE THE STRIP WITH REMOTE DALI DIMMABLE POWER SUPPLIES AS REQUIRED LOCATE THE POWER SUPPLIES IN A CONCEALED ACCESSIBLE POSITION NOTED ON THE AS CONSTRUCTED DOCUMENTS. CONFIRM THE BEND PLANE (TOP OR SIDE) ON SITE WITH THE ARCHITECT.	WHITE	RAPID LED R2321 OR R2322 - 2700K + POWER SUPPLY & DALI CONTROLLER	A
S44	10W/M 2700K LED	IP67 LED FLEX SCREW FIXED RECESSED ONTO THE CEILING COFFER AS PER THE ARCHITECTURAL DETAIL. PROVIDE THE STRIP WITH REMOTE DALI DIMMABLE POWER SUPPLIES AS REQUIRED LOCATE THE POWER SUPPLIES IN A CONCEALED ACCESSIBLE POSITION NOTED ON THE AS CONSTRUCTED DOCUMENTS. CONFIRM THE BEND PLANE (TOP OR SIDE) ON SITE WITH THE ARCHITECT.	WHITE	RAPID LED R2321 OR R2322 - 2700K + POWER SUPPLY & DALI CONTROLLER	A



ELECTRICAL DESIGN GROUP

ELECTRICAL BUILDING SERVICES CONSULTANTS

P.O. Box 15, SHERWOOD Q. 4075

Phone: (07) 3278 4375 Fax: (07) 3716 0222

Web Site: www.edg.net.au Email: brisbane@edg.net.au

C3457a - THE LION RICHLANDS - STAGE 2


C3457a-0002(C).xls

ELECTRICAL EQUIPMENT SCHEDULE

REVISION C - 16 SEPTEMBER 2026

THE LIGHT FITTING SUPPLIER CONTACT DETAILS MAY BE AVAILABLE ON THE EDG WEBSITE VIA THE FOLLOWING LINK
www.edg.net.au/Links/Lighting.htm

TYPE	LAMPS	DESCRIPTION	COLOUR / ACCESSORY	CATALOGUE No	REV
S45	10W/M 2700K LED	IP67 LED FLEX SCREW FIXED RECESSED ONTO THE CEILING COFFER AS PER THE ARCHITECTURAL DETAIL. PROVIDE THE STRIP WITH REMOTE DALI DIMMABLE POWER SUPPLIES AS REQUIRED LOCATE THE POWER SUPPLIES IN A CONCEALED ACCESSIBLE POSITION NOTED ON THE AS CONSTRUCTED DOCUMENTS. CONFIRM THE BEND PLANE (TOP OR SIDE) ON SITE WITH THE ARCHITECT.	WHITE	RAPID LED R2321 OR R2322 - 2700K + POWER SUPPLY & DALI CONTROLLER	A
S46	ALLOW A PC SUM OF \$50,000.00 FOR THE SUPPLY AND INSTALLATION OF THE S46 FITTING. PROVIDE THE S46 FITTING WITH DALI CONTROL.				A
S47	ALLOW A PC SUM OF \$50,000.00 FOR THE SUPPLY AND INSTALLATION OF THE S47 FITTING. PROVIDE THE S47 FITTING WITH DALI CONTROL.				A
S48	ALLOW A PC SUM OF \$50,000.00 FOR THE SUPPLY AND INSTALLATION OF THE S48 FITTING. PROVIDE THE S48 FITTING WITH DALI CONTROL.				A
S49	10W/M 2700K LED	IP67 LED FLEX SCREW FIXED RECESSED ONTO THE CEILING COFFER AS PER THE ARCHITECTURAL DETAIL. PROVIDE THE STRIP WITH REMOTE DALI DIMMABLE POWER SUPPLIES AS REQUIRED LOCATE THE POWER SUPPLIES IN A CONCEALED ACCESSIBLE POSITION NOTED ON THE AS CONSTRUCTED DOCUMENTS. CONFIRM THE BEND PLANE (TOP OR SIDE) ON SITE WITH THE ARCHITECT.	WHITE	RAPID LED R2321 OR R2322 - 2700K + POWER SUPPLY & DALI CONTROLLER	A
S50	10W/M 2700K LED	IP67 LED FLEX WITHIN A SCREW FIXED EXTRUSION C/W DIFFUSER MOUNTED BEHIND THE TV AS PER THE ELEVATION. MOUNT AS PER THE ARCHITECTURAL DETAIL. PROVIDE THE STRIP WITH REMOTE DALI DIMMABLE POWER SUPPLIES AS REQUIRED LOCATE THE POWER SUPPLIES IN A CONCEALED ACCESSIBLE POSITION NOTED ON THE AS CONSTRUCTED DOCUMENTS.	NATURAL	RAPID LED R2321 OR R2322 - 2700K + POWER SUPPLY & DALI CONTROLLER	C
S51	10W/M 2700K LED	IP67 LED FLEX SCREW FIXED RECESSED ONTO THE CEILING COFFER AS PER THE ARCHITECTURAL DETAIL. PROVIDE THE STRIP WITH REMOTE DALI DIMMABLE POWER SUPPLIES AS REQUIRED LOCATE THE POWER SUPPLIES IN A CONCEALED ACCESSIBLE POSITION NOTED ON THE AS CONSTRUCTED DOCUMENTS. CONFIRM THE BEND PLANE (TOP OR SIDE) ON SITE WITH THE ARCHITECT.	WHITE	RAPID LED R2321 OR R2322 - 2700K + POWER SUPPLY & DALI CONTROLLER	C
STRIP HEATER (H1)		2100 LONG LINEAR HEAT LAMP C/W CUSTOM SUPPORT AND INTEGRAL SWITCH MOUNTED AS PER THE ARCHITECTURAL DETAIL ALL CABLING IS TO BE CONCEALED	SILVER	ROBAND HQ2100E	A



ELECTRICAL DESIGN GROUP


ELECTRICAL BUILDING SERVICES CONSULTANTS

P.O. Box 15, SHERWOOD Q. 4075

Phone: (07) 3278 4375 Fax: (07) 3716 0222

Web Site: www.edg.net.au Email: brisbane@edg.net.au

C3457a - THE LION RICHLANDS - STAGE 2					C3457a-0002(C).xls
ELECTRICAL EQUIPMENT SCHEDULE					
REVISION C - 16 SEPTEMBER 2026					
THE LIGHT FITTING SUPPLIER CONTACT DETAILS MAY BE AVAILABLE ON THE EDG WEBSITE VIA THE FOLLOWING LINK www.edg.net.au/Links/Lighting.htm					
TYPE	LAMPS	DESCRIPTION	COLOUR / ACCESSORY	CATALOGUE No	REV
EXTERNAL HEATER (HR01)		WALL MOUNTED 2300w AREA HEATER LOCATED AT 2500 AFFL.	WHITE HEATER AND MOUNTING	BROMIC PLATINUM SMART HEAT ELECTRIC MARINE 2620251	A
E1	LED	EMERGENCY LIGHT: RECESSED NON-MAINTAINED EMERGENCY LIGHT. AS2293 CLASSIFICATION C0-D80 - C90-D80.	WHITE	CLEVERTRONICS CLIFE-PRO	A
E2	LED	EMERGENCY LIGHT: SURFACE MOUNTED ON THE UNDERSIDE OF THE TABLE TRAY SYSTEM NON-MAINTAINED EMERGENCY LIGHT. AS2293 CLASSIFICATION C0-D80 - C90-D80.	WHITE	CLEVERTRONICS CLIFE-PRO- SM	A
E3	LED	EMERGENCY LIGHT: SURFACE MOUNTED ON THE UNDERSIDE OF THE TABLE TRAY SYSTEM NON-MAINTAINED EMERGENCY LIGHT. AS2293 CLASSIFICATION C0-D80 - C90-D80.	BLACK	CLEVERTRONICS CLIFE-PRO- SM-BLK	A
EX BOH	LED	BACK OF HOUSE EXIT LIGHT: MAINTAINED 24M VIEWING DISTANCE EXIT LIGHT C/W DIFFUSERS & DIRECTIONAL ARROWS AS SHOWN. CEILING SURFACE MOUNT OR WALL MOUNT BETWEEN 2100mm & 2700mm AFFL IF THERE IS NO VERTICAL SURFACE TO MOUNT THE FITTING ON WITHIN THIS RANGE CONFIRM THE MOUNTING HEIGHT WITH THE ENGINEER.	WHITE	CLEVERTRONICS CCFLED	A
EX TH	LED	THEATRE MASK EXIT LIGHT: MAINTAINED 24M VIEWING DISTANCE EXIT LIGHT C/W DIFFUSERS & DIRECTIONAL ARROWS AS SHOWN. CEILING SURFACE MOUNT OR WALL MOUNT BETWEEN 2100mm & 2700mm AFFL IF THERE IS NO VERTICAL SURFACE TO MOUNT THE FITTING ON WITHIN THIS RANGE CONFIRM THE MOUNTING HEIGHT WITH THE ENGINEER.	BLACK	CLEVERTRONICS LSBLED -BLK THEATRE MASK	A
EX	LED	EXIT LIGHT: MAINTAINED 24M VIEWING DISTANCE EXIT LIGHT C/W DIFFUSERS & DIRECTIONAL ARROWS AS SHOWN. CEILING SURFACE MOUNT OR WALL MOUNT BETWEEN 2100mm & 2700mm AFFL IF THERE IS NO VERTICAL SURFACE TO MOUNT THE FITTING ON WITHIN THIS RANGE CONFIRM THE MOUNTING HEIGHT WITH THE ENGINEER.	WHITE	CLEVERTRONICS LSBLED	A
EMERGENCY PACK		LIGHT FITTINGS THAT ARE DESIGNATED AS BEING PROVIDED WITH AN EMERGENCY PACK ARE TO BE PROVIDED WITH AN INTEGRAL AS2293 EMERGENCY PACK. THE FITTINGS ARE TO BE NON MAINTAINED WITH ALL LAMPS SWITCHED AS PER THE LIGHTING CONTROL FOR THAT SPACE UNLESS NOTED OTHERWISE. REFER TO THE SPECIFICATION FOR FURTHER DETAILS OF THE CONFIGURATION AND SWITCHING OF EMERGENCY LIGHTS.			A
CHANNEL x		CONTROL CHANNEL WITH A NUMERICAL REFERENCE. REFER TO THE POWER AND LIGHTING CONTROL SCHEMATIC / SCHEDULE			A



ELECTRICAL DESIGN GROUP


ELECTRICAL BUILDING SERVICES CONSULTANTS

P.O. Box 15, SHERWOOD Q. 4075

Phone: (07) 3278 4375 Fax: (07) 3716 0222

Web Site: www.edg.net.au Email: brisbane@edg.net.au

C3457a - THE LION RICHLANDS - STAGE 2					C3457a-0002(C).xls
ELECTRICAL EQUIPMENT SCHEDULE					
REVISION C - 16 SEPTEMBER 2026					
THE LIGHT FITTING SUPPLIER CONTACT DETAILS MAY BE AVAILABLE ON THE EDG WEBSITE VIA THE FOLLOWING LINK www.edg.net.au/Links/Lighting.htm					
TYPE	LAMPS	DESCRIPTION	COLOUR / ACCESSORY	CATALOGUE No	REV
CEILING FAN 1 (F1)		1320 DIA COASTAL GRADE FAN WITH A DEDICATED WIRED WALL MOUNTED ON / OFF / SPEED CONTROLLER CONFIRM THE SUSPENSION HEIGHT OF THE FAN AND POSITION OF THE CONTROLLER WITH THE ARCHITECT ON SITE	WHITE	VENTAIR SPIN1304WH	A
ONE-WAY LIGHT SWITCH		ONE-WAY LIGHT SWITCH C/W CIRCUIT IDENTIFICATION ON THE FACEPLATE BEHIND THE SURROUND MOUNTED AT 1000mm AFFL UNLESS NOTED OTHERWISE.	WHITE	CLIPSAL C2000 SERIES 30USM	A
TWO-WAY LIGHT SWITCH		TWO -WAY LIGHT SWITCH C/W CIRCUIT IDENTIFICATION ON THE FACEPLATE BEHIND THE SURROUND MOUNTED AT 1000mm AFFL UNLESS NOTED OTHERWISE.	WHITE	CLIPSAL C2000 SERIES 30USM	A
LIGHTING CONTROL SWITCH PANEL (SPx)		6-BUTTON PROGRAMMABLE SWITCH PANEL C/W CENTRAL LCD DISPLAY MOUNTED AT 1000mm AFFL UNLESS NOTED OTHERWISE.	ALUMINIUM	DYNALITE ANTUMBRA DISPLAY	A
PROXIMITY DETECTOR SWITCH (PD)		ADJUSTABLE FLUSH RECESSED 360 DEGREE PIR PRESENCE DETECTOR TO OPERATE THE ASSOCIATED LIGHTS FOR A PRE-SET AMOUNT OF TIME. ADJUST THE TIME AND SENSITIVITY ON SITE AS DIRECTED BY THE ENGINEER. SUBMIT DETAILS OF THE MOVEMENT DETECTOR SWITCH FOR APPROVAL PRIOR TO ORDERING	WHITE	CLIPSAL	A
HAND DRYER CONNECTION (HD)		SINGLE POWER OUTLET C/W CIRCUIT IDENTIFICATION ON THE FACEPLATE BEHIND THE SURROUND FOR THE HAND DRYER MOUNT THE GPO AS PER THE ARCHITECTURAL DETAIL	WHITE UNLESS NOTED AS BLACK (BK)	CLIPSAL C2000 SERIES	A
SINGLE POWER OUTLET		SINGLE POWER OUTLET C/W CIRCUIT IDENTIFICATION ON THE FACEPLATE BEHIND THE SURROUND MOUNT AT 300mm AFFL U.N.O. RATING 10A U.N.O.	WHITE UNLESS NOTED AS BLACK (BK)	CLIPSAL C2000 SERIES	A
SINGLE POWER OUTLET AUTO DOOR (AD)		SINGLE POWER OUTLET C/W CIRCUIT IDENTIFICATION ON THE FACEPLATE BEHIND THE SURROUND MOUNT THE OUTLETS WITH IN THE AUTO DOOR MULLION SUCH THAT THE FLEX IS NOT VISIBLE	WHITE	CLIPSAL C2000 SERIES	A
SINGLE POWER OUTLET SUSPENDED (SUS)		POWER OUTLET SUSPENDED TO 1600 AFFL UNLESS NOTED OTHERWISE VIA A 3MM STAINLESS STEEL WIRE ROPE.	WHITE	CLIPSAL "56 SERIES"	A
DOUBLE POWER OUTLET		DOUBLE POWER OUTLET C/W CIRCUIT IDENTIFICATION ON THE FACEPLATE BEHIND THE SURROUND MOUNT AT 300mm AFFL U.N.O. RATING 10A U.N.O.	WHITE UNLESS NOTED AS BLACK (BK)	CLIPSAL C2000 SERIES	A
IP56 SINGLE POWER OUTLET		SINGLE POWER OUTLET IP56 MOUNT AT 300mm AFFL U.N.O. RATING 10A U.N.O.	GREY	CLIPSAL 56 SERIES	A



ELECTRICAL DESIGN GROUP

ELECTRICAL BUILDING SERVICES CONSULTANTS

P.O. Box 15, SHERWOOD Q. 4075


Phone: (07) 3278 4375 Fax: (07) 3716 0222

Web Site: www.edg.net.au Email: brisbane@edg.net.au

C3457a - THE LION RICHLANDS - STAGE 2					C3457a-0002(C).xls
ELECTRICAL EQUIPMENT SCHEDULE					
REVISION C - 16 SEPTEMBER 2026					
THE LIGHT FITTING SUPPLIER CONTACT DETAILS MAY BE AVAILABLE ON THE EDG WEBSITE VIA THE FOLLOWING LINK www.edg.net.au/Links/Lighting.htm					
TYPE	LAMPS	DESCRIPTION	COLOUR / ACCESSORY	CATALOGUE No	REV
DOUBLE POWER OUTLET (USB)		DOUBLE POWER OUTLET C/W USB CHARGER AND CIRCUIT IDENTIFICATION ON THE FACEPLATE BEHIND THE SURROUND MOUNT ABOVE BENCH U.N.O. RATING 10A U.N.O.	WHITE UNLESS NOTED AS BLACK (BK)	CLIPSAL C2000 SERIES + 30USBCM MECH	A
IP56 DOUBLE POWER OUTLET		DOUBLE POWER OUTLET IP56 MOUNT AT 300mm AFFL U.N.O. RATING 10A U.N.O.	GREY	CLIPSAL 56 SERIES	A
WEATHERPROOF POWER OUTLET (WP)		IP54 WEATHERPROOF SINGLE / DOUBLE POWER OUTLET AS NOTED ON DRAWING C/W COVER FLAP OVER SOCKET. MOUNT AT MINIMUM 1100mm AFFL U.N.O. RATING 10A U.N.O.	GREY	CLIPSAL WSC227/1-RG	A
SPECIAL PURPOSE OUTLET		SPECIAL PURPOSE OUTLET TYPE AS NOTED. MOUNT AT 1350mm AFFL U.N.O. RATING 20A U.N.O. CONNECT TO EQUIPMENT VIA FLEXIBLE CONDUIT.			A
SINGLE-PHASE ISOLATOR		SINGLE-PHASE WEATHERPROOF ISOLATOR. MOUNT AT 1350mm AFFL U.N.O. RATING 20A U.N.O. CONNECT TO EQUIPMENT VIA FLEXIBLE CONDUIT.	-	CLIPSAL WHT20	A
THREE-PHASE ISOLATOR		THREE-PHASE WEATHERPROOF ISOLATOR. MOUNT AT 1350mm AFFL U.N.O. RATING 20A U.N.O. CONNECT TO EQUIPMENT VIA FLEXIBLE CONDUIT.	-	CLIPSAL WHT35	A
THREE-PHASE ISOLATOR RSD		THREE-PHASE ISOLATOR. MOUNT AT HIGH LEVEL ADJACENT THE ROLLER SHUTTER DOOR CONTROLLER / MOTOR. COORDINATE THE POSITION ON SITE WITH THE ROLLER SHUTTER DOOR SUPPLIER CONNECT TO EQUIPMENT VIA FLEXIBLE CONDUIT.	-	CLIPSAL WHT35	A
SIGN CONNECTION		COORDINATE THE LOCATION AND CONNECTION WITH THE SIGN CONTRACTOR ENSURING THE GPO / ISOLATORS ARE PROVIDED WITH APPROPRIATE WEATHER PROTECTION AND ARE CONCEALED FROM VIEW.			A
FLOOR BOX 1 (FB1)		SURFACE MOUNTED FLOOR BOX C/W A WHITE DOUBLE GPO POWER POINT SOCKET W/ 2 X USB A & 1 X USB C ON ONE SIDE AND A DOUBLE COMMUNICATIONS OUTLET ON THE OTHER SIDE.	STAINLESS STEEL FLOOR BOX WHITE OUTLETS	ELECTRIC CABLE DUCT SYSTEMS AFB20 - 4C-SKU040.000.0117 GPO AND CLIPSAL C2000 COMMS OUTLET	A
TABLE BOX (TB1)		FLUSH RECESSED IN DESK BOX C/W FOUR 10 AMP GPO POWER POINT SOCKETS 2 X USB A CHARGING POINTS, 2 X USB C CHARGING POINTS AND 2 X COMMUNICATIONS OUTLETS.	WHITE	ELECTRIC CABLE DUCT SYSTEMS IDSO4P6D-SOLO	A
ELECTRICAL SERVICES POLE (SV)		PROVIDE EACH ELECTRICAL SERVICES POLE AS A ROUND (LESS THAN 100MM DIA) TWO CHANNEL POWDER COATED POLE FROM THE GAMING BASE TO THE CEILING TO PROVIDE POWER AND COMMUNICATIONS CABLING ACCESS FROM THE CEILING TO THE GAMING MACHINE BASE. PROVIDE A FLANGE AROUND THE POLE TO CONNECT IT TO THE BASE AND TO THE CEILING. THE ARCHITECT WILL CONFIRM THE COLOUR. (ALLOW FOR DULUX BRIGHT GOLD PEARL MATT 9717420Q IN COLOUR) SUBMIT DETAILS OF THE PROPOSED POLE FOR APPROVAL.			A

C3457a-0002(C).xls

Pages inc. any attach. 18 of 22



ELECTRICAL DESIGN GROUP


ELECTRICAL BUILDING SERVICES CONSULTANTS

P.O. Box 15, SHERWOOD Q. 4075

Phone: (07) 3278 4375 Fax: (07) 3716 0222

Web Site: www.edg.net.au Email: brisbane@edg.net.au

C3457a - THE LION RICHLANDS - STAGE 2					C3457a-0002(C).xls
ELECTRICAL EQUIPMENT SCHEDULE					
REVISION C - 16 SEPTEMBER 2026					
THE LIGHT FITTING SUPPLIER CONTACT DETAILS MAY BE AVAILABLE ON THE EDG WEBSITE VIA THE FOLLOWING LINK www.edg.net.au/Links/Lighting.htm					
TYPE	LAMPS	DESCRIPTION	COLOUR / ACCESSORY	CATALOGUE No	REV
SECURITY EQUIPMENT		SECURITY EQUIPMENT BY THE SECURITY CONTRACTOR.			A
DB-5		DISTRIBUTION BOARD DB-5 AS PER THE DB-5 SCHEDULE AND THE NOTES. REFER TO THE SCHEMATIC FOR DETAILS OF THE SUPPLY SUBMAIN. PROVIDE A SHOP DRAWING OF THE DISTRIBUTION BOARD FOR APPROVAL.			A
DB-6		DISTRIBUTION BOARD DB-6 AS PER THE DB-6 SCHEDULE AND THE NOTES. REFER TO THE SCHEMATIC FOR DETAILS OF THE SUPPLY SUBMAIN. PROVIDE A SHOP DRAWING OF THE DISTRIBUTION BOARD FOR APPROVAL.			A
DB-7		DISTRIBUTION BOARD DB-7 AS PER THE DB-7 SCHEDULE AND THE NOTES. REFER TO THE SCHEMATIC FOR DETAILS OF THE SUPPLY SUBMAIN. PROVIDE A SHOP DRAWING OF THE DISTRIBUTION BOARD FOR APPROVAL.			A
DB-8		DISTRIBUTION BOARD DB-8 AS PER THE DB-8 SCHEDULE AND THE NOTES. REFER TO THE SCHEMATIC FOR DETAILS OF THE SUPPLY SUBMAIN. PROVIDE A SHOP DRAWING OF THE DISTRIBUTION BOARD FOR APPROVAL.			A
DB-M		EXISTING DISTRIBUTION BOARD DB-M TO BE PROVIDED WITH THE MODIFICATIONS AND SWITCHGEAR AS PER THE DB-M SCHEDULE.			A
DB-K		EXISTING DISTRIBUTION BOARD DB-K TO BE PROVIDED WITH THE MODIFICATIONS AND SWITCHGEAR AS PER THE DB-K SCHEDULE.			A
DB-P		EXISTING DISTRIBUTION BOARD DB-P TO BE PROVIDED WITH THE MODIFICATIONS AND SWITCHGEAR AS PER THE DB-P SCHEDULE.			A
DB-G		EXISTING DISTRIBUTION BOARD DB-G REMOVE ALL EXISTING SWITCHGEAR MADE REDUNDANT BY THE WORKS.			A
DB-S		EXISTING DISTRIBUTION BOARD DB-S TO REMAIN AS IS.			A
DB-DS		EXISTING DISTRIBUTION BOARD DB-DS TO REMAIN AS IS.			A
DB-T		EXISTING DISTRIBUTION BOARD DB-T TO REMAIN AS IS.			A
DB-FIELD 2		EXISTING DISTRIBUTION BOARD DB-FIELD 2 TO REMAIN AS IS.			A
MANSFIELD		EXISTING DISTRIBUTION BOARD MANSFIELD TO REMAIN AS IS.			A
SOLAR		EXISTING SOLAR DISTRIBUTION BOARD TO REMAIN AS IS.			A
DB-FR		EXISTING DISTRIBUTION BOARD DB-FR TO BE REMOVED. ANY EXISTING CIRCUITS SUPPLIED FROM DB-FR ARE TO BE RESUPPLIED FROM DB-6 WITH NEW SWITCHGEAR.			A
DB-4		EXISTING DISTRIBUTION BOARD DB-4 TO REMAIN AS IS.			A
DB-DR		EXISTING DISTRIBUTION BOARD DB-DR TO REMAIN AS IS.			A



ELECTRICAL DESIGN GROUP


ELECTRICAL BUILDING SERVICES CONSULTANTS

P.O. Box 15, SHERWOOD Q. 4075

Phone: (07) 3278 4375 Fax: (07) 3716 0222

Web Site: www.edg.net.au Email: brisbane@edg.net.au

C3457a - THE LION RICHLANDS - STAGE 2					C3457a-0002(C).xls
ELECTRICAL EQUIPMENT SCHEDULE					
REVISION C - 16 SEPTEMBER 2026					
THE LIGHT FITTING SUPPLIER CONTACT DETAILS MAY BE AVAILABLE ON THE EDG WEBSITE VIA THE FOLLOWING LINK www.edg.net.au/Links/Lighting.htm					
TYPE	LAMPS	DESCRIPTION	COLOUR / ACCESSORY	CATALOGUE No	REV
DB-A		EXISTING DISTRIBUTION BOARD DB-A TO REMAIN AS IS.			A
DB-B		EXISTING DISTRIBUTION BOARD DB-B TO REMAIN AS IS.			A
MSB		EXISTING MAIN SWITCH BOARD TO BE PROVIDED WITH A SECOND SECTION AS PER THE SCHEMATIC AND NOTES.			A
MDB-1		EXISTING MAIN DISTRIBUTION BOARD TO BE PROVIDED WITH A SECOND SECTION AS PER THE SCHEMATIC AND NOTES.			A
MDB-2		EXISTING MAIN DISTRIBUTION BOARD TO REMAIN AS IS.			A
MSSB-1		EXISTING MECHANICAL SERVICES SWITCHBOARD TO REMAIN AS IS.			A
MSSB-2		EXISTING MECHANICAL SERVICES SWITCHBOARD TO REMAIN AS IS.			A
MSSB-3		EXISTING MECHANICAL SERVICES SWITCHBOARD TO REMAIN AS IS.			A
MSSB-4		NEW MECHANICAL SERVICES SWITCHBOARD PROVIDED BY THE MECHANICAL SUB CONTRACTOR. COORDINATE THE SUBMAIN CONNECTION WITH THE MECHANICAL SUB CONTRACTOR ON SITE.			A
REVENUE METER (M1)		EXISTING RETAIL METER TO REMAIN AS IS			A
PRIVATE METER (M2)		EXISTING PRIVATE MULTIFUNCTION TO REMAIN AS IS			A
PRIVATE METER (M3)		EXISTING PRIVATE MULTIFUNCTION TO REMAIN AS IS			A
REVENUE METER (M4)		NEW QECCM V4 COMPLIANT RETAIL METER			A
PRIVATE METER (M5)		NEW PRIVATE MULTIFUNCTION TO MATCH THE EXISTING M2 METER			A
PRIVATE METER (M6)		NEW PRIVATE MULTIFUNCTION TO MATCH THE EXISTING M3 METER			A
COMMUNICATIONS RACK (CR-6)		FREE STANDING 42 RU MINIMUM 800 DEEP 800 WIDE COMMUNICATIONS RACK CR-6 PROVIDE A SHOP DRAWING OF THE RACK INCLUDING THE ARRANGEMENT OF EQUIPMENT PROVIDED WITHIN IT AS PART OF THE CONTRACT FOR APPROVAL. PROVIDE THE RACK WITH THE REQUIRED CAT 6 PATCH PANELS, CABLE MANAGEMENT AND CASTERS. CONNECT A FIBER IN THE RACK VIA A 12 CORE OS3 OPTICAL FIBRE CABLE FULLY TERMINATED WITH LC CONNECTORS TO A NEW FIBER IN EXISTING MAIN SERVER RACK.		4 CABLING SKU 002.001.4280	A



ELECTRICAL DESIGN GROUP


ELECTRICAL BUILDING SERVICES CONSULTANTS

P.O. Box 15, SHERWOOD Q. 4075

Phone: (07) 3278 4375 Fax: (07) 3716 0222

Web Site: www.edg.net.au Email: brisbane@edg.net.au

C3457a - THE LION RICHLANDS - STAGE 2					C3457a-0002(C).xls
ELECTRICAL EQUIPMENT SCHEDULE					
REVISION C - 16 SEPTEMBER 2026					
THE LIGHT FITTING SUPPLIER CONTACT DETAILS MAY BE AVAILABLE ON THE EDG WEBSITE VIA THE FOLLOWING LINK www.edg.net.au/Links/Lighting.htm					
TYPE	LAMPS	DESCRIPTION	COLOUR / ACCESSORY	CATALOGUE No	REV
COMMUNICATIONS RACK (CR-7)		FREE STANDING 42 RU MINIMUM 800 DEEP 800 WIDE COMMUNICATIONS RACK CR-7 PROVIDE A SHOP DRAWING OF THE RACK INCLUDING THE ARRANGEMENT OF EQUIPMENT PROVIDED WITHIN IT AS PART OF THE CONTRACT FOR APPROVAL. PROVIDE THE RACK WITH THE REQUIRED CAT 6 PATCH PANELS, CABLE MANAGEMENT AND CASTERS. CONNECT A FOBOT IN THE RACK VIA A 12 CORE OS3 OPTICAL FIBRE CABLE FULLY TERMINATED WITH LC CONNECTORS TO A NEW FOBOT IN EXISTING MAIN SERVER RACK.		4 CABLING SKU 002.001.4280	A
GAMING RACK (CR-G)		FREE STANDING 42 RU MINIMUM 800 DEEP 800 WIDE GAMING RACK PROVIDE A SHOP DRAWING OF THE RACK INCLUDING THE ARRANGEMENT OF EQUIPMENT PROVIDED WITHIN IT AS PART OF THE CONTRACT FOR APPROVAL. PROVIDE THE RACK WITH THE REQUIRED CAT 6 PATCH PANELS, CABLE MANAGEMENT AND CASTERS. CONNECT A FOBOT IN THE RACK VIA A 12 CORE OS3 OPTICAL FIBRE CABLE FULLY TERMINATED WITH LC CONNECTORS TO A NEW FOBOT IN EXISTING MAIN GAMING RACK.		4 CABLING SKU 002.001.4280	A
COMMUNICATIONS OUTLET		RJ45 CAT-6 COMMUNICATIONS OUTLET, CABLED BACK TO CAT 6 PATCH PANELS IN ONE OF THE COMMUNICATIONS RACK VIA 4-PAIR CAT-6 UTP CABLE. MOUNT UP TO 3 RJ45 OUTLETS PER MULTI-GANG FACEPLATE WITH SEPARATE PERMANENT LABELLING FOR EACH OUTLET. MOUNT AT 300 AFFL. UNLESS NOTED OTHERWISE	WHITE UNLESS NOTED AS BLACK (BK)	CLIPSAL C2000 SERIES	A
CAT 6 GAMING OUTLET		RJ45 CAT-6 COMMUNICATIONS OUTLET, CABLED BACK TO CAT 6 DEDICATED GAMING PATCH PANELS IN ONE OF THE GAMING RACKS VIA 4-PAIR CAT-6 UTP CABLE. MOUNT UP TO 4 RJ45 OUTLETS PER MULTI-GANG FACEPLATE WITH SEPARATE PERMANENT LABELLING FOR EACH OUTLET. MOUNT AT 300 AFFL. UNLESS NOTED OTHERWISE	WHITE UNLESS NOTED AS BLACK (BK)	CLIPSAL C2000 SERIES	A
GAMING FIBRE (GF)		INSTALL DUPLEX FIBRE OPTIC CABLE BETWEEN THE POKER MACHINE BASES AND FROM THE POKER MACHINE BASES BACK TO THE GAMING RACK. THE DUPLEX FIBRE OPTIC CABLE WILL BE SUPPLIED AND TERMINATED BY OTHERS.			A
PIT P1		PROVIDE PIT 1 AS A POWER PIT AND A COMMUNICATIONS PIT. PROVIDE THE POWER PIT AS 450 X 450 CLEAR INTERNAL X 700 DEEP PLASTIC POWER PIT C/W A REINFORCED CONCRETE SURROUND AND A CLASS B STEEL LID WITH A SLIP RESISTANCE OF R10. PROVIDE THE COMMUNICATIONS PIT AS 350 X 350 CLEAR INTERNAL X 700 DEEP PLASTIC POWER PIT C/W A REINFORCED CONCRETE SURROUND AND A CLASS B STEEL LID WITH A SLIP RESISTANCE OF R10. PROVIDE THE POWER PIT LID WITH A PERMANENT LABEL ELECTRICITY THE COMMUNICATIONS PIT LID WITH A PERMEANT LABEL "COMMUNICATIONS". SUBMIT DETAILS OF THE PITS, LIDS, LABELS AND AN INSTALLATION SECTION FOR APPROVAL.			A
PIT P2		PROVIDE PIT 2 AS A POWER PIT AND A COMMUNICATIONS PIT. PROVIDE THE POWER PIT AS 450 X 450 CLEAR INTERNAL X 700 DEEP PLASTIC POWER PIT C/W A REINFORCED CONCRETE SURROUND AND A CLASS B STEEL LID WITH A SLIP RESISTANCE OF R10. PROVIDE THE COMMUNICATIONS PIT AS 350 X 350 CLEAR INTERNAL X 700 DEEP PLASTIC POWER PIT C/W A REINFORCED CONCRETE SURROUND AND A CLASS B STEEL LID WITH A SLIP RESISTANCE OF R10. PROVIDE THE POWER PIT LID WITH A PERMANENT LABEL ELECTRICITY THE COMMUNICATIONS PIT LID WITH A PERMEANT LABEL "COMMUNICATIONS". SUBMIT DETAILS OF THE PITS, LIDS, LABELS AND AN INSTALLATION SECTION FOR APPROVAL.			A



ELECTRICAL DESIGN GROUP

ELECTRICAL BUILDING SERVICES CONSULTANTS

P.O. Box 15, SHERWOOD Q. 4075

Phone: (07) 3278 4375 Fax: (07) 3716 0222

Web Site: www.edg.net.au Email: brisbane@edg.net.au

C3457a - THE LION RICHLANDS - STAGE 2

C3457a-0002(C).xls

ELECTRICAL EQUIPMENT SCHEDULE

REVISION C - 16 SEPTEMBER 2026

THE LIGHT FITTING SUPPLIER CONTACT DETAILS MAY BE AVAILABLE ON THE EDG WEBSITE VIA THE FOLLOWING LINK
www.edg.net.au/Links/Lighting.htm

TYPE	LAMPS	DESCRIPTION	COLOUR / ACCESSORY	CATALOGUE No	REV
PIT P3		PROVIDE PIT 3 AS A POWER PIT AND A COMMUNICATIONS PIT . PROVIDE THE POWER PIT AS 450 X 450 CLEAR INTERNAL X 700 DEEP PLASTIC POWER PIT C/W A REINFORCED CONCRETE SURROUND AND A CLASS B STEEL LID WITH A SLIP RESISTANCE OF R10. PROVIDE THE COMMUNICATIONS PIT AS 350 X 350 CLEAR INTERNAL X 700 DEEP PLASTIC POWER PIT C/W A REINFORCED CONCRETE SURROUND AND A CLASS B STEEL LID WITH A SLIP RESISTANCE OF R10. PROVIDE THE POWER PIT LID WITH A PERMANENT LABEL ELECTRICITY THE COMMUNICATIONS PIT LID WITH A PERMEANT LABEL "COMMUNICATIONS". SUBMIT DETAILS OF THE PITS, LIDS, LABELS AND AN INSTALLATION SECTION FOR APPROVAL.			A
PIT P4		PROVIDE PIT 4 AS A POWER PIT AND A COMMUNICATIONS PIT . PROVIDE THE POWER PIT AS 450 X 450 CLEAR INTERNAL X 700 DEEP PLASTIC POWER PIT C/W A REINFORCED CONCRETE SURROUND AND A CLASS B STEEL LID WITH A SLIP RESISTANCE OF R10. PROVIDE THE COMMUNICATIONS PIT AS 350 X 350 CLEAR INTERNAL X 700 DEEP PLASTIC POWER PIT C/W A REINFORCED CONCRETE SURROUND AND A CLASS B STEEL LID WITH A SLIP RESISTANCE OF R10. PROVIDE THE POWER PIT LID WITH A PERMANENT LABEL ELECTRICITY THE COMMUNICATIONS PIT LID WITH A PERMEANT LABEL "COMMUNICATIONS". SUBMIT DETAILS OF THE PITS, LIDS, LABELS AND AN INSTALLATION SECTION FOR APPROVAL.			A