

ELECTRICAL DESIGN GROUP

ELECTRICAL BUILDING SERVICES CONSULTANTS

P.O. Box 15, SHERWOOD Q. 4075

Phone: (07) 3278 4375 Fax: (07) 3716 0222

Web Site: www.edg.net.au Email: brisbane@edg.net.au


C3457a - THE LION RICHLANDS - STAGE 2

C3457a-0004(B).xls

LIGHTING CONTROL SCHEDULE

REVISION B - 17 JULY 2026

MISCELLANEOUS EQUIPMENT					REV
ITEM	DESCRIPTION				A
SP1	AS DETAILED IN THE EQUIPMENT SCHEDULE 6-BUTTON PROGRAMMABLE SWITCH PANEL C/W CENTRAL LCD DISPLAY DYNALITE ANTUMBRA DISPLAY ALUMINIUM				A
SP2	AS DETAILED IN THE EQUIPMENT SCHEDULE 6-BUTTON PROGRAMMABLE SWITCH PANEL C/W CENTRAL LCD DISPLAY DYNALITE ANTUMBRA DISPLAY ALUMINIUM				A
SP3	AS DETAILED IN THE EQUIPMENT SCHEDULE 6-BUTTON PROGRAMMABLE SWITCH PANEL C/W CENTRAL LCD DISPLAY DYNALITE ANTUMBRA DISPLAY ALUMINIUM				A
SP4	AS DETAILED IN THE EQUIPMENT SCHEDULE 6-BUTTON PROGRAMMABLE SWITCH PANEL C/W CENTRAL LCD DISPLAY DYNALITE ANTUMBRA DISPLAY ALUMINIUM				A
SP5	AS DETAILED IN THE EQUIPMENT SCHEDULE 6-BUTTON PROGRAMMABLE SWITCH PANEL C/W CENTRAL LCD DISPLAY DYNALITE ANTUMBRA DISPLAY ALUMINIUM				A
SP6	AS DETAILED IN THE EQUIPMENT SCHEDULE 6-BUTTON PROGRAMMABLE SWITCH PANEL C/W CENTRAL LCD DISPLAY DYNALITE ANTUMBRA DISPLAY ALUMINIUM				A
SP7	AS DETAILED IN THE EQUIPMENT SCHEDULE 6-BUTTON PROGRAMMABLE SWITCH PANEL C/W CENTRAL LCD DISPLAY DYNALITE ANTUMBRA DISPLAY ALUMINIUM				A
SP8	AS DETAILED IN THE EQUIPMENT SCHEDULE 6-BUTTON PROGRAMMABLE SWITCH PANEL C/W CENTRAL LCD DISPLAY DYNALITE ANTUMBRA DISPLAY ALUMINIUM				A
SP9	AS DETAILED IN THE EQUIPMENT SCHEDULE 6-BUTTON PROGRAMMABLE SWITCH PANEL C/W CENTRAL LCD DISPLAY DYNALITE ANTUMBRA DISPLAY ALUMINIUM				A
SP10	AS DETAILED IN THE EQUIPMENT SCHEDULE 6-BUTTON PROGRAMMABLE SWITCH PANEL C/W CENTRAL LCD DISPLAY DYNALITE ANTUMBRA DISPLAY ALUMINIUM				A
PE CELL	PROGRAMMABLE PE CELL DUS 90CS CONFIRM THE LOCATION ON SITE WITH THE ARCHITECT				A
TIME CLOCK	PROGRAMMABLE TIME CLOCK ENVISION GATEWAY PDEG C/W INTERNET ACCESS LOCATE DB-6				A
CONTROL MODULE 1					A
TYPE:		DYNALITE DDBC1200			A
DESCRIPTION		12CH BOARD CAST DALI CONTROLLER			A
LOCATION		DIN RAIL MOUNTED WITHIN DB-5			A
BUS:		A			A
CHANNEL	CONTROL	DESCRIPTION			A
		LOCATION	CIRCUIT	USE	A
5-1	DALI DIM		DB-5 - L1		A
5-2	DALI DIM		DB-5 - L1		A
5-3	DALI DIM		DB-5 - L2		A
5-4	DALI DIM		DB-5 - L2		A
5-5	DALI DIM		DB-5 - L2		A
5-6	DALI DIM		DB-5 - L3		A
5-7	DALI DIM		DB-5 - L4		A
5-8	DALI DIM		DB-5 - L4		A
5-9	DALI DIM		DB-5 - L4		A
5-10	DALI DIM		DB-5 - L4		A
5-11	DALI DIM		DB-5 - L5		A
5-12	DALI DIM		DB-5 - L5		A



ELECTRICAL DESIGN GROUP

ELECTRICAL BUILDING SERVICES CONSULTANTS

P.O. Box 15, SHERWOOD Q. 4075

Phone: (07) 3278 4375 Fax: (07) 3716 0222

Web Site: www.edg.net.au Email: brisbane@edg.net.au


C3457a - THE LION RICHLANDS - STAGE 2

C3457a-0004(B).xls

LIGHTING CONTROL SCHEDULE

REVISION B - 17 JULY 2026

CONTROL MODULE 2					A
TYPE:		DYNALITE DDBC1200			A
DESCRIPTION		12CH BOARD CAST DALI CONTROLLER			A
LOCATION		DIN RAIL MOUNTED WITHIN DB-5			A
BUS:		A			A
CHANNEL	CONTROL	DESCRIPTION			A
		LOCATION	CIRCUIT	USE	A
5-13	DALI DIM		DB-5 - L6		A
5-14	DALI DIM		DB-5 - L6		A
5-15	DALI DIM		DB-5 - L6		A
5-16	DALI DIM		DB-5 - L7		A
5-17	DALI DIM		DB-5 - L7		A
5-18	DALI DIM		DB-5 - L8		A
5-19	DALI DIM		DB-5 - L9		A
5-20	DALI DIM		DB-5 - L10		A
5-21	DALI DIM		DB-5 - L11		A
5-22	DALI DIM		DB-5 - L12		A
5-23	DALI DIM		DB-5 - L12		A
5-24	DALI DIM		DB-5 - L4		B
CONTROL MODULE 3					A
TYPE:		DYNALITE DDBC1200			A
DESCRIPTION		12CH BOARD CAST DALI CONTROLLER			A
LOCATION		DIN RAIL MOUNTED WITHIN DB-5			A
BUS:		A			A
CHANNEL	CONTROL	DESCRIPTION			A
		LOCATION	CIRCUITS	USE	A
5-25	DALI DIM		DB-5 - L13		A
5-26	DALI DIM		DB-5 - L13		A
5-27	DALI DIM		DB-5 - L13		A
5-28	DALI DIM		DB-5 - L13		A
5-29	DALI DIM		DB-5 - L13		A
5-30	DALI DIM		DB-5 - L16		A
5-31					A
5-32					A
5-33					A
5-34					A
5-35					A
5-36					A



ELECTRICAL DESIGN GROUP

ELECTRICAL BUILDING SERVICES CONSULTANTS

P.O. Box 15, SHERWOOD Q. 4075

Phone: (07) 3278 4375 Fax: (07) 3716 0222

Web Site: www.edg.net.au Email: brisbane@edg.net.au


C3457a - THE LION RICHLANDS - STAGE 2

C3457a-0004(B).xls


LIGHTING CONTROL SCHEDULE

REVISION B - 17 JULY 2026

CONTROL MODULE 4					A
TYPE:		DYNALITE DDRC1220FR-GL			A
DESCRIPTION		12 CH SWITCHING CONTROLLER			A
LOCATION		DIN RAIL MOUNTED WITHIN DB-5			A
BUS:		A			A
CHANNEL	CONTROL	DESCRIPTION			A
		LOCATION	CIRCUIT	USE	A
5-37	SWITCH		DB-5 - L14		A
5-38	SWITCH		DB-5 - L14		A
5-39	SWITCH	GAMING	DB-5 - L14		A
5-40	SWITCH	GAMING	DB-5 - L14		A
5-41	SWITCH	EXTERNAL	DB-5 - L7		A
5-42	SWITCH	GAMING	DB-5 - P42 TO DB-5 - P47	SIGN	A
5-43	SWITCH	GAMING	DB-5 - P48 TO DB-5 - P52	SIGN	A
5-44	SWITCH	CARPARK	DB-5 - L29		A
5-45	SWITCH	ROOF	DB-5 - L30		A
5-46	SWITCH	GAMING	DB-5 - L32		B
5-47					A
5-48					A
CONTROL MODULE 5					A
TYPE:		DYNALITE DDBC1200			A
DESCRIPTION		12CH BOARD CAST DALI CONTROLLER			A
LOCATION		DIN RAIL MOUNTED WITHIN DB-5			A
BUS:		A			A
CHANNEL	CONTROL	DESCRIPTION			A
		LOCATION	CIRCUITS	USE	A
5-49	DALI DIM		DB-5 - L15		A
5-50	DALI DIM		DB-5 - L15		B
5-51	DALI DIM		DB-5 - L15		B
5-52					A
5-53					A
5-54					A
5-55					A
5-56					A
5-57					A
5-58					A
5-59					A
5-60					A

**C3457a - THE LION RICHLANDS - STAGE 2****C3457a-0004(B).xls****LIGHTING CONTROL SCHEDULE****REVISION B - 17 JULY 2026**

CONTROL MODULE 6					A
TYPE:		DYNALITE DDBC1200			A
DESCRIPTION		12CH BOARD CAST DALI CONTROLLER			A
LOCATION		DIN RAIL MOUNTED WITHIN DB-6			A
BUS:		A			A
CHANNEL	CONTROL	DESCRIPTION			A
		LOCATION	CIRCUITS	USE	A
6-1	DALI DIM		DB-6 - L13		A
6-2	DALI DIM		DB-6 - L13		A
6-3	DALI DIM		DB-6 - L13		A
6-4	DALI DIM		DB-6 - L13		A
6-5	DALI DIM		DB-6 - L13		A
6-6	DALI DIM		DB-6 - L14		A
6-7	DALI DIM		DB-6 - L14		A
6-8	DALI DIM		DB-6 - L15		A
6-9	DALI DIM		DB-6 - L15		A
6-10	DALI DIM		DB-6 - L15		A
6-11	DALI DIM		DB-6 - L15		A
6-12	DALI DIM		DB-6 - L15		A
CONTROL MODULE 7					A
TYPE:		DYNALITE DDBC1200			A
DESCRIPTION		12CH BOARD CAST DALI CONTROLLER			A
LOCATION		DIN RAIL MOUNTED WITHIN DB-6			A
BUS:		A			A
CHANNEL	CONTROL	DESCRIPTION			A
		LOCATION	CIRCUITS	USE	A
6-13	DALI DIM		DB-6 - L16		A
6-14	DALI DIM		DB-6 - L16		A
6-15	DALI DIM		DB-6 - L16		A
6-16	DALI DIM		DB-6 - L17		A
6-17	DALI DIM		DB-6 - L17		A
6-18	DALI DIM		DB-6 - L17		A
6-19	DALI DIM		DB-6 - L17		A
6-20	DALI DIM		DB-6 - L18		A
6-21	DALI DIM		DB-6 - L18		A
6-22	DALI DIM		DB-6 - L18		A
6-23	DALI DIM		DB-6 - L18		A
6-24					A



ELECTRICAL DESIGN GROUP

ELECTRICAL BUILDING SERVICES CONSULTANTS

P.O. Box 15, SHERWOOD Q. 4075

Phone: (07) 3278 4375 Fax: (07) 3716 0222

Web Site: www.edg.net.au Email: brisbane@edg.net.au


C3457a - THE LION RICHLANDS - STAGE 2

C3457a-0004(B).xls

LIGHTING CONTROL SCHEDULE

REVISION B - 17 JULY 2026

CONTROL MODULE 8					A
TYPE:		DYNALITE DDBC1200			A
DESCRIPTION		12CH BOARD CAST DALI CONTROLLER			A
LOCATION		DIN RAIL MOUNTED WITHIN DB-6			A
BUS:		A			A
CHANNEL	CONTROL	DESCRIPTION			A
		LOCATION	CIRCUITS	USE	A
6-25	DALI DIM		DB-6 - L19		A
6-26	DALI DIM		DB-6 - L19		A
6-27	DALI DIM		DB-6 - L19		B
6-28	DALI DIM		DB-6 - L19		B
6-29	DALI DIM		DB-6 - L20		A
6-30	DALI DIM		DB-6 - L20		A
6-31	DALI DIM		DB-6 - L20		A
6-32	DALI DIM		DB-6 - L20		A
6-33	DALI DIM		DB-6 - L20		A
6-34	DALI DIM		DB-6 - L21		A
6-35	DALI DIM		DB-6 - L21		A
6-36	DALI DIM		DB-6 - L21		A
CONTROL MODULE 9					A
TYPE:		DYNALITE DDBC1200			A
DESCRIPTION		12CH BOARD CAST DALI CONTROLLER			A
LOCATION		DIN RAIL MOUNTED WITHIN DB-6			A
BUS:		A			A
CHANNEL	CONTROL	DESCRIPTION			A
		LOCATION	CIRCUIT	USE	A
6-37	DALI DIM		DB-6 - L21		A
6-38	DALI DIM		DB-6 - L22		A
6-39	DALI DIM		DB-6 - L22		A
6-40	DALI DIM		DB-6 - L22		A
6-41	DALI DIM		DB-6 - L23		A
6-42	DALI DIM		DB-6 - L23		A
6-43	DALI DIM		DB-6 - L23		A
6-44	DALI DIM		DB-6 - L23		A
6-45	DALI DIM		DB-6 - L23		A
6-46	DALI DIM		DB-6 - L23		A
6-47	DALI DIM		DB-6 - L22		A
6-48					A



ELECTRICAL DESIGN GROUP

ELECTRICAL BUILDING SERVICES CONSULTANTS

P.O. Box 15, SHERWOOD Q. 4075

Phone: (07) 3278 4375 Fax: (07) 3716 0222

Web Site: www.edg.net.au Email: brisbane@edg.net.au


C3457a - THE LION RICHLANDS - STAGE 2

C3457a-0004(B).xls

LIGHTING CONTROL SCHEDULE

REVISION B - 17 JULY 2026

CONTROL MODULE 10					A
TYPE:		DYNALITE DDBC1200			A
DESCRIPTION		12CH BOARD CAST DALI CONTROLLER			A
LOCATION		DIN RAIL MOUNTED WITHIN DB-6			A
BUS:		A			A
CHANNEL	CONTROL	DESCRIPTION			A
		LOCATION	CIRCUITS	USE	A
6-49	DALI DIM		DB-6 - L24		A
6-50	DALI DIM		DB-6 - L24		A
6-51	DALI DIM		DB-6 - L24		A
6-52	DALI DIM		DB-6 - L24		A
6-53	DALI DIM		DB-6 - L25		A
6-54	DALI DIM		DB-6 - L26		A
6-55	DALI DIM		DB-6 - L26		A
6-56	DALI DIM		DB-6 - L26		A
6-57	DALI DIM		DB-6 - L26		A
6-58	DALI DIM		DB-6 - L26		A
6-59	DALI DIM		DB-6 - L26		A
6-60					A
CONTROL MODULE 11					A
TYPE:		DYNALITE DDRC1220FR-GL			A
DESCRIPTION		12 CH SWITCHING CONTROLLER			A
LOCATION		DIN RAIL MOUNTED WITHIN DB-6			A
BUS:		A			A
CHANNEL	CONTROL	DESCRIPTION			A
		LOCATION	CIRCUITS	USE	A
6-61	SWITCH		DB-6 - L27		A
6-62	SWITCH		DB-6 - L27		A
6-63	SWITCH		DB-6 - L27		A
6-64	SWITCH		DB-6 - L27		A
6-65	SWITCH		DB-6 - L28		A
6-66	SWITCH		DB-6 - L28		A
6-67	SWITCH		DB-6 - L28		A
6-68	SWITCH		DB-6 - L35		A
6-69					A
6-70					A
6-71					A
6-72					A



ELECTRICAL DESIGN GROUP

ELECTRICAL BUILDING SERVICES CONSULTANTS

P.O. Box 15, SHERWOOD Q. 4075

Phone: (07) 3278 4375 Fax: (07) 3716 0222

Web Site: www.edg.net.au Email: brisbane@edg.net.au


C3457a - THE LION RICHLANDS - STAGE 2

C3457a-0004(B).xls

LIGHTING CONTROL SCHEDULE

REVISION B - 17 JULY 2026

CONTROL MODULE 12					A
TYPE:		DYNALITE DDMC802			A
DESCRIPTION		8CH MODULAR CONTROLLER			A
LOCATION		DIN RAIL MOUNTED WITHIN DB-6			A
BUS:		A			A
CHANNEL	CONTROL	DESCRIPTION			A
		LOCATION	CIRCUIT	USE	A
6-73	DGTM202		DB-6 -L29		A
6-74					A
6-75	DGTM202				A
6-76					A
6-77	DGTM202				A
6-78					A
6-79					A
6-80					A
CONTROL MODULE 13					A
TYPE:		DYNALITE DDMC802			A
DESCRIPTION		8CH MODULAR CONTROLLER			A
LOCATION		DIN RAIL MOUNTED WITHIN DB-6			A
BUS:		A			A
CHANNEL	CONTROL	DESCRIPTION			A
		LOCATION	CIRCUIT	USE	A
6-81	DGTM202		DB-6 -L30		A
6-82					A
6-83	DGTM202				A
6-84					A
6-85	DGTM202				A
6-86					A
6-87					A
6-88					A



ELECTRICAL DESIGN GROUP

ELECTRICAL BUILDING SERVICES CONSULTANTS

P.O. Box 15, SHERWOOD Q. 4075

Phone: (07) 3278 4375 Fax: (07) 3716 0222

Web Site: www.edg.net.au Email: brisbane@edg.net.au


C3457a - THE LION RICHLANDS - STAGE 2

C3457a-0004(B).xls

LIGHTING CONTROL SCHEDULE

REVISION B - 17 JULY 2026

CONTROL MODULE 14					A
TYPE:		DYNALITE DDMC802			A
DESCRIPTION		8CH MODULAR CONTROLLER			A
LOCATION		DIN RAIL MOUNTED WITHIN DB-6			A
BUS:		A			A
CHANNEL	CONTROL	DESCRIPTION			A
		LOCATION	CIRCUIT	USE	A
6-89	DGTM202		DB-6 -L31		A
6-90					A
6-91	DGTM202				A
6-92					A
6-93					A
6-94					A
6-95					A
6-96					A
CONTROL MODULE 15					A
TYPE:		DYNALITE DDBC1200			A
DESCRIPTION		12CH BOARD CAST DALI CONTROLLER			A
LOCATION		DIN RAIL MOUNTED WITHIN DB-6			A
BUS:		A			A
CHANNEL	CONTROL	DESCRIPTION			A
		LOCATION	CIRCUITS	USE	A
6-97	DALI DIM		DB-6 - L32		A
6-98					A
6-99					A
6-100					A
6-101					A
6-102					A
6-103					A
6-104					A
6-105					A
6-106					A
6-107					A
6-108					A



ELECTRICAL DESIGN GROUP

ELECTRICAL BUILDING SERVICES CONSULTANTS

P.O. Box 15, SHERWOOD Q. 4075

Phone: (07) 3278 4375 Fax: (07) 3716 0222

Web Site: www.edg.net.au Email: brisbane@edg.net.au


C3457a - THE LION RICHLANDS - STAGE 2

C3457a-0004(B).xls

LIGHTING CONTROL SCHEDULE

REVISION B - 17 JULY 2026

CONTROL MODULE 16					A
TYPE:		DYNALITE DDRC1220FR-GL			A
DESCRIPTION		12 CH SWITCHING CONTROLLER			A
LOCATION		DIN RAIL MOUNTED WITHIN DB-7			A
BUS:		A			A
CHANNEL	CONTROL	DESCRIPTION			A
		LOCATION	CIRCUIT	USE	A
7-1	SWITCH		DB-7 - L9	SIGN	A
7-2	SWITCH		DB-7 - L9		A
7-3	SWITCH		DB-7 - L9		A
7-4	SWITCH		DB-7 - L9		A
7-5	SWITCH		DB-7 - L9		A
7-6	SWITCH		DB-7 - L9		A
7-7	SWITCH		DB-7 - L16	CARPARK	B
7-8	SWITCH		DB-7 - L17	CARPARK	B
7-9	SWITCH		DB-7 - L17	CARPARK	A
7-10					A
7-11					A
7-12					A
CONTROL MODULE 17					A
TYPE:		DYNALITE DDBC1200			A
DESCRIPTION		12CH BOARD CAST DALI CONTROLLER			A
LOCATION		DIN RAIL MOUNTED WITHIN DB-7			A
BUS:		A			A
CHANNEL	CONTROL	DESCRIPTION			A
		LOCATION	CIRCUITS	USE	A
7-13	DALI DIM		DB-7 - L10		A
7-14	DALI DIM		DB-7 - L10		A
7-15	DALI DIM		DB-7 - L11		A
7-16	DALI DIM		DB-7 - L11		A
7-17	DALI DIM		DB-7 - L12		A
7-18	DALI DIM		DB-7 - L13		A
7-19	DALI DIM		DB-7 - L13		A
7-20	DALI DIM		DB-7 - L13		A
7-21	DALI DIM		DB-7 - L13		A
7-22					A
7-23					A
7-24					A



ELECTRICAL DESIGN GROUP

ELECTRICAL BUILDING SERVICES CONSULTANTS

P.O. Box 15, SHERWOOD Q. 4075

Phone: (07) 3278 4375 Fax: (07) 3716 0222

Web Site: www.edg.net.au Email: brisbane@edg.net.au


C3457a - THE LION RICHLANDS - STAGE 2

C3457a-0004(B).xls

LIGHTING CONTROL SCHEDULE

REVISION B - 17 JULY 2026

CONTROL MODULE 18					A
TYPE:		DYNALITE DDBC1200			A
DESCRIPTION		12CH BOARD CAST DALI CONTROLLER			A
LOCATION		DIN RAIL MOUNTED WITHIN DB-7			A
BUS:		A			A
CHANNEL	CONTROL	DESCRIPTION			A
		LOCATION	CIRCUITS	USE	A
7-25	DALI DIM		DB-7 - L14		A
7-26	DALI DIM		DB-7 - L14		A
7-27	DALI DIM		DB-7 - L14		A
7-28	DALI DIM		DB-7 - L14		A
7-29					A
7-30					A
7-31					A
7-32					A
7-33					A
7-34					A
7-35					A
7-36					A
CONTROL MODULE 19					A
TYPE:		DYNALITE DDRC1220FR-GL			A
DESCRIPTION		12 CH SWITCHING CONTROLLER			A
LOCATION		DIN RAIL MOUNTED WITHIN DB-8			A
BUS:		A			A
CHANNEL	CONTROL	DESCRIPTION			A
		LOCATION	CIRCUIT	USE	A
8-1	SWITCH		DB-8 - L3	SIGN	A
8-2	SWITCH		DB-8 - L3		A
8-3	SWITCH		DB-8 - L3		A
8-4					A
8-5					A
8-6					A
8-7					A
8-8					A
8-9					A
8-10					A
8-11					A
8-12					A



ELECTRICAL DESIGN GROUP

ELECTRICAL BUILDING SERVICES CONSULTANTS

P.O. Box 15, SHERWOOD Q. 4075

Phone: (07) 3278 4375 Fax: (07) 3716 0222

Web Site: www.edg.net.au Email: brisbane@edg.net.au


C3457a - THE LION RICHLANDS - STAGE 2

C3457a-0004(B).xls


LIGHTING CONTROL SCHEDULE

REVISION B - 17 JULY 2026

CONTROL MODULE 20					A
TYPE:		DYNALITE DDBC1200			A
DESCRIPTION		12CH BOARD CAST DALI CONTROLLER			A
LOCATION		DIN RAIL MOUNTED WITHIN DB-8			A
BUS:		A			A
CHANNEL	CONTROL	DESCRIPTION			A
		LOCATION	CIRCUITS	USE	A
8-13	DALI DIM		DB-8 - L4		A
8-14	DALI DIM		DB-8 - L4		A
8-15	DALI DIM		DB-8 - L4		A
8-16	DALI DIM		DB-8 - L4		A
8-17	DALI DIM		DB-8 - L4		A
8-18	DALI DIM		DB-8 - L5		A
8-19	DALI DIM		DB-8 - L5		A
8-20	DALI DIM		DB-8 - L6		A
8-21	DALI DIM		DB-8 - L6		A
8-22	DALI DIM		DB-8 - L7		A
8-23	DALI DIM		DB-8 - L7		A
8-24					A
CONTROL MODULE 21					A
TYPE:		DYNALITE DDBC1200			A
DESCRIPTION		12CH BOARD CAST DALI CONTROLLER			A
LOCATION		DIN RAIL MOUNTED WITHIN DB-8			A
BUS:		A			A
CHANNEL	CONTROL	DESCRIPTION			A
		LOCATION	CIRCUITS	USE	A
8-25	DALI DIM		DB-8 - L8		A
8-26	DALI DIM		DB-8 - L8		A
8-27	DALI DIM		DB-8 - L8		A
8-28	DALI DIM		DB-8 - L9		A
8-29	DALI DIM		DB-8 - L9		A
8-30					A
8-31					A
8-32					A
8-33					A
8-34					A
8-35					A
8-36					A

**C3457a - THE LION RICHLANDS - STAGE 2****C3457a-0004(B).xls****LIGHTING CONTROL SCHEDULE****REVISION B - 17 JULY 2026**

CONTROL MODULE 22					A
TYPE:		DYNALITE DDRC1220FR-GL			A
DESCRIPTION		12 CH SWITCHING CONTROLLER			A
LOCATION		DIN RAIL MOUNTED WITHIN A NEW CNCLOSURE ADJACENTY DB-M			A
BUS:		A			A
CHANNEL	CONTROL	DESCRIPTION			A
		LOCATION	CIRCUIT	USE	A
M-1	SWITCH		DB-M - L1		A
M-2	SWITCH		DB-M - L2		A
M-3	SWITCH		DB-M - L3		A
M-4	SWITCH		DB-M - L4		A
M-5	SWITCH		DB-M - L5		A
M-6	SWITCH		DB-M - L6		A
M-7					A
M-8					A
M-9					A
M-10					A
M-11					A
M-12					A
CONTROL MODULE 23					A
TYPE:		DYNALITE DDBC1200			A
DESCRIPTION		12CH BOARD CAST DALI CONTROLLER			A
LOCATION		DIN RAIL MOUNTED WITHIN A NEW CNCLOSURE ADJACENTY DB-M			A
BUS:		A			A
CHANNEL	CONTROL	DESCRIPTION			A
		LOCATION	CIRCUITS		A
M-13	DALI DIM		DB-M - L13		A
M-14	DALI DIM		DB-M - L13		A
M-15	DALI DIM		DB-M - L13		A
M-16	DALI DIM		DB-M - L13		A
M-17					A
M-18					A
M-19					A
M-20					A
M-21					A
M-22					A
M-23					A
M-24					A



ELECTRICAL DESIGN GROUP

ELECTRICAL BUILDING SERVICES CONSULTANTS

P.O. Box 15, SHERWOOD Q. 4075

Phone: (07) 3278 4375 Fax: (07) 3716 0222

Web Site: www.edg.net.au Email: brisbane@edg.net.au

C3457a - THE LION RICHLANDS - STAGE 2

C3457a-0004(B).xls

LIGHTING CONTROL SCHEDULE

REVISION B - 17 JULY 2026

CONTROL MODULE 24					A
TYPE:		DYNALITE DDRC1220FR-GL			A
DESCRIPTION		12 CH SWITCHING CONTROLLER			A
LOCATION		DIN RAIL MOUNTED WITHIN DB-P IT IS ACCEPTABLE TO UTILISE AN EXISTING RELAY CONTROLLER IF AVAILABLE			A
BUS:		A			A
CHANNEL	CONTROL	DESCRIPTION			A
		LOCATION	CIRCUIT	USE	A
P-1	SWITCH VIA CONTACTORS	GAMING	DB-P - P43 TO DB-P - P 52	SIGNS	A
P-2	SWITCH VIA CONTACTORS	GAMING	DB-P - P53 TO DB-P - P 60	SINGS	A
P-3					A
P-4					A
P-5					A
P-6					A
P-7					A
P-8					A
P-9					A
P-10					A
P-11					A
P-12					A