



ELECTRICAL DESIGN GROUP

ELECTRICAL BUILDING SERVICES CONSULTANTS

P.O. Box 15, SHERWOOD Q. 4075

Phone: (07) 3278 4375

Website: www.edg.net.au Email: brisbane@edg.net.au

C3457a - THE LION RICHLANDS - STAGE 2

C3457a-0009(B).xls

DISTRIBUTION BOARD DB-M

REVISION B - 17 July 2026

							REV
PROVIDE THE FOLLOWING ADDITIONAL SWITCHGEAR WITHIN THE EXISTING DB-M. THE SWITCHGEAR TYPE IS TO MATCH THE EXISTING USED IN DB-M.							A
CIRC	PH	CIRCUIT BREAKER (amps)	CONTROL EQUIPMENT	CABLE SIZE (mm ²)	LOCATION	CIRCUIT USE	
P1	1	20	RCBO	2.5		CLEANING	A
P2	1	20	RCBO	2.5		AUTODOOR	A
L1	1	20	RCBO	2.5		LIGHTS	A
L2	1	20	RCBO	2.5		LIGHTS	A
L3							B
L4	3	20	RCBO	2.5		LIGHTS	A
L5	1	20	RCBO	2.5		LIGHTS	A
L6	1	20	RCBO	2.5		LIGHTS	A
L7	1	20	RCBO	2.5		HEATERS	A
L8	1	20	RCBO	2.5		HEATERS	A
L9	1	20	RCBO	2.5		HEATERS	A
L10	1	20	RCBO	2.5		FANS	A
L11	1	20	RCBO	2.5		FANS	A
L12	1	20	RCBO	2.5		LOUVERS	A
L13	1	20	RCBO	2.5		LIGHTS	A