



# ELECTRICAL DESIGN GROUP

ELECTRICAL BUILDING SERVICES CONSULTANTS

P.O. Box 15, SHERWOOD Q. 4075

Phone: (07) 3278 4375 Fax: (07) 3716 0222

Web Site: [www.edg.net.au](http://www.edg.net.au) Email: [brisbane@edg.net.au](mailto:brisbane@edg.net.au)

C3556a - ROYAL HOTEL, BEENLEIGH

C3556a-0002(B).xls

## ELECTRICAL EQUIPMENT SCHEDULE

REVISION B - 18 JUNE 2025

THE LIGHT FITTING SUPPLIER CONTACT DETAILS MAY BE AVAILABLE ON THE EDG WEBSITE VIA THE FOLLOWING LINK  
[www.edg.net.au/Links/Lighting.htm](http://www.edg.net.au/Links/Lighting.htm)

TYPE	LAMPS	DESCRIPTION	COLOUR / ACCESSORY	CATALOGUE No	REV
L1		GAMING BASE KICK LED STRIP LIGHTS TO BE PROVIDED AS PART OF THE GAMING BASE.			B
L2	12W/M 2700K LED	FLEXIBLE LED ROPE FLEX SCREW FIXED RECESSED INTO THE JOINERY PELMET AS PER THE ARCHITECTURAL DETAIL. PROVIDE THE L2 STRIP WITH REMOTE DALI DIMMABLE POWER SUPPLIES AS REQUIRED LOCATE THE POWER SUPPLIES IN A CONCEALED ACCESSIBLE POSITION NOTED ON THE AS CONSTRUCTED DOCUMENTS.	WHITE	NPA L-NF-GLOW-VWW + POWER SUPPLY & DALI CONTROLLER	A
L3	880LM /M 3000K 24V LED	LED STRIP LIGHT IN A SCREW FIXED EXTRUSION C/W OPAL DIFFUSER MOUNTED BEHIND THE TV ALONG ALL FOUR SIDES AS PER THE ARCHITECTURAL DETAIL. PROVIDE THE L3 WITH A REMOTE DALI DIMMABLE POWER SUPPLY LOCATED IN A CONCEALED ACCESSIBLE POSITION NOTED ON THE AS CONSTRUCTED DOCUMENTS.	NATURAL	MELEC ML-ALU-1407-2M - ML-VLCRI-14.4-WWW	A
L4	880LM /M 3000K 24V LED	LED STRIP LIGHT IN A SCREW FIXED EXTRUSION C/W OPAL DIFFUSER MOUNTED IN THE GAMING CEILING PELMET AS PER THE ARCHITECTURAL DETAIL. PROVIDE EACH GROUP OF L4 STRIP WITH REMOTE DALI DIMMABLE POWER SUPPLIES AS REQUIRED LOCATE THE POWER SUPPLIES IN A CONCEALED ACCESSIBLE POSITION NOTED ON THE AS CONSTRUCTED DOCUMENTS.	NATURAL	MELEC ML-ALU-1407-2M - ML-VLCRI-14.4-WWW	A
L5	12W/M 2700K LED	FLEXIBLE LED ROPE FLEX SCREW FIXED RECESSED INTO THE ENTRY CEILING PELMET AS PER THE ARCHITECTURAL DETAIL. PROVIDE THE L5 STRIP WITH REMOTE DALI DIMMABLE POWER SUPPLIES AS REQUIRED LOCATE THE POWER SUPPLIES IN A CONCEALED ACCESSIBLE POSITION NOTED ON THE AS CONSTRUCTED DOCUMENTS.	WHITE	NPA L-NF-GLOW-VWW + POWER SUPPLY & DALI CONTROLLER	A
L6	880LM /M 3000K 24V LED	LED STRIP LIGHT IN A SCREW FIXED EXTRUSION C/W OPAL DIFFUSER MOUNTED IN THE GAMING CEILING PELMET AS PER THE ARCHITECTURAL DETAIL. PROVIDE EACH GROUP OF L6 STRIP WITH REMOTE DALI DIMMABLE POWER SUPPLIES AS REQUIRED LOCATE THE POWER SUPPLIES IN A CONCEALED ACCESSIBLE POSITION NOTED ON THE AS CONSTRUCTED DOCUMENTS.	NATURAL	MELEC ML-ALU-1407-2M - ML-VLCRI-14.4-WWW	A
L7	12W/M 2700K LED	FLEXIBLE LED ROPE FLEX SCREW FIXED RECESSED INTO THE TOP OF THE JOINERY SEAT AS PER THE ARCHITECTURAL DETAIL. PROVIDE THE L7 STRIP WITH REMOTE DALI DIMMABLE POWER SUPPLIES AS REQUIRED LOCATE THE POWER SUPPLIES IN A CONCEALED ACCESSIBLE POSITION NOTED ON THE AS CONSTRUCTED DOCUMENTS.	WHITE	NPA L-NF-GLOW-VWW + POWER SUPPLY & DALI CONTROLLER	A



# ELECTRICAL DESIGN GROUP

ELECTRICAL BUILDING SERVICES CONSULTANTS

P.O. Box 15, SHERWOOD Q. 4075

Phone: (07) 3278 4375 Fax: (07) 3716 0222

Web Site: [www.edg.net.au](http://www.edg.net.au) Email: [brisbane@edg.net.au](mailto:brisbane@edg.net.au)

C3556a - ROYAL HOTEL, BEENLEIGH

C3556a-0002(B).xls

## ELECTRICAL EQUIPMENT SCHEDULE

REVISION B - 18 JUNE 2025

THE LIGHT FITTING SUPPLIER CONTACT DETAILS MAY BE AVAILABLE ON THE EDG WEBSITE VIA THE FOLLOWING LINK  
[www.edg.net.au/Links/Lighting.htm](http://www.edg.net.au/Links/Lighting.htm)

TYPE	LAMPS	DESCRIPTION	COLOUR / ACCESSORY	CATALOGUE No	REV
L8	880LM /M 3000K 24V LED	LED STRIP LIGHT IN A SCREW FIXED EXTRUSION C/W OPAL DIFFUSER MOUNTED IN THE COUNTER PELMET AS PER THE ARCHITECTURAL DETAIL. PROVIDE EACH GROUP OF L8 STRIP WITH REMOTE DALI DIMMABLE POWER SUPPLIES AS REQUIRED LOCATE THE POWER SUPPLIES IN A CONCEALED ACCESSIBLE POSITION NOTED ON THE AS CONSTRUCTED DOCUMENTS.	NATURAL	MELEC ML-ALU-1407-2M - ML-VLCRI-14.4-WW	A
L9	880LM /M 3000K 24V LED	MULTIPLE HORIZONTAL RUNS OF LED STRIP LIGHT IN A SCREW FIXED EXTRUSION C/W OPAL DIFFUSER FLUSH RECESSED INTO THE REAR BAR JOINERY AS PER THE ARCHITECTURAL DETAIL. REFER TO THE ELEVATIONS FOR THE NUMBER OF RUNS AND LENGTHS. PROVIDE REMOTE DALI DIMMABLE POWER SUPPLIES AS REQUIRED LOCATE THE POWER SUPPLIES IN A CONCEALED ACCESSIBLE POSITION NOTED ON THE AS CONSTRUCTED DOCUMENTS. IT IS ACCEPTABLE TO SUPPLY MULTIPLE L9 SECTIONS FROM A SINGLE SUITABLY SIZED DRIVER	NATURAL	MELEC ML-ALU-1407-2M - ML-VLCRI-14.4-WW	A
L10	12W/M 2700K LED	FLEXIBLE LED ROPE FLEX SCREW FIXED RECESSED INTO THE COUNTER PELMET AS PER THE ARCHITECTURAL DETAIL. PREFER TO THE ELEVATIONS FOR THE NUMBER OF RUNS AND LENGTHS. PROVIDE REMOTE DALI DIMMABLE POWER SUPPLIES AS REQUIRED LOCATE THE POWER SUPPLIES IN A CONCEALED ACCESSIBLE POSITION NOTED ON THE AS CONSTRUCTED DOCUMENTS. IT IS ACCEPTABLE TO SUPPLY MULTIPLE L10 SECTIONS FROM A SINGLE SUITABLY SIZED DRIVER	WHITE	NPA L-NF-GLOW-VWW + POWER SUPPLY & DALI CONTROLLER	A
L11	12W/M 2700K LED	FLEXIBLE LED ROPE FLEX SCREW FIXED RECESSED INTO THE JOINERY AS PER THE ARCHITECTURAL DETAIL. PROVIDE THE L11 STRIP WITH REMOTE DALI DIMMABLE POWER SUPPLIES AS REQUIRED LOCATE THE POWER SUPPLIES IN A CONCEALED ACCESSIBLE POSITION NOTED ON THE AS CONSTRUCTED DOCUMENTS.	WHITE	NPA L-NF-GLOW-VWW + POWER SUPPLY & DALI CONTROLLER	A
L12	880LM /M 3000K 24V LED	LED STRIP LIGHT IN A SCREW FIXED EXTRUSION C/W OPAL DIFFUSER MOUNTED IN THE ENTRY SEATING AREA CEILING PELMET AS PER THE ARCHITECTURAL DETAIL. PROVIDE EACH GROUP OF L12 STRIP WITH REMOTE DALI DIMMABLE POWER SUPPLIES AS REQUIRED LOCATE THE POWER SUPPLIES IN A CONCEALED ACCESSIBLE POSITION NOTED ON THE AS CONSTRUCTED DOCUMENTS.	NATURAL	MELEC ML-ALU-1407-2M - ML-VLCRI-14.4-WW	A



# ELECTRICAL DESIGN GROUP

ELECTRICAL BUILDING SERVICES CONSULTANTS

P.O. Box 15, SHERWOOD Q. 4075

Phone: (07) 3278 4375 Fax: (07) 3716 0222

Web Site: [www.edg.net.au](http://www.edg.net.au) Email: [brisbane@edg.net.au](mailto:brisbane@edg.net.au)

C3556a - ROYAL HOTEL, BEENLEIGH


C3556a-0002(B).xls

## ELECTRICAL EQUIPMENT SCHEDULE

REVISION B - 18 JUNE 2025

THE LIGHT FITTING SUPPLIER CONTACT DETAILS MAY BE AVAILABLE ON THE EDG WEBSITE VIA THE FOLLOWING LINK  
[www.edg.net.au/Links/Lighting.htm](http://www.edg.net.au/Links/Lighting.htm)

TYPE	LAMPS	DESCRIPTION	COLOUR / ACCESSORY	CATALOGUE No	REV
PD01	TRAILING EDGE DIMMABLE 240 VOLT 2700K G9 LED 330 LUMENS +/- 10% 15,000 HOUR LIFE	150MM DIA DECORATIVE PENDANT ALLOW TO ASSEMBLE AND INSTALL CONFIRM THE SUSPENSION HEIGHT ONSITE WITH THE ARCHITECT	BLACK WITH FROSTED GLOBE	BEACON LIGHTING CIRQUE 1 LIGHT 011440	A
PD02	NOT USED				A
PD03	TRAILING EDGE DIMMABLE 240 VOLT 2700K B22 FILAMENT LED 700 LUMENS +/- 10% 15,000 HOUR LIFE	DECORATIVE PENDANT ALLOW TO ASSEMBLE AND INSTALL CONFIRM THE SUSPENSION HEIGHT ONSITE WITH THE ARCHITECT	AGED SOLID BRASS	FAT SHACK VINTAGE FACTORY BATTEN LIGHT + BLACK CAGE GUARD C027-BRS- BLK	A
PD04	PROVIDE SIX TRAILING EDGE DIMMABLE G9 240 VOLT 2700K 330 LUMENS +/- 10% 15,000 HOUR LIFE	SIX LAMP DECORATIVE PENDANT ALLOW TO ASSEMBLE AND INSTALL CONFIRM THE SUSPENSION HEIGHT ONSITE WITH THE ARCHITECT	BLACK BRASS FINISH OPAL RIPPLED 110 GLASS	ABOUT SPACE APENERA PENDANT	A
PD05	INTEGRAL TRAILING EDGE DIMMABLE 2700K LED 1000 LUMENS / M	DECORATIVE PENDANT ALLOW TO ASSEMBLE AND INSTALL CONFIRM THE SUSPENSION HEIGHT ONSITE WITH THE ARCHITECT	BLACK	FAT SHACK VINTAGE INSTITUTE 1200 LP032-SML	A
PD06	TRAILING EDGE DIMMABLE 240 VOLT 2700K B22 FILAMENT LED 700 LUMENS +/- 10% 15,000 HOUR LIFE	DECORATIVE PENDANT ALLOW TO ASSEMBLE AND INSTALL CONFIRM THE SUSPENSION HEIGHT ONSITE WITH THE ARCHITECT	AGED SOLID BRASS	FAT SHACK VINTAGE CONE 3 LIGHT GOOSENECK P015- 3GO-SML-CPR	A
WL01	TRAILING EDGE DIMMABLE 240 VOLT 2700K B22 FILAMENT LED 700 LUMENS +/- 10% 15,000 HOUR LIFE	250MM DIA DISK 150MM DIA SHADE WALL LIGHT MOUNTED LIGHT AS PER THE ARCHITECTURAL ELEVATION	LARGE BRASS DISK SMALL OPAL SHADE	FAT SHACK VINTAGE GLASS BALL DISC WALL LIGHT W233-BS- LRG-OPL-15	A
WL02	INTEGRAL 5W 3000K LED	375 X 180 WALL LIGHT MOUNTED LIGHT AS PER THE ARCHITECTURAL ELEVATION	BRASS	ZEST LIGHTING ORSON ANTIQUE BRASS	A
WL03	TRAILING EDGE DIMMABLE 240 VOLT 2700K E14 55DIA FILAMENT LED 700 LUMENS +/- 10% 15,000 HOUR LIFE	80MM DIA 310MM HIGH WALL LIGHT MOUNTED LIGHT AS PER THE ARCHITECTURAL ELEVATION	BRASS	FAT SHACK VINTAGE TELLER GLASS ROD WALL LIGHT W728- GLD-CLR	A



# ELECTRICAL DESIGN GROUP

ELECTRICAL BUILDING SERVICES CONSULTANTS

P.O. Box 15, SHERWOOD Q. 4075

Phone: (07) 3278 4375 Fax: (07) 3716 0222

Web Site: [www.edg.net.au](http://www.edg.net.au) Email: [brisbane@edg.net.au](mailto:brisbane@edg.net.au)

C3556a - ROYAL HOTEL, BEENLEIGH

C3556a-0002(B).xls

## ELECTRICAL EQUIPMENT SCHEDULE

REVISION B - 18 JUNE 2025

THE LIGHT FITTING SUPPLIER CONTACT DETAILS MAY BE AVAILABLE ON THE EDG WEBSITE VIA THE FOLLOWING LINK  
[www.edg.net.au/Links/Lighting.htm](http://www.edg.net.au/Links/Lighting.htm)

TYPE	LAMPS	DESCRIPTION	COLOUR / ACCESSORY	CATALOGUE No	REV
WL04	TRAILING EDGE DIMMABLE 240 VOLT 2700K B22 FILAMENT LED 700 LUMENS +/- 10% 15,000 HOUR LIFE	25MM DIA 95MM HIGH WALL LIGHT MOUNTED LIGHT AS PER THE ARCHITECTURAL ELEVATION	SATIN BRASS ARM / BRASS SHADE	FAT SHACK VINTAGE CONE GOOSENECK OUTDOOR WALL LIGHT W323-SBS-BRS	A
WL05	TRAILING EDGE DIMMABLE 240 VOLT 2700K B22 FILAMENT LED 700 LUMENS +/- 10% 15,000 HOUR LIFE	150M DIA WALL LIGHT MOUNTED LIGHT AS PER THE ARCHITECTURAL ELEVATION	BRASS / OPAL SHADE	FAT SHACK VINTAGE GLASS BALL LIGHT W326-OPL-15	A
WL06	450LUMEN 2700K LED	COLUMN MOUNTED UP / DOWN LIGHT C/W REMOTE DALI DIMMABLE POWER SUPPLY IT IS ACCEPTABLE TO USE A SUITABLY SIZED SINGLE POWER SUPPLY / DALI CONTROLLER TO SUPPLY MULTIPLE L8 FITTINGS ON THE SAME CHANNEL. LOCATE THE POWER SUPPLY AND DALI CONTROLLER IN A CONCEALED ACCESSIBLE POSITION WITH THE LOCATION NOTED ON THE AS CONSTRUCTED DOCUMENTS.	BLACK	NPA L-FX-SL-ARA- SP1303WM-12V-27K-D	B
SL01	13W 3000K LED	SURFACE MOUNTED DOWNLIGHT C/W INTEGRAL DALI DIMMABLE DRIVER ALLOW TO CHASE IN ALL CABLING AND CONDUITS	WHITE	EQUAL TO GAMMA ILLUMINATION SOLO 1412-3K-13W	A
SL02	NOT USED				A
SL03	NOT USED				A
SL04	TRAILING EDGE DIMMABLE 240 VOLT 2700K E27 LED 400 LUMENS +/- 10% 15,000 HOUR LIFE	135 DEEP SURFACE MOUNTED LIGHT	BLACK BASE OPAL MATT SHADE	FAT SHACK VINTAGE OSLO GLASS STEEL CEILING LIGHT W1067-BLK-SML-KIT	A
SL05	TRAILING EDGE DIMMABLE 240 VOLT 2700K GU10 LED 300 LUMENS +/- 10% 15,000 HOUR LIFE	100 DIA 150 DEEP SURFACE MOUNTED LIGHT	BLACK	BEACON LIGHTING MLF BY MASSON MILA GU10 177703	A
RD01	13W 3000K LED	RECESSED DOWNLIGHT C/W REMOTE DALI DIMMABLE DRIVER	WHITE TRIM	GAMMA ILLUMINATION RHO 1001-3K-13W	A
RD02	13W 3000K LED	RECESSED ADJUSTABLE DOWNLIGHT C/W REMOTE DALI DIMMABLE DRIVER	WHITE TRIM	GAMMA ILLUMINATION KHO 1002-3K-13W	A



# ELECTRICAL DESIGN GROUP

ELECTRICAL BUILDING SERVICES CONSULTANTS

P.O. Box 15, SHERWOOD Q. 4075

Phone: (07) 3278 4375 Fax: (07) 3716 0222

Web Site: [www.edg.net.au](http://www.edg.net.au) Email: [brisbane@edg.net.au](mailto:brisbane@edg.net.au)

C3556a - ROYAL HOTEL, BEENLEIGH

C3556a-0002(B).xls

## ELECTRICAL EQUIPMENT SCHEDULE

REVISION B - 18 JUNE 2025

THE LIGHT FITTING SUPPLIER CONTACT DETAILS MAY BE AVAILABLE ON THE EDG WEBSITE VIA THE FOLLOWING LINK  
[www.edg.net.au/Links/Lighting.htm](http://www.edg.net.au/Links/Lighting.htm)

TYPE	LAMPS	DESCRIPTION	COLOUR / ACCESSORY	CATALOGUE No	REV
RD03	13W 3000K LED	RECESSED ADJUSTABLE DOWNLIGHT C/W REMOTE DALI DIMMABLE DRIVER	WHITE TRIM	EQUAL TO GAMMA ILLUMINATION SCOOP MINI G2 1496-FL-3K-13W	A
RD04	13W 3000K LED	RECESSED ADJUSTABLE DOWNLIGHT C/W REMOTE DALI DIMMABLE DRIVER	WHITE TRIM	EQUAL TO GAMMA ILLUMINATION MYLO 1004-FL-3K-13W	A
RD05	13W 3000K LED	RECESSED DOWNLIGHT C/W REMOTE DALI DIMMABLE DRIVER	BLACK TRIM	GAMMA ILLUMINATION RHO 1001-3K-13W	A
RD06	13W 3000K LED	RECESSED DOWNLIGHT C/W REMOTE DALI DIMMABLE DRIVER	WHITE TRIM	GAMMA ILLUMINATION RHO 1001-3K-13W	A
FS01	1W LED AT 500 CENTRES	FESTOON LIGHTING WITH 24V DC IP65 FESTOON LIGHTING TO BE FIXED TO A 316 STAINLESS STEEL WIRE SUPPORT SYSTEM. LOCATE THE DRIVER IN A CONCEALED ACCESSIBLE POSITION NOTED ON THE AS CONSTRUCTED DOCUMENTS. CONFIRM THE LENGTH AND POSITION ON SITE	BLACK CABLE AND FIXINGS 316 STAINLESS STEEL SUPPORT AND FIXINGS	FIRE FLY FFC-LS-50-24VE27-BK	A
TLE	EXISTING LINEAR TRACK AND ASSOCIATED FITTINGS TO BE RETAINED				A
FDE	ALLOW A PC SUM OF \$500.00 PLUS GST FOR THE SUPPLY OF EACH FDE. ALLOW TO INSTALL				A
UL01	5W 3000K LED	GARDEN ELV SPIKE LIGHT. PROVIDE EACH GROUP OF UL01 FITTINGS WITH A REMOTE COMMON DALI DIMMABLE DRIVER. LOCATE DRIVER /POWER SUPPLY IN A CONCEALED ACCESSIBLE POSITION NOTED ON THE AS CONSTRUCTED DOCUMENTS.	BLACK	GAMMA ILLUMINATION RULOJ 885102	A
E1	LED	EMERGENCY LIGHT: RECESSED NON-MAINTAINED EMERGENCY LIGHT. AS2293 CLASSIFICATION C0-D40 - C90-D40.	WHITE	CLEVERTRONICS LLIFE	A
E2	LED	EMERGENCY LIGHT: RECESSED NON-MAINTAINED EMERGENCY LIGHT. AS2293 CLASSIFICATION C0-D40 - C90-D40.	BLACK	CLEVERTRONICS LLIFEBLK	A
EX	LED	EXIT LIGHT: MAINTAINED 24M VIEWING DISTANCE EXIT LIGHT C/W DIFFUSERS & DIRECTIONAL ARROWS AS SHOWN. CEILING SURFACE MOUNT OR WALL MOUNT BETWEEN 2100mm & 2700mm AFFL IF THERE IS NO VERTICAL SURFACE TO MOUNT THE FITTING ON WITHIN THIS RANGE CONFIRM THE MOUNTING HEIGHT WITH THE ENGINEER. AS2293 CLASSIFICATION C0-D1.25- C90-D2	WHITE UNLESS NOTED AS BK THEN BLACK BODY	CLEVERTRONICS LUBPRO-SM	A



# ELECTRICAL DESIGN GROUP

ELECTRICAL BUILDING SERVICES CONSULTANTS

P.O. Box 15, SHERWOOD Q. 4075

Phone: (07) 3278 4375 Fax: (07) 3716 0222

Web Site: [www.edg.net.au](http://www.edg.net.au) Email: [brisbane@edg.net.au](mailto:brisbane@edg.net.au)

C3556a - ROYAL HOTEL, BEENLEIGH

C3556a-0002(B).xls

## ELECTRICAL EQUIPMENT SCHEDULE

REVISION B - 18 JUNE 2025

THE LIGHT FITTING SUPPLIER CONTACT DETAILS MAY BE AVAILABLE ON THE EDG WEBSITE VIA THE FOLLOWING LINK  
[www.edg.net.au/Links/Lighting.htm](http://www.edg.net.au/Links/Lighting.htm)

TYPE	LAMPS	DESCRIPTION	COLOUR / ACCESSORY	CATALOGUE No	REV
HEATER	LAMP TYPE 1 (HL01)	250W PENDANT HEAT LAMP CONFIRM THE SUSPENSION HEIGHT ONSITE WITH THE ARCHITECT	GLOSSY GREY	HATCO DL-500-CL-CH/BK	A
HEATER	LAMP TYPE 2 (HL02)	TWO LAMP 900 LONG HEAT LAMP MOUNTED UNDER THE SHELF AS PER THE ARCHITECTURAL DETAIL	ALUMINIUM	ROBAND HQ900E	A
HEATER TYPE 1 (HR01)		2300W WALL MOUNTED HEATER C/W MOUNTING BRACKET AND REMOTE CONTROL LOCATED ADJACENT SP4	BLACK	BROMIC PLATINUM SMART ELECTRIC	A
EXISTING HEATER (HRE)		EXISTING HEATER TO BE RETAINED AND RECONNECTED WITH THE EXISTING CONTROL REINSTATED			A
FE	CEILING FAN	132 DIA DC MOTOR CEILING FAN. PROVIDE THE F01 WITH A DEDICATED WIRED CONTROLLER CONFIRM THE DROP ON SITE WITH THE ARCHITECT	BLACK	BIG ASS FANS HAIKU MK-HK4-04	A
FAN CONTROLLER TYPE 1 (FC1)		FAN ON / OFF / SPEED CONTROLS. WALL MOUNTED AT 1000 AFFL	WHITE	TYPE TO MATCH THE FAN	A
CHANNEL x		CONTROL CHANNEL WITH A NUMERICAL REFERENCE. REFER TO THE POWER AND LIGHTING CONTROL SCHEMATIC / SCHEDULE			A
ONE-WAY LIGHT SWITCH		ONE-WAY LIGHT SWITCH C/W CIRCUIT IDENTIFICATION ON THE FACEPLATE BEHIND THE SURROUND MOUNTED AT 1000mm AFFL UNLESS NOTED OTHERWISE.	WHITE	CLIPSAL C2000 SERIES 30USM	A
TWO-WAY LIGHT SWITCH		TWO-WAY LIGHT SWITCH C/W CIRCUIT IDENTIFICATION ON THE FACEPLATE BEHIND THE SURROUND MOUNTED AT 1000mm AFFL UNLESS NOTED OTHERWISE.	WHITE	CLIPSAL C2000 SERIES 30USM	A
LIGHTING CONTROL SWITCH PANEL (SPx)		6-BUTTON PROGRAMMABLE SWITCH PANEL C/W CENTRAL LCD DISPLAY MOUNTED AT 1000mm AFFL UNLESS NOTED OTHERWISE.	ALUMINIUM	DYNALITE ANTUMBRA DISPLAY	A
SINGLE POWER OUTLET		SINGLE POWER OUTLET C/W CIRCUIT IDENTIFICATION ON THE FACEPLATE BEHIND THE SURROUND MOUNT AT 300mm AFFL U.N.O. RATING 10A U.N.O.	WHITE UNLESS NOTED AS BLACK (BK)	CLIPSAL C2000 SERIES	A
SINGLE POWER OUTLET AUTO DOOR (AD)		SINGLE POWER OUTLET C/W CIRCUIT IDENTIFICATION ON THE FACEPLATE BEHIND THE SURROUND MOUNTED CONCEALED WITHIN THE AUTO DOOR MULLION. RATING 10A U.N.O.	WHITE	CLIPSAL C2000 SERIES	A



# ELECTRICAL DESIGN GROUP

ELECTRICAL BUILDING SERVICES CONSULTANTS

P.O. Box 15, SHERWOOD Q. 4075

Phone: (07) 3278 4375 Fax: (07) 3716 0222

Web Site: [www.edg.net.au](http://www.edg.net.au) Email: [brisbane@edg.net.au](mailto:brisbane@edg.net.au)

C3556a - ROYAL HOTEL, BEENLEIGH

C3556a-0002(B).xls

## ELECTRICAL EQUIPMENT SCHEDULE

REVISION B - 18 JUNE 2025

THE LIGHT FITTING SUPPLIER CONTACT DETAILS MAY BE AVAILABLE ON THE EDG WEBSITE VIA THE FOLLOWING LINK  
[www.edg.net.au/Links/Lighting.htm](http://www.edg.net.au/Links/Lighting.htm)

TYPE	LAMPS	DESCRIPTION	COLOUR / ACCESSORY	CATALOGUE No	REV
DOUBLE POWER OUTLET		DOUBLE POWER OUTLET C/W CIRCUIT IDENTIFICATION ON THE FACEPLATE BEHIND THE SURROUND MOUNT AT 300mm AFFL U.N.O. RATING 10A U.N.O.	WHITE UNLESS NOTED AS BLACK (BK)	CLIPSAL C2000 SERIES	A
WEATHERPROOF POWER OUTLET (WP)		IP54 WEATHERPROOF SINGLE / DOUBLE POWER OUTLET AS NOTED ON DRAWING C/W COVER FLAP OVER SOCKET. MOUNT AT MINIMUM 1100mm AFFL U.N.O. RATING 10A U.N.O.	-	CLIPSAL WSCF227F	A
SPECIAL PURPOSE OUTLET		SPECIAL PURPOSE OUTLET TYPE AS NOTED. MOUNT AT 1350mm AFFL U.N.O. RATING 20A U.N.O. CONNECT TO EQUIPMENT VIA FLEXIBLE CONDUIT.			A
SIGN CONNECTION		COORDINATE THE LOCATION AND CONNECTION WITH THE SIGN CONTRACTOR ENSURING THE GPO / ISOLATORS ARE PROVIDED WITH APPROPRIATE WEATHER PROTECTION AND ARE CONCEALED FROM VIEW.			A
SINGLE-PHASE ISOLATOR		SINGLE-PHASE WEATHERPROOF ISOLATOR. MOUNT AT 1350mm AFFL U.N.O. RATING 20A U.N.O. CONNECT TO EQUIPMENT VIA FLEXIBLE CONDUIT.	-	CLIPSAL WHT20	A
THREE-PHASE ISOLATOR		THREE-PHASE WEATHERPROOF ISOLATOR. MOUNT AT 1350mm AFFL U.N.O. RATING 20A U.N.O. CONNECT TO EQUIPMENT VIA FLEXIBLE CONDUIT.	-	CLIPSAL WHT35	A
GAMING ROOM JUNCTION BOX		PROVIDE A SQUARE PLASTIC JUNCTION BOX CHASED INTO THE SLAB WITH THE TOP FLUSH WITH THE FLOOR. THE GAMING POWER CONDUITS ARE TO RUN TO A POWER JUNCTION BOX AND THE GAMING COMMUNICATIONS CONDUITS ARE TO RUN TO A COMMUNICATIONS JUNCTION BOX. LOCATE THE JUNCTION BOXES UNDER THE GAMING MACHINES.			A
DB-A		DISTRIBUTION BOARD DB-A AS PER THE DB-A SCHEDULE AND NOTES. PROVIDE A SHOP DRAWING OF DB-A FOR APPROVAL. REFER TO THE DB-T DESCRIPTION OF THE SUPPLY TO DB-A			A
DB-G		EXISTING DISTRIBUTION BOARD AND ALL ASSOCIATED LOAD CENTRES / DIMMERS AND CONTROLS TO BE REMOVED. ANY EXISTING CIRCUITS THAT REMAIN ARE TO BE RESUPPLIED FROM THE NEW DB-A VIA NEW AS3000 COMPLIANT SWITCHGEAR WITH THE SAME CAPACITY AND CONTROL FUNCTION AS THE ORIGINAL			A
DB-T		EXISTING DISTRIBUTION BOARD TO REMAIN REMOVE ALL EXISTING CIRCUITS AND ASSOCIATED CABLING THAT BECOMES REDUNDANT DUE TO THE PROPOSED WORKS. UPDATE THE EXISTING LABELLING AND SCHEDULE AT PRACTICAL COMPLETION SUCH THAT EACH CIRCUIT USE AND LOCATION CAN BE QUICKLY AND SIMPLY IDENTIFIED. PROVIDE THE MCCB CHASSIS WITH A NEW 160AMP MCCB TO SUPPLY DB-A. PROVIDE A 4C+E 70MM CU PVC/ XLPE SUBMAIN FROM THE NEW MCCB TO DB-A. UPDATE THE MCCB LABELLING AT PRACTICAL COMPLETION.			A
MSB		EXISTING MAIN SWITCHBOARD TO REMAIN AS IS.			A
FIRE INDICATOR PANEL (FIP)		REPLACE THE EXISTING FIP WITH A CURRENT VERSION OF THE AS1670.1 COMPLIANT WHITE FIRE INDICATOR PANEL. RECONNECT ALL OF THE EXISTING DETECTORS AND SPEAKERS OUTSIDE OF THE WORKS AREA.			A
SMOKE DETECTOR		AS1670.1 SURFACE MOUNTED SMOKE DETECTOR WHITE UNLESS NOTED AS BK THEN BLACK			A

C3556a-0002(B).xls

Pages inc. any attach. 7 of 8



# ELECTRICAL DESIGN GROUP

ELECTRICAL BUILDING SERVICES CONSULTANTS

P.O. Box 15, SHERWOOD Q. 4075

Phone: (07) 3278 4375 Fax: (07) 3716 0222

Web Site: [www.edg.net.au](http://www.edg.net.au) Email: [brisbane@edg.net.au](mailto:brisbane@edg.net.au)

C3556a - ROYAL HOTEL, BEENLEIGH

C3556a-0002(B).xls

ELECTRICAL EQUIPMENT SCHEDULE

REVISION B - 18 JUNE 2025

THE LIGHT FITTING SUPPLIER CONTACT DETAILS MAY BE AVAILABLE ON THE EDG WEBSITE VIA THE FOLLOWING LINK  
[www.edg.net.au/Links/Lighting.htm](http://www.edg.net.au/Links/Lighting.htm)

TYPE	LAMPS	DESCRIPTION	COLOUR / ACCESSORY	CATALOGUE No	REV
RECESSED FIRE ALARM SPEAKER		AS1670.1 RECESSED FIRE ALARM SPEAKER C/W GRILL	WHITE UNLESS NOTED AS BK THEN BLACK		A
FIRE ALARM SYSTEM INTERFACE		FIRE ALARM FAILSAFE INTERFACE TO UNLOCK THE DOOR UPON A FIRE ALARM			A