

## LEGEND


	ELECTRICAL SERVICES SWITCHBOARD.
	SWITCHBOARD / CONTROL PANEL NOT PROVIDED AS PART OF THE ELECTRICAL SUBCONTRACT.
	SINGLE POWER OUTLET.
	DOUBLE POWER OUTLET.
	SPECIAL PURPOSE POWER OUTLET.
	EXISTING POWER OUTLET TO REMAIN AS NOTED.
	SIGNAGE CONNECTION.
	SINGLE PHASE ISOLATOR.
	THREE PHASE ISOLATOR.
	GAMING JUNCTION BOX.
	CONDUIT ROUTE.
	FAN CONTROL, TYPE x.
	LIGHTING CONTROL SWITCHPANEL, TYPE x.
	ONE-WAY LIGHT SWITCH.
	TWO-WAY LIGHT SWITCH.
	CIRCUIT LINE.
	SWITCH LINE.
	POWER CIRCUIT DESIGNATION. DENOTES DB AND CIRCUIT.
	LIGHTING CONTROL CHANNEL REFERENCE.
	ELECTRICAL EQUIPMENT AS NOTED.
	FIRE INDICATOR PANEL.
	SMOKE DETECTOR.
	RECESSED FIRE ALARM SPEAKER.
	FIRE ALARM DOOR SYSTEM INTERFACE.
	FE: CEILING FAN
	HR01: WALL MOUNTED HEATER.
	HRE: EXISTING HEATER TO BE RETAINED.
	Lx: LED JOINERY / CEILING STRIP LIGHT, TYPE AS NOTED.
	E1: GENERAL RECESSED LED EMERGENCY LIGHT, WHITE.
	E2: GENERAL RECESSED LED EMERGENCY LIGHT, BLACK.
	EX: EMERGENCY LED EXIT LIGHT, WHITE UNLESS NOTED AS BLACK.
	PD01: DECORATIVE SUSPENDED PENDANT LIGHT.
	PD02: NOT USED.
	PD03: DECORATIVE SUSPENDED PENDANT LIGHT.
	PD04: DECORATIVE SUSPENDED PENDANT LIGHT.
	PD05: DECORATIVE SUSPENDED PENDANT LIGHT.
	PD06: DECORATIVE SUSPENDED PENDANT LIGHT.
	WL01: WALL LIGHT.
	WL02: WALL LIGHT.
	WL03: WALL LIGHT.
	WL04: WALL LIGHT.
	WL05: WALL LIGHT.

## LEGEND

	SL01: SURFACE MOUNTED DOWNLIGHT.
	SL02: NOT USED.
	SL03: NOT USED.
	SL04: SURFACE MOUNTED LIGHT.
	SL05: SURFACE MOUNTED LIGHT.
	RD01: RECESSED DOWNLIGHT.
	RD02: RECESSED ADJUSTABLE DOWNLIGHT.
	RD03: RECESSED ADJUSTABLE DOWNLIGHT.
	RD04: RECESSED ADJUSTABLE DOWNLIGHT.
	RD05: RECESSED DOWNLIGHT.
	RD06: RECESSED DOWNLIGHT.
	TLE: EXISTING LINEAR TRACK AND FITTINGS RETAINED.
	FS01: FESTOON DECORATIVE LIGHTING.
	FDE: LIGHT FITTING TYPE TO BE CONFIRMED.
	UL01: GARDEN SPIKE LIGHT.
	HL01: SUSPENDED PENDANT HEAT LAMP.
	HL02: 900 LONG LINEAR SHELF HEAT LAMP.

### EQUIPMENT:

TEST - TEST PUSH BUTTON MOUNTED ON THE DISTRIBUTION BOARD ESCUTCHEON.  
RESET - RESET PUSH BUTTON MOUNTED ON THE DISTRIBUTION BOARD ESCUTCHEON.  
LAMP - AMBER TEST INDICATING LAMP MOUNTED ON THE DISTRIBUTION BOARD ESCUTCHEON.  
Ta - ADJUSTABLE 0-3 HOUR TIMED RELAY.  
Tb - 15 MINUTE RUN-ON TIMER TO OPERATE UPON THE RETURN OF MAINS POWER.  
Cx - CONTACTOR x.  
CRx - CONTROL RELAY x.  
Rx - RELAY x.




## SCHEMATIC

### EMERGENCY LIGHTING

NOT TO SCALE

## NOTES

- THE EMERGENCY LIGHT UNSWITCHED ACTIVE / GENERAL LIGHTING SWITCHED ACTIVE CIRCUIT ARRANGEMENT AND CONTROL IS TYPICAL FOR ALL CIRCUITS SUPPLYING EMERGENCY LIGHTS.
- PROVIDE ADDITIONAL CONTROL RELAYS (CRx) CONFIGURED AS PER CRa AND CRb FOR ALL ADDITIONAL LIGHTING CIRCUITS THAT SUPPLY LIGHTS IN THE VICINITY OF THE EMERGENCY LIGHTS.




### GAMING MACHINE NOTES

- ALL SERVICES ARE TO ENTER THE GAMING MACHINE BASE / VOID FROM THE WALL CAVITY VIA A 300AFFL WALL BRACKET FOR A FUTURE BLANK FACEPLATE.
- ENSURE THAT THE GPO IS MOUNTED ON THE SIDE OF THE BASE TO ALLOW CABLE ACCESS.

THE COPYRIGHT OF THIS DRAWING REMAINS THE PROPERTY OF THE ELECTRICAL DESIGN GROUP.

USE FIGURED DIMENSIONS IN PREFERENCE TO SCALE.

ALL DIMENSIONS TO BE VERIFIED ONSITE.



## DETAIL

### TYPICAL OUTLET MOUNTINGS

NOT TO SCALE

A	TENDER	10/06/2025
REV:	DESCRIPTION:	DATE:

## ELECTRICAL DESIGN GROUP

ELECTRICAL BUILDING SERVICES CONSULTANTS

BRISBANE: P.O. Box 15 Sherwood Qld 4075  
Phone: (07) 3278 4375  
Email: brisbane@edg.net.au  
Web: www.edg.net.au

ELECTRICAL DESIGN GROUP BRISBANE PTY LTD  
ACN 092 710 793

TRADING AS:  
ELECTRICAL DESIGN  
GROUP

PROJECT:

## ROYAL HOTEL, BEENLEIGH

SITE ADDRESS:

85 GEORGE STREET, BEENLEIGH  
QUEENSLAND

SCALE: SHEET SIZE:

NOT TO SCALE AT A1

DRAWING TITLE:

## ELECTRICAL SERVICES LEGEND & DETAILS

PROJECT NO: DRAWING NO: REVISION:

C3556a E01 A