

ELECTRICAL DESIGN GROUP

ELECTRICAL BUILDING SERVICES CONSULTANTS

P.O. Box 15, SHERWOOD Q. 4075

Phone: (07) 3278 4375 Fax: (07) 3716 0222

Web Site: www.edg.net.au Email: brisbane@edg.net.au

C3657a - BROTHERS RUGBY CLUB - REDEVELOPMENT


C3657a-0002(A).xls

ELECTRICAL EQUIPMENT SCHEDULE

REVISION A - 07 AUGUST 2026

THE LIGHT FITTING SUPPLIER CONTACT DETAILS MAY BE AVAILABLE ON THE EDG WEBSITE VIA THE FOLLOWING LINK
www.edg.net.au/Links/Lighting.htm

TYPE	LAMPS	DESCRIPTION	COLOUR / ACCESSORY	CATALOGUE No	REV
L1	26W 4000K	600 x 600 LAY IN FLAT PLATE LED FITTING C/W REMOTE DRIVER MOUNTED IN A FLUSH RECESSED PB MOUNTING KIT	WHITE TRIM	GAMMA ILLUMINATION AXIS 1548-4K-26W C/W FLUSH RECESS PB KIT	A
L2	26W 4000K	600 x 600 LAY IN FLAT PLATE LED FITTING C/W REMOTE DALI DIMMABLE DRIVER MOUNTED IN A FLUSH RECESSED PB MOUNTING KIT	WHITE TRIM	GAMMA ILLUMINATION AXIS 1548-4K-26W C/W FLUSH RECESS PB KIT DALI	A
L3	13W 4000K LED	RECESSED DOWNLIGHT C/W REMOTE DRIVER	WHITE TRIM	GAMMA ILLUMINATION COBALT 1402-4K-13W	A
L4	36W LED 4000K	1200 LONG SURFACE MOUNTED IP65 DIFFUSED BATTEN C/W INTEGRAL ELECTRONIC CONTROL GEAR	LIGHT GREY	GAMMA STORM 1558-CCT-36W	A
L5	22W 4000K LED	RECESSED DOWNLIGHT C/W REMOTE DALI DIMMABLE DRIVER	WHITE TRIM	GAMMA ILLUMINATION COBALT 1402-4K-22W	A
L6	28W 3000K LED	RECESSED DOWNLIGHT C/W REMOTE DALI DIMMABLE DRIVER	WHITE TRIM	GAMMA ILLUMINATION COBALT 1403-3K-28W DALI	A
L7	13W 4000K LED	RECESSED DOWNLIGHT C/W REMOTE DRIVER	WHITE TRIM	GAMMA ILLUMINATION COBALT 1402-4K-13W	A
L8	13W 3000K LED	RECESSED DOWNLIGHT C/W REMOTE DALI DIMMABLE DRIVER	WHITE TRIM	GAMMA ILLUMINATION COBALT 1402-3K-13W	A
L9	14.4W/M 3000K LED	LED STRIP WITHIN A SCREW FIXED EXTRUSION C/W DIFFUSER UNDER THE FRONT OF THE BAR COUNTER AS PER THE ARCHITECTURAL DETAIL. PROVIDE THE STRIP WITH REMOTE DALI DIMMABLE POWER SUPPLIES AS REQUIRED LOCATE THE POWER SUPPLIES IN A CONCEALED ACCESSIBLE POSITION NOTED ON THE AS CONSTRUCTED DOCUMENTS.	NATURAL	RAPID LED R2334 PLUS ALUMINIUM EXTRUSION AND POWER SUPPLY & DALI CONTROLLER	A
L10	36No 22W 4000K LED	SURFACE MOUNTED 3 CHANNEL TRACK CONFIRM THE FITTING POSITIONS AND AIMING ON SITE WITH THE ARCHITECT ALL CHANNELS ARE TO BE SUPPLIED TOGETHER	WHITE	GAMMA ILLUMINATION 28 SERIES TRACK AND 36 NO SCOPE 1305-FL 4K-22W - DALI	A



ELECTRICAL DESIGN GROUP

ELECTRICAL BUILDING SERVICES CONSULTANTS

P.O. Box 15, SHERWOOD Q. 4075

Phone: (07) 3278 4375 Fax: (07) 3716 0222

Web Site: www.edg.net.au Email: brisbane@edg.net.au

C3657a - BROTHERS RUGBY CLUB - REDEVELOPMENT


C3657a-0002(A).xls

ELECTRICAL EQUIPMENT SCHEDULE

REVISION A - 07 AUGUST 2026

THE LIGHT FITTING SUPPLIER CONTACT DETAILS MAY BE AVAILABLE ON THE EDG WEBSITE VIA THE FOLLOWING LINK
www.edg.net.au/Links/Lighting.htm

TYPE	LAMPS	DESCRIPTION	COLOUR / ACCESSORY	CATALOGUE No	REV
L11	3000K LED +/- 10% 1500 LUMEN / M	8000 LONG SURFACE MOUNTED LINEAR EXTRUSION C/W OPAL DIFFUSER LEDS AND INTEGRAL DRIVER.	WHITE	GAMMA ILLUMINATION GAP57575	A
L12	26W 4000K	600 x 600 LAY IN FLAT PLATE LED FITTING C/W REMOTE DRIVER AND A SURFACE MOUNTING KIT	WHITE TRIM	GAMMA ILLUMINATION AXIS 1548-4K-26W C/W SM KIT	A
L13	3000K LED +/- 10% 1500 LUMEN / M	8000 LONG SURFACE MOUNTED LINEAR EXTRUSION C/W OPAL DIFFUSER LEDS AND INTEGRAL DRIVER. PROVIDE A 1000 LONG SECTION WITHIN THE FITTING SEPARATELY SWITCHED TO BE OPERATED AS A SECURITY LIGHT WHEN THE REMAINDER OF THE FITTING IS OFF.	WHITE	GAMMA ILLUMINATION GAP57575	A
L14	13W 4000K LED	SURFACE MOUNTED 3 CHANNEL DALI TRACK CONFIRM THE FITTING POSITIONS AND AIMING ON SITE WITH THE ARCHITECT SUPPLY / CIRCUIT THE THREE CHANNELS TOGETHER.	WHITE	GAMMA ILLUMINATION 25 SERIES TRACK AND VIXO 1115-VWFL-4K-13 AS INDICATED	A
FL1	EXISTING FIELD LIGHT POLE TO BE TEMPORARILY SUPPLIED FROM DB-T AND THEN RESUPPLIED FROM DB-A.				A
FL2	EXISTING FIELD LIGHT POLE TO BE TEMPORARILY SUPPLIED FROM DB-T AND THEN RESUPPLIED FROM DB-A.				A
E1	LED	EMERGENCY LIGHT: RECESSED NON-MAINTAINED EMERGENCY LIGHT. AS2293 CLASSIFICATION C0-D80 - C90-D80.	WHITE	CLEVERTRONICS CLIFE-PRO	A
E2	LED	EMERGENCY LIGHT: SURFACE MOUNTED ON THE UNDERSIDE OF THE TABLE TRAY SYSTEM NON-MAINTAINED EMERGENCY LIGHT. AS2293 CLASSIFICATION C0-D80 - C90-D80.	WHITE	CLEVERTRONICS CLIFE-PRO- SM	A
EX	LED	WHITE EXIT LIGHT: MAINTAINED 24M VIEWING DISTANCE EXIT LIGHT C/W DIFFUSERS & DIRECTIONAL ARROWS AS SHOWN. CEILING OR WALL MOUNT BETWEEN 2100mm & 2700mm AFFL IF THERE IS NO VERTICAL SURFACE TO MOUNT THE FITTING ON WITHIN THIS RANGE CONFIRM THE MOUNTING HEIGHT WITH THE ENGINEER. AS2293 CLASSIFICATION C0-D1.25- C90-D2	WHITE	CLEVERTRONICS CSBLED	A
EX WP	LED	EXIT LIGHT: MAINTAINED 24M VIEWING DISTANCE EXIT LIGHT C/W DIFFUSERS & DIRECTIONAL ARROWS AS SHOWN AND A IP56 HOUSING CEILING OR WALL MOUNT BETWEEN 2100mm & 2700mm AFFL IF THERE IS NO VERTICAL SURFACE TO MOUNT THE FITTING ON WITHIN THIS RANGE CONFIRM THE MOUNTING HEIGHT WITH THE ENGINEER. AS2293 CLASSIFICATION C0-D3.2 - C90-E2.	WHITE LOGO GREEN BACKGROUND WHITE BODY	CLEVERTRONICS CWELED-A	A



ELECTRICAL DESIGN GROUP

ELECTRICAL BUILDING SERVICES CONSULTANTS

P.O. Box 15, SHERWOOD Q. 4075

Phone: (07) 3278 4375 Fax: (07) 3716 0222

Web Site: www.edg.net.au Email: brisbane@edg.net.au

C3657a - BROTHERS RUGBY CLUB - REDEVELOPMENT

C3657a-0002(A).xls

ELECTRICAL EQUIPMENT SCHEDULE


REVISION A - 07 AUGUST 2026

THE LIGHT FITTING SUPPLIER CONTACT DETAILS MAY BE AVAILABLE ON THE EDG WEBSITE VIA THE FOLLOWING LINK
www.edg.net.au/Links/Lighting.htm

TYPE	LAMPS	DESCRIPTION	COLOUR / ACCESSORY	CATALOGUE No	REV
EMERGENCY PACK		LIGHT FITTINGS THAT ARE DESIGNATED AS BEING PROVIDED WITH AN EMERGENCY PACK ARE TO BE PROVIDED WITH AN INTEGRAL AS2293 EMERGENCY PACK. THE FITTINGS ARE TO BE NON MAINTAINED WITH ALL LAMPS SWITCHED AS PER THE LIGHTING CONTROL FOR THAT SPACE UNLESS NOTED OTHERWISE. REFER TO THE SPECIFICATION FOR FURTHER DETAILS OF THE CONFIGURATION AND SWITCHING OF EMERGENCY LIGHTS.			A
CHANNEL PE		CONTROL THE ASSOCIATED LIGHTS VIA AN ADJUSTABLE PE CELL SUCH THAT THE LIGHTS DO NOT OPERATE DURING DAYLIGHT. PROVIDE A PE CELL BYPASS SWITCH ON THE DB ESCUTCHEON.			A
ONE-WAY LIGHT SWITCH		ONE-WAY LIGHT SWITCH C/W CIRCUIT IDENTIFICATION ON THE FACEPLATE BEHIND THE SURROUND MOUNTED AT 1000mm AFFL UNLESS NOTED OTHERWISE.	WHITE	CLIPSAL C2000 SERIES 30USM	A
WEATHERPROOF ONE-WAY LIGHT SWITCH (WP)		IP56 ONE OR TWO-WAY AS NOTED ON DRAWING LIGHT SWITCH C/W CIRCUIT IDENTIFICATION ON THE FACEPLATE BEHIND THE SURROUND MOUNTED AT 1000mm AFFL UNLESS NOTED OTHERWISE.	WHITE	CLIPSAL "56 SERIES"	A
TWO-WAY LIGHT SWITCH		TWO -WAY LIGHT SWITCH C/W CIRCUIT IDENTIFICATION ON THE FACEPLATE BEHIND THE SURROUND MOUNTED AT 1000mm AFFL UNLESS NOTED OTHERWISE.	WHITE	CLIPSAL C2000 SERIES 30USM	A
DALI LIGHT SWITCH		MANUAL ROTARY DALI POT DIMMER C/W CIRCUIT IDENTIFICATION ON THE FACEPLATE BEHIND THE SURROUND THE DALI DIMMER IS TO BE MOUNTED REMOTELY WITH THE POSITION CONFIRMED ON SITE.	WHITE	CLIPSAL C2000 SMARTSCAPE DALI-RD20-M ROTARY DIMMER	A
LIGHTING CONTROL PANEL (LCP)		SEMI RECESSED 316 STAINLESS STEEL LOCKABLE HINGED HOUSING CONTAINING CONTROLS FOR THE VIC WALSH OVAL AND THE JACK ROSS OVAL WITH THE SAME LEVEL OF FUNCTION AS THE EXISTING CONTROLS. ALL CONTROLS ARE TO BE PROVIDED WITH CLEAR ENGRAVED LABELLING. PROVIDE A SHOP DRAWING INCLUDING A CONTROL SCHEMATIC OF THE LCP FOR APPROVAL. PROVIDE THE HOUSING WITH A MOUNTING FLANGE.			A
PROXIMITY DETECTOR SWITCH (PD)		ADJUSTABLE FLUSH RECESSED DUAL TECHNOLOGY 360 DEGREE ULTRASONIC PRESENCE DETECTOR TO OPERATE THE ASSOCIATED LIGHTS FOR A PRE-SET AMOUNT OF TIME. ADJUST THE TIME AND SENSITIVITY ON SITE AS DIRECTED BY THE ENGINEER.	WHITE	CLIPSAL SELECTION BY THE CONTRACTOR SUBMIT DETAILS OF THE MOVEMENT DETECTOR SWITCH FOR APPROVAL PRIOR TO ORDERING	A
SINGLE POWER OUTLET		SINGLE POWER OUTLET C/W CIRCUIT IDENTIFICATION ON THE FACEPLATE BEHIND THE SURROUND MOUNT AT 300mm AFFL U.N.O. RATING 10A U.N.O.	WHITE UNLESS NOTED AS BLACK (BK)	CLIPSAL C2000 SERIES	A
DOUBLE POWER OUTLET		DOUBLE POWER OUTLET C/W CIRCUIT IDENTIFICATION ON THE FACEPLATE BEHIND THE SURROUND MOUNT AT 300mm AFFL U.N.O. RATING 10A U.N.O.	WHITE UNLESS NOTED AS BLACK (BK)	CLIPSAL C2000 SERIES	A
WEATHERPROOF POWER OUTLET (WP)		IP54 WEATHERPROOF SINGLE / DOUBLE POWER OUTLET AS NOTED ON DRAWING C/W COVER FLAP OVER SOCKET. MOUNT AT MINIMUM 1100mm AFFL U.N.O. RATING 10A U.N.O.	GREY	CLIPSAL WSC227/1-RG	A

C3657a-0002(A).xls

Pages inc. any attach. 3 of 7



ELECTRICAL DESIGN GROUP

ELECTRICAL BUILDING SERVICES CONSULTANTS

P.O. Box 15, SHERWOOD Q. 4075

Phone: (07) 3278 4375 Fax: (07) 3716 0222

Web Site: www.edg.net.au Email: brisbane@edg.net.au

C3657a - BROTHERS RUGBY CLUB - REDEVELOPMENT


C3657a-0002(A).xls

ELECTRICAL EQUIPMENT SCHEDULE

REVISION A - 07 AUGUST 2026

THE LIGHT FITTING SUPPLIER CONTACT DETAILS MAY BE AVAILABLE ON THE EDG WEBSITE VIA THE FOLLOWING LINK
www.edg.net.au/Links/Lighting.htm

TYPE	LAMPS	DESCRIPTION	COLOUR / ACCESSORY	CATALOGUE No	REV
15A WEATHERPROOF POWER OUTLET (WP 15A)		IP54 WEATHERPROOF 20A SINGLE POWER OUTLET. MOUNT AT MINIMUM 1100mm AFFL U.N.O. RATING 20A U.N.O.	GREY	CLIPSAL WSC227/1/15-RG	A
20A WEATHERPROOF POWER OUTLET (WP 20A)		IP66 WEATHERPROOF 20A SINGLE POWER OUTLET. MOUNT AT MINIMUM 1100mm AFFL U.N.O. RATING 20A U.N.O.	GREY	CLIPSAL 56 SERIES	A
SPECIAL PURPOSE OUTLET		SPECIAL PURPOSE OUTLET TYPE AS NOTED. MOUNT AT 1350mm AFFL U.N.O. RATING 20A U.N.O. CONNECT TO EQUIPMENT VIA FLEXIBLE CONDUIT.			A
SINGLE-PHASE ISOLATOR		SINGLE-PHASE WEATHERPROOF ISOLATOR. MOUNT AT 1350mm AFFL U.N.O. RATING 20A U.N.O. CONNECT TO EQUIPMENT VIA FLEXIBLE CONDUIT.	-	CLIPSAL WHT20	A
THREE-PHASE ISOLATOR		THREE-PHASE WEATHERPROOF ISOLATOR. MOUNT AT 1350mm AFFL U.N.O. RATING 20A U.N.O. CONNECT TO EQUIPMENT VIA FLEXIBLE CONDUIT.	-	CLIPSAL WHT35	A
CCTV MONITOR (CM)		55-INCH UHD WALL-MOUNTED DIGITAL CCTV MONITOR MOUNTED AT 1800 AFFL C/W MOUNTING BRACKET AND DIRECT CONNECTION TO THE CCTV NVR MOUNTED IN CR-A.	NA	HIKVISION SKU: DS-D6055UN-B-SW	A
CCTV CAMERA INTERNAL POSITIONS		SURFACE MOUNTED COLOUR FIXED TURRET CAMERA CABLED TO A CAT 6 CAMERA PATCH PANEL WITHIN THE COMMUNICATIONS RACK CR-A VIA 4-PAIR CAT-6 UTP CABLE.	WHITE	HIKVISION DS-2CD2347G2-L	A
CCTV CAMERA EXTERNAL POSITIONS		SURFACE MOUNTED IR FIXED TURRET CAMERA CABLED TO A CAT 6 CAMERA PATCH PANEL WITHIN THE COMMUNICATIONS RACK CR-A VIA 4-PAIR CAT-6 UTP CABLE.	WHITE	HIKVISION DS-2CD2346G2P-ISU/SL	A
MATV OUTLET		MATV OUTLET CONNECTED TO A DEDICATED ANTENNA TO PROVIDE THE LOCALLY AVAILABLE FREE TO AIR TV SERVICES	WHITE	CLIPSAL C2000 SERIES	A
MATV ANTENNA		ROOF MOUNTED MATV ANTENNA TO RECEIVE AND DISTRIBUTE THE LOCALLY AVAILABLE FREE TO AIR TV SERVICES			A
SECURITY EQUIPMENT		WALL MOUNTED INNER RANGE INTEGRITI SECURITY CONTROLLER, REQUIRED EXPANDERS, INTEGRAL BATTERY BACK UPS AND HOUSINGS.			A
SECURITY PIEZO SIREN		FLUSH RECESSED PIEZO SIREN SUBMIT DETAILS OF THE PIEZO SIRENS FOR APPROVAL PRIOR TO ORDERING.			A
SECURITY INTRUDER DETECTOR		DUAL-TECHNOLOGY MOVEMENT DETECTORS WALL MOUNTED AS PER THE MANUFACTURER'S SPECIFICATION. CONNECT TO THE LOCAL SECURITY EQUIPMENT WITH ONE DETECTOR PER ZONE. PROGRAM THE SECURITY SYSTEM TO THE SATISFACTION OF THE CLUB. SUBMIT DETAILS OF THE DETECTORS INCLUDING THE MOUNTING ARRANGEMENTS FOR APPROVAL PRIOR TO ORDERING.			A



ELECTRICAL DESIGN GROUP

ELECTRICAL BUILDING SERVICES CONSULTANTS

P.O. Box 15, SHERWOOD Q. 4075

Phone: (07) 3278 4375 Fax: (07) 3716 0222

Web Site: www.edg.net.au Email: brisbane@edg.net.au

C3657a - BROTHERS RUGBY CLUB - REDEVELOPMENT


C3657a-0002(A).xls

ELECTRICAL EQUIPMENT SCHEDULE

REVISION A - 07 AUGUST 2026

THE LIGHT FITTING SUPPLIER CONTACT DETAILS MAY BE AVAILABLE ON THE EDG WEBSITE VIA THE FOLLOWING LINK
www.edg.net.au/Links/Lighting.htm

TYPE	LAMPS	DESCRIPTION	COLOUR / ACCESSORY	CATALOGUE No	REV
SECURITY KEY PAD (KP)		LCD KEYPAD MOUNTED AT 1100mm AFFL.	-	INNER RANGE ELITEX STANDARD KEYPAD	A
SIREN STROBE		SECURITY SATELLITE STROBE SIREN MOUNTED AT HIGH LEVEL TO OPERATE WHEN THE BUILDING GOES INTO ALARM.			A
DB-A		DISTRIBUTION BOARD DB-A AS PER THE DB-A SCHEDULE, POWER SCHEMATICS AND NOTES.			A
MSB		MAIN SWITCHBOARD TO BE MODIFIED AS PER THE POWER SCHEMATIC AND NOTES.			A
MSSB		MECHANICAL SERVICES SWITCHBOARD PROVIDED BY THE MECHANICAL SUB CONTRACTOR. COORDINATE THE SUBMAIN CONNECTION WITH THE MECHANICAL SUB CONTRACTOR ON SITE.			A
DB-CD		EXISTING DISTRIBUTION BOARD DB-CA TO BE REMOVED. REDIRECT / EXTEND THE EXISTING DB-CD SUPPLY SUBMAIN TO DB-T. REDIRECT / EXTEND ALL OF THE EXISTING VIC WALSH OVAL LIGHTING AND THE JACK ROSS OVAL LIGHTING CIRCUITS AND CONTROLS TO DB-T VIA NEW UNDERGROUND CONDUITS LOCATED TO ALLOW THE DEMOLITION AND CONSTRUCTION OF THE PROPOSED WORKS.			A
DB-FL		EXISTING FIELD LIGHT DISTRIBUTION BOARD TO REMAIN AS IS.			A
DB-T		PROVIDE DB-T AS A TEMPORARY WEATHERPROOF LOCKABLE DISTRIBUTION BOARD C/W SUPPORT AND MOUNTING TO SUPPLY ALL OF THE EXISTING FIELD LIGHTS SUPPLIED FROM DB-CD. PROVIDE DB-T WITH A SEPARATE EXTERNALLY MOUNTED LOCKABLE WEATHERPROOF HINGED HOUSING CONTAINING CONTROLS FOR THE VIC WALSH OVAL LIGHTING AND THE JACK ROSS OVAL LIGHTING WITH THE SAME LEVEL OF FUNCTION AS THE EXISTING CONTROLS. ALL CONTROLS ARE TO BE PROVIDED WITH CLEAR LABELLING. REDIRECT / EXTEND THE EXISTING DB-CD SUPPLY SUBMAIN TO DB-T. REDIRECT / EXTEND ALL OF THE EXISTING VIC WALSH OVAL LIGHTING AND THE JACK ROSS OVAL LIGHTING CIRCUITS AND CONTROLS TO DB-T VIA NEW UNDERGROUND CONDUITS LOCATED TO ALLOW THE DEMOLITION AND CONSTRUCTION OF THE PROPOSED WORKS.			A
REVENUE METER (M1)		EXISTING ENERGEX REVENUE METER TO REMAIN AS IS			A
PRIVATE METER (M2)		PROVIDE A MULTIFUNCTION METER THAT LOGS THE FOLLOWING ACROSS EACH PHASE, DEMANDS, VOLTAGES, POWER FACTORS, AND HARMONICS.			A
SPEAKER RECESSED		15W CEILING RECESSED MULTI TAP 100V 8 OHM PUBLIC ADDRESS DUAL CONE SPEAKER CABLED BACK TO THE ASSOCIATED AMPLIFIER WITHIN THE COMMUNICATIONS RACK VIA 1.5MM MARKED FIG 8 CABLE.	WHITE UNLESS NOTED BLACK (BK)	AUSTRALIAN MONITOR QF8CS	A
SPEAKER SURFACE MOUNTED		15W RECESSED MULTI TAP 100V 8 OHM PUBLIC ADDRESS DUAL CONE SPEAKER MOUNTED INTO A SURFACE MOUNTED MOUNTING KIT CABLED BACK TO THE ASSOCIATED AMPLIFIER WITHIN THE COMMUNICATIONS RACK VIA 1.5MM MARKED FIG 8 CABLE.	WHITE UNLESS NOTED BLACK (BK)	AUSTRALIAN MONITOR QF8CS PLUS SURFACE MOUNTING KIT	A



ELECTRICAL DESIGN GROUP

ELECTRICAL BUILDING SERVICES CONSULTANTS

P.O. Box 15, SHERWOOD Q. 4075

Phone: (07) 3278 4375 Fax: (07) 3716 0222

Web Site: www.edg.net.au Email: brisbane@edg.net.au

C3657a - BROTHERS RUGBY CLUB - REDEVELOPMENT

C3657a-0002(A).xls

ELECTRICAL EQUIPMENT SCHEDULE


REVISION A - 07 AUGUST 2026

THE LIGHT FITTING SUPPLIER CONTACT DETAILS MAY BE AVAILABLE ON THE EDG WEBSITE VIA THE FOLLOWING LINK
www.edg.net.au/Links/Lighting.htm

TYPE	LAMPS	DESCRIPTION	COLOUR / ACCESSORY	CATALOGUE No	REV
SPEAKER WALL MOUNTED		15W WALL MOUNTED IP65 MULTI TAP 100V 8 OHM PUBLIC ADDRESS SPEAKER C/W ADJUSTABLE MOUNTING KIT CABLED BACK TO THE ASSOCIATED AMPLIFIER WITHIN THE COMMUNICATIONS RACK VIA 1.5MM MARKED FIG 8 CABLE.	WHITE UNLESS NOTED BLACK (BK)	AUSTRALIAN MONITOR FLEX15W	A
HORN		30W SURFACE MOUNTED ADJUSTABLE IP66 MULTI TAP 100V 8 OHM PUBLIC ADDRESS HORN SPEAKER CABLED BACK TO THE ASSOCIATED AMPLIFIER WITHIN THE COMMUNICATIONS RACK VIA 1.5MM MARKED FIG 8 CABLE.	WHITE	AUSTRALIAN MONITOR SH30	A
AUDIO INPUT PANEL (AI)		MIC / LINE AUDIO INPUT MOUNTED AT 300 AFFL UNO CONNECTED TO THE MIXER LOCATED CR-A	WHITE	AUSTRALIAN MONITOR WPML	A
AUDIO VOLUME CONTROL PANEL (VC)		AUDIO VOLUME CONTROL C/E FOUR BUTTON ZONE SELECTION	WHITE	AUSTRALIAN MONITOR WP4R	A
COMMUNICATIONS RACK CR-E		EXISTING MAIN CLUB HOUSE COMMUNICATIONS RACK TO BE PROVIDED WITH A FOBOT. CONFIRM THE LOCATION OF CR-E ON SITE.			A
COMMUNICATIONS RACK CR-A		PROVIDE CR-A AS A FREE STANDING 42 RU MINIMUM 600 DEEP 600 WIDE RACK C/W TWO REAR VERTICAL 10 PORT POWER RAILS AND CASTERS. PROVIDE THE RACK WITH A FOBOT, PATCH PANELS, CABLE MANAGEMENT AND ALL NECESSARY MOUNTINGS / FIXINGS. THE MATV HEADEND, PA SYSTEM EQUIPMENT AND CCTV NVR AR TO NE MOUNTED WITHIN CR-A. PROVIDE AN ELEVATION OF THE CR-A EQUIPMENT CONFIGURATION FOR APPROVAL. ENSURE ALL CABLING INTO CR-A IS PROVIDED WITH SUFFICIENT COILED LENGTH TO ALLOW THE RACK TO BE MOVED OUT OF THE SERVER ROOM.		4 CABLING SKU 002.001.4280	A
COMMUNICATIONS OUTLET		RJ45 CAT-6 COMMUNICATIONS OUTLET, CABLED BACK TO CAT 6 PATCH PANELS IN RACK CR-A VIA 4-PAIR CAT-6 UTP CABLE. MOUNT UP TO 3 RJ45 OUTLETS PER MULTI-GANG FACEPLATE WITH SEPARATE PERMANENT LABELLING FOR EACH OUTLET. MOUNT AT 300 AFFL UNLESS NOTED OTHERWISE	WHITE UNLESS NOTED AS BLACK (BK)	CLIPSAL C2000 SERIES	A
SURFACE MOUNT (SM)		SM DENOTES THE FITTING / OUTLET IS TO BE SURFACE MOUNTED			A
RISER		PROVIDE THE RISER AS A REMOVABLE 2MM GALVANIZED STEEL COVER OVER POWER AND COMMUNICATIONS TRAYS CONNECTING THE UNDERGROUND CONDUITS TO THE CEILING SPACE. CONFIRM THE POSITION OF THE RISER ON SITE.			A
POWER PIT 1		600 X 600 CLEAR INTERNAL X 900 DEEP INSITU POWER PIT C/W A REINFORCED CONCRETE SURROUND AND A CLASS D LID WITH A SLIP RESISTANCE OF R10. SUBMIT DETAILS OF THE PIT, LID AND AN INSTALLATION SECTION FOR APPROVAL.			A
POWER PIT 2		600 X 600 CLEAR INTERNAL X 900 DEEP POWER PIT C/W A CLASS B LID.			A

C3657a-0002(A).xls

Pages inc. any attach. 6 of 7



ELECTRICAL DESIGN GROUP

ELECTRICAL BUILDING SERVICES CONSULTANTS

P.O. Box 15, SHERWOOD Q. 4075

Phone: (07) 3278 4375 Fax: (07) 3716 0222

Web Site: www.edg.net.au Email: brisbane@edg.net.au

C3657a - BROTHERS RUGBY CLUB - REDEVELOPMENT

C3657a-0002(A).xls

ELECTRICAL EQUIPMENT SCHEDULE

REVISION A - 07 AUGUST 2026

THE LIGHT FITTING SUPPLIER CONTACT DETAILS MAY BE AVAILABLE ON THE EDG WEBSITE VIA THE FOLLOWING LINK
www.edg.net.au/Links/Lighting.htm

TYPE	LAMPS	DESCRIPTION	COLOUR / ACCESSORY	CATALOGUE No	REV
COMMUNICATIONS PIT 1		300 X 000 CLEAR INTERNAL X 900 DEEP INSITU POWER PIT C/W A REINFORCED CONCRETE SURROUND AND A CLASS D LID WITH A SLIP RESISTANCE OF R10 SUBMIT DETAILS OF THE PIT, LID AND AN INSTALLATION SECTION FOR APPROVAL.			A
COMMUNICATIONS PIT 2		300 X 300 CLEAR INTERNAL X 900 DEEP POWER PIT C/W A CLASS B LID.			A
FIRE INDICATOR PANEL (FIP)		AS 1670 COMPLAINT FIRE INDICATOR PANEL INCORPORATING THE EWCIE AND FDCIE			A
FIRE EVACUATION HORN		SURFACE MOUNTED TWO-TONE 30W ALERT AND EVACUATION HORN SPEAKER TO AS1670.1 C/W 100V MULTI-TAP TRANSFORMER. MOUNT AT HIGH LEVEL.			A
FIRE MANUAL CALL POINT		MANUAL CALL POINT MOUNTED ON THE FIP AS PER AS1670.1			A
FIRE EVACUATION RECESSED SPEAKER		RECESSED 5W TWO-TONE 8-INCH CONE ALERT AND EVACUATION SPEAKER TO AS1670.1 C/W 100V MULTI-TAP TRANSFORMER AND FLUSH GRILLE PAINTED OUT TO MATCH THE CEILING.			A
FIRE EVACUATION SURFACE SPEAKER		SURFACE MOUNT 5W TWO-TONE 8-INCH CONE ALERT AND EVACUATION SPEAKER TO AS1670.1 C/W 100V MULTI-TAP TRANSFORMER AND GRILLE PAINTED OUT TO MATCH THE CEILING.			A
SMOKE DETECTOR		SURFACE MOUNTED AS7240.7 POINT SMOKE DETECTORS WITH A PERFORMANCE OF 6 TO 12 % OBS/M SET AT 7.8 %. WHITE UNLESS NOTED AS BLACK (BK)			A
THERMAL DETECTOR		SURFACE MOUNTED AS7240.5:2018 TYPE B SEALED FIXED TEMPERATURE ADDRESSABLE THERMAL DETECTOR. WHITE UNLESS NOTED AS BLACK (BK)			A
FIRE ALARM STROBE		WALL MOUNTED FIRE ALARM STROBE LIGHT AS PER AS1670.1			A