

ELECTRICAL DESIGN GROUP


ELECTRICAL BUILDING SERVICES CONSULTANTS

P.O. Box 15, SHERWOOD Q. 4075

Phone: (07) 3278 4375 Fax: (07) 3716 0222

Web Site: www.edg.net.au Email: brisbane@edg.net.au

C3685a - ALLENSTOWN HOTEL, ROCKHAMPTON					C3685a-0002(D).xls
ELECTRICAL EQUIPMENT SCHEDULE					
REVISION D - 23 OCTOBER 2026					
THE LIGHT FITTING SUPPLIER CONTACT DETAILS MAY BE AVAILABLE ON THE EDG WEBSITE VIA THE FOLLOWING LINK www.edg.net.au/Links/Lighting.htm					
TYPE	LAMPS	DESCRIPTION	COLOUR / ACCESSORY	CATALOGUE No	REV
S1	14.4W/M 2700K LED	LED STRIP WITHIN A SCREW FIXED EXTRUSION C/W DIFFUSER RECESSED INTO THE SUSPENDED BAR BULKHEAD AS PER THE ARCHITECTURAL DETAIL. PROVIDE THE STRIP WITH REMOTE DALI DIMMABLE POWER SUPPLIES AS REQUIRED LOCATE THE POWER SUPPLIES IN A CONCEALED ACCESSIBLE POSITION NOTED ON THE AS CONSTRUCTED DOCUMENTS.	NATURAL	RAPID LED R2334 2700 K PLUS ALUMINIUM EXTRUSION OPAL DIFFUSER AND POWER SUPPLY & DALI CONTROLLER	A
S2	NO LONGER REQUIRED				D
S3	14.4W/M 2700K LED	LED STRIP WITHIN A SCREW FIXED EXTRUSION C/W DIFFUSER WITHIN THE BISTRO CEILING PELMET AS PER THE ARCHITECTURAL DETAIL. PROVIDE THE STRIP WITH REMOTE DALI DIMMABLE POWER SUPPLIES AS REQUIRED LOCATE THE POWER SUPPLIES IN A CONCEALED ACCESSIBLE POSITION NOTED ON THE AS CONSTRUCTED DOCUMENTS.	NATURAL	RAPID LED R2334 2700 K PLUS ALUMINIUM EXTRUSION OPAL DIFFUSER AND POWER SUPPLY & DALI CONTROLLER	A
S4	NO LONGER REQUIRED				D
S5	14.4W/M 2700K LED	LED STRIP WITHIN A SCREW FIXED EXTRUSION C/W DIFFUSER WITHIN THE GAMING CEILING PELMET AS PER THE ARCHITECTURAL DETAIL. PROVIDE THE STRIP WITH REMOTE DALI DIMMABLE POWER SUPPLIES AS REQUIRED LOCATE THE POWER SUPPLIES IN A CONCEALED ACCESSIBLE POSITION NOTED ON THE AS CONSTRUCTED DOCUMENTS.	NATURAL	RAPID LED R2334 2700 K PLUS ALUMINIUM EXTRUSION OPAL DIFFUSER AND POWER SUPPLY & DALI CONTROLLER	A
S6	14.4W/M 2700K LED	MULTIPLE RUNS OF LED STRIP WITHIN A SCREW FIXED EXTRUSION C/W DIFFUSER RECESSED INTO THE REAR BAR JOINERY AS PER THE ELEVATION AND THE ARCHITECTURAL DETAIL. PROVIDE THE STRIP WITH REMOTE DALI DIMMABLE POWER SUPPLIES AS REQUIRED LOCATE THE POWER SUPPLIES IN A CONCEALED ACCESSIBLE POSITION NOTED ON THE AS CONSTRUCTED DOCUMENTS.	NATURAL	RAPID LED R2334 2700 K PLUS ALUMINIUM EXTRUSION OPAL DIFFUSER AND POWER SUPPLY & DALI CONTROLLER	A
S7	14.4W/M 2700K LED	LED STRIP WITHIN A SCREW FIXED EXTRUSION C/W DIFFUSER RECESSED INTO THE BAR FRONT AS PER THE ARCHITECTURAL DETAIL. PROVIDE THE STRIP WITH REMOTE DALI DIMMABLE POWER SUPPLIES AS REQUIRED LOCATE THE POWER SUPPLIES IN A CONCEALED ACCESSIBLE POSITION NOTED ON THE AS CONSTRUCTED DOCUMENTS.	NATURAL	RAPID LED R2334 2700 K PLUS ALUMINIUM EXTRUSION OPAL DIFFUSER AND POWER SUPPLY & DALI CONTROLLER	A
S8	14.4W/M 2700K LED	LED STRIP WITHIN A SCREW FIXED EXTRUSION C/W DIFFUSER RECESSED INTO THE BAR FRONT FEATURE AS PER THE ARCHITECTURAL DETAIL. PROVIDE THE STRIP WITH REMOTE DALI DIMMABLE POWER SUPPLIES AS REQUIRED LOCATE THE POWER SUPPLIES IN A CONCEALED ACCESSIBLE POSITION NOTED ON THE AS CONSTRUCTED DOCUMENTS.	NATURAL	RAPID LED R2334 2700 K PLUS ALUMINIUM EXTRUSION OPAL DIFFUSER AND POWER SUPPLY & DALI CONTROLLER	A



ELECTRICAL DESIGN GROUP


ELECTRICAL BUILDING SERVICES CONSULTANTS

P.O. Box 15, SHERWOOD Q. 4075

Phone: (07) 3278 4375 Fax: (07) 3716 0222

Web Site: www.edg.net.au Email: brisbane@edg.net.au

C3685a - ALLENSTOWN HOTEL, ROCKHAMPTON					C3685a-0002(D).xls
ELECTRICAL EQUIPMENT SCHEDULE					
REVISION D - 23 OCTOBER 2026					
THE LIGHT FITTING SUPPLIER CONTACT DETAILS MAY BE AVAILABLE ON THE EDG WEBSITE VIA THE FOLLOWING LINK www.edg.net.au/Links/Lighting.htm					
TYPE	LAMPS	DESCRIPTION	COLOUR / ACCESSORY	CATALOGUE No	REV
S9	11W RGBW LED	LED STRIP LIGHT IN A SCREW FIXED SURFACE MOUNTED EXTRUSION C/W ROUND DIFFUSER AND A REMOTE DALI RGB CONTROLLER / POWER SUPPLY LOCATED IN A CONCEALED ACCESSIBLE POSITION NOTED ON THE AS CONSTRUCTED DOCUMENTS.	WHITE EXTRUSION AND DIFFUSER	HV9690-2618 + HV9753-IP67-60-RGBW + DALI RGB DRIVER	A
S10	10W/M 2700K LED	IP67 LED FLEX SCREW FIXED RECESSED INTO THE REAR BAR JOINERY AS PER THE ELEVATION AND THE ARCHITECTURAL DETAIL. PROVIDE THE STRIP WITH REMOTE POWER SUPPLY LOCATED IN A CONCEALED ACCESSIBLE POSITION NOTED ON THE AS CONSTRUCTED DOCUMENTS. CONFIRM THE BEND PLANE (TOP OR SIDE) ON SITE WITH THE ARCHITECT.	WHITE	RAPID LED R2321 OR R2322 - 2700K + POWER SUPPLY & DALI CONTROLLER	A
S11	14.4W/M 2700K LED	LED STRIP WITHIN A SCREW FIXED EXTRUSION C/W DIFFUSER RECESSED INTO THE BAR FRONT AS PER THE ARCHITECTURAL DETAIL. PROVIDE THE STRIP WITH REMOTE DALI DIMMABLE POWER SUPPLIES AS REQUIRED LOCATE THE POWER SUPPLIES IN A CONCEALED ACCESSIBLE POSITION NOTED ON THE AS CONSTRUCTED DOCUMENTS.	NATURAL	RAPID LED R2334 2700 K PLUS ALUMINIUM EXTRUSION OPAL DIFFUSER AND POWER SUPPLY & DALI CONTROLLER	A
S12	14.4W/M 2700K LED	LED STRIP WITHIN A SCREW FIXED EXTRUSION C/W DIFFUSER RECESSED INTO THE ENTRY CEILING PELMET AS PER THE ARCHITECTURAL DETAIL. PROVIDE THE STRIP WITH REMOTE DALI DIMMABLE POWER SUPPLIES AS REQUIRED LOCATE THE POWER SUPPLIES IN A CONCEALED ACCESSIBLE POSITION NOTED ON THE AS CONSTRUCTED DOCUMENTS.	NATURAL	RAPID LED R2334 2700 K PLUS ALUMINIUM EXTRUSION OPAL DIFFUSER AND POWER SUPPLY & DALI CONTROLLER	A
S13	14.4W/M 4000K LED	LED STRIP WITHIN A SCREW FIXED EXTRUSION C/W DIFFUSER MOUNTED ON THE UNDERSIDE OF THE OVERHEAD CUPBOARDS AGAINST THE SPLASHBACK. PROVIDE THE STRIP WITH A REMOTE DRIVER LOCATED IN A CONCEALED ACCESSIBLE POSITION NOTED ON THE AS CONSTRUCTED DOCUMENTS. PROVIDE A MANUAL SWITCH ON THE SPLASH BACK TO CONTROL THE S13 FITTING.	NATURAL	RAPID LED R2334 4000 K PLUS ALUMINIUM EXTRUSION OPAL DIFFUSER	D
WL01	2No 5W WARM WHITE 240 VOLT TRAILING EDGE DIMMABLE G9 LED LAMPS	300 HIGH DECORATIVE WALL LIGHT MOUNTED AS PER THE ARCHITECTURAL ELEVATION	BASS ALABASTER GLASS	HAVIT HV8079-T-BR	C
WL02	15W 3000K INTEGRATED LED	600 WIDE DECORATIVE WALL LIGHT MOUNTED AS PER THE ARCHITECTURAL ELEVATION	BRONZE	BEACON LIGHTING PRODUCT NAME: GOUGH II ADJUSTABLE WALL BRACKET SKU 190668	A
WL03	6W TRAILING EDGE DIMMABLE A60 240 VOLT E27 2200K LED LAMP	DECORATIVE WALL LIGHT MOUNTED AS PER THE ARCHITECTURAL ELEVATION	GRAPHITE, MATT BRASS	ABOUT SPACE PERFORA	A



ELECTRICAL DESIGN GROUP


ELECTRICAL BUILDING SERVICES CONSULTANTS

P.O. Box 15, SHERWOOD Q. 4075

Phone: (07) 3278 4375 Fax: (07) 3716 0222

Web Site: www.edg.net.au Email: brisbane@edg.net.au

C3685a - ALLENSTOWN HOTEL, ROCKHAMPTON					C3685a-0002(D).xls
ELECTRICAL EQUIPMENT SCHEDULE					
REVISION D - 23 OCTOBER 2026					
THE LIGHT FITTING SUPPLIER CONTACT DETAILS MAY BE AVAILABLE ON THE EDG WEBSITE VIA THE FOLLOWING LINK www.edg.net.au/Links/Lighting.htm					
TYPE	LAMPS	DESCRIPTION	COLOUR / ACCESSORY	CATALOGUE No	REV
WL04	6W TRAILING EDGE DIMMABLE A60 240 VOLT ES 2200K LED LAMP	DECORATIVE WALL LIGHT MOUNTED AS PER THE ARCHITECTURAL ELEVATION	BRASS BRONZE	BEACON LIGHTING PRODUCT MAYFAIR SEASIDE KIMBERLY 1 LIGHT WALL SCONCE SKU 238010	A
WL05	22W 3000K LED	COLUMN MOUNTED ADJUSTABLE IP54 FLOOD LIGHT C/W INTEGRAL DALI DIMMABLE DRIVER CONFIRM THE MOUNTING HEIGHT AND AIMING ON SITE WITH THE ARCHITECT	WHITE	GAMMA ILLUMINATION VIXO SM 1115SM-FL-EK- 22W	A
WL10	6W A60 FILAMENT 240 VOLT E27 2200K LED LAMP	DECORATIVE WALL LIGHT MOUNTED AS PER THE ARCHITECTURAL ELEVATION	BRASS	HAVIT HV3511W-PB	D
WL11	2 NO 5W X 3000K LED	TWIN HEAD ADJUSTABLE WALL LIGHT MOUNTED AS PER THE ARCHITECTURAL ELEVATION REMOTE DRIVER LOCATED IN A CONCEALED ACCESSIBLE POSITION NOTED ON THE AS BUILT DRAWINGS	WHITE	HAVIT LIGHTING HV1335T-HV1337T	C
RD01	15W 2700K LED	90 DIA RECESSED DOWNLIGHT C/W 60 DEG BEAM REMOTE DALI DIMMABLE DRIVER	BLACK	RAPID R1078-BK-15W- XW-60-DALI	A
RD02	15W 2700K LED	90 DIA RECESSED DOWNLIGHT C/W 60 DEG BEAM REMOTE DALI DIMMABLE DRIVER	WHITE	RAPID R1078-WH- 15W-XW-60-DALI	A
RD03	15W 2700K LED	90 DIA RECESSED DOWNLIGHT C/W 60 DEG BEAM REMOTE DALI DIMMABLE DRIVER	WHITE	RAPID R1078-WH- 15W-XW-60-DALI	C
RD04	15W 2700K LED	90 DIA RECESSED DOWNLIGHT C/W 24 DEG BEAM REMOTE DALI DIMMABLE DRIVER	BLACK	RAPID R1078-BK-15W- XW-60-DALI	B
RD05	15W 2700K LED	90 DIA RECESSED DOWNLIGHT C/W 60 DEG BEAM REMOTE DRIVER	BLACK	RAPID R1078-BK-15W- XW-60	B
G1	GAMING BASE KICK LED STRIP LIGHTS TO BE PROVIDED AS PART OF THE GAMING BASE AND CONNECTED BY THE GAMING ELECTRICIAN.				A



ELECTRICAL DESIGN GROUP

ELECTRICAL BUILDING SERVICES CONSULTANTS

P.O. Box 15, SHERWOOD Q. 4075


Phone: (07) 3278 4375 Fax: (07) 3716 0222

Web Site: www.edg.net.au Email: brisbane@edg.net.au

C3685a - ALLENSTOWN HOTEL, ROCKHAMPTON					C3685a-0002(D).xls
ELECTRICAL EQUIPMENT SCHEDULE					
REVISION D - 23 OCTOBER 2026					
THE LIGHT FITTING SUPPLIER CONTACT DETAILS MAY BE AVAILABLE ON THE EDG WEBSITE VIA THE FOLLOWING LINK www.edg.net.au/Links/Lighting.htm					
TYPE	LAMPS	DESCRIPTION	COLOUR / ACCESSORY	CATALOGUE No	REV
FS01	1W LED AT 500 CENTRES	FESTOON LIGHTS WITH NEW 24V DC IP65 FESTOON LIGHTING TO BE FIXED TO A 316 STAINLESS STEEL WIRE SUPPORT SYSTEM. SUPPLY THE NEW FESTOON LIGHTS VIA REMOTE DALI DIMMABLE DRIVERS IN A CONCEALED ACCESSIBLE POSITIONS NOTED ON THE AS CONSTRUCTED DOCUMENTS. CONFIRM THE LENGTH AND POSITION ON SITE ENSURE THE FESTOON LIGHTS ARE LOWER THAN THE ADJACENT CEILING FANS	BLACK CABLE AND FIXINGS 316 STAINLESS STEEL SUPPORT AND FIXINGS	FIRE FLY FFC-LS-50-24VE27-BK	A
SL01	3No 5W WARM WHITE 240 VOLT TRAILING EDGE DIMMABLE GU10 LED LAMPS	THREE TUBE SURFACE MOUNTED CAN DOWNLIGHT C/W REMOTE DALI TO TRAILING EDGE CONVERTER	BLACK	BEACON LIGHTING MFL TRIVUIM 3 LIGHT SKU 087152	A
SL02	26W 4000K	600 x 600 LAY IN FLAT PLATE LED FITTING C/W REMOTE DRIVER MOUNTED IN A FLUSH RECESSED PB MOUNTING KIT	WHITE TRIM	GAMMA ILLUMINATION AXIS 1548-4K-26W C/W FLUSH RECESS PB KIT	D
SL10	REPLACE THE EXISTING 1200 LONG SURFACE BATTEN WITH A NEW IP66 3000K LED BATTEN.				A
SL11	36W LED 4000K	1200 LONG SURFACE MOUNTED IP66 DIFFUSED BATTEN C/W INTEGRAL ELECTRONIC CONTROL GEAR AND SENSOR	LIGHT GREY	GAMMA STORM 1558-CCT-36W MS	A
E1	LED	EMERGENCY LIGHT: RECESSED NON-MAINTAINED EMERGENCY LIGHT. AS2293 CLASSIFICATION C0-D40 - C90-D40.	BLACK	CLEVERTRONICS LLIFE-BLK	B
E2	LED	EMERGENCY LIGHT: RECESSED NON-MAINTAINED EMERGENCY LIGHT. AS2293 CLASSIFICATION C0-D40 - C90-D40.	WHITE	CLEVERTRONICS LLIFE	B
EX	LED	EXIT LIGHT: MAINTAINED 24M VIEWING DISTANCE EXIT LIGHT C/W DIFFUSERS & DIRECTIONAL ARROWS AS SHOWN. CEILING SURFACE MOUNT OR WALL MOUNT BETWEEN 2100mm & 2700mm AFFL IF THERE IS NO VERTICAL SURFACE TO MOUNT THE FITTING ON WITHIN THIS RANGE CONFIRM THE MOUNTING HEIGHT WITH THE ENGINEER. AS2293 CLASSIFICATION C0-D1.25- C90-D2	BLACK UNLESS NOTED AS WH THEN WHITE BODY	CLEVERTRONICS LUBPRO-SM-BLK	B
F01	EXISTING CEILING FAN	EXISTING CEILING FAN TO BE RETAINED AND RESUPPLIED WITH THE EXISTING CONTROLS RELOCATED ADJACENT SP1.			A
F02	CEILING FAN	60 INCH CEILING FAN C/W MOUNTING THAT ALLOWS THE FAN TO HANG TRUE AND A REMOTE CONTROLLER WALL MOUNTED ADJACENT SP3. CONFIRM THE DROP ON SITE WITH THE ARCHITECT	WHITE / WHITE	BIG ASS HAIKU OUTDOOR	A
L1	THIS LIGHT FITTING HAS BEEN RELABELLED SL02				D

C3685a-0002(D).xls

Pages inc. any attach. 4 of 8



ELECTRICAL DESIGN GROUP


ELECTRICAL BUILDING SERVICES CONSULTANTS

P.O. Box 15, SHERWOOD Q. 4075

Phone: (07) 3278 4375 Fax: (07) 3716 0222

Web Site: www.edg.net.au Email: brisbane@edg.net.au

C3685a - ALLENSTOWN HOTEL, ROCKHAMPTON					C3685a-0002(D).xls
ELECTRICAL EQUIPMENT SCHEDULE					
REVISION D - 23 OCTOBER 2026					
THE LIGHT FITTING SUPPLIER CONTACT DETAILS MAY BE AVAILABLE ON THE EDG WEBSITE VIA THE FOLLOWING LINK www.edg.net.au/Links/Lighting.htm					
TYPE	LAMPS	DESCRIPTION	COLOUR / ACCESSORY	CATALOGUE No	REV
PD01	9.6W/M 3000K DOTLESS LED STRIP	LED STRIP WITHIN A SCREW FIXED EXTRUSION C/W DIFFUSER SURFACE MOUNTED TO THE UNDERSIDE OF THE FEATURE STEEL BULKHEAD AS PER THE ARCHITECTURAL DETAIL. PROVIDE THE STRIP WITH REMOTE DALI DIMMABLE POWER SUPPLIES AS REQUIRED LOCATE THE POWER SUPPLIES IN A CONCEALED ACCESSIBLE POSITION NOTED ON THE AS CONSTRUCTED DOCUMENTS. ALL CABLING MUST RUN CONCEALED WITHIN THE STEEL STRUCTURE.	CUSTOM POWDERCOATED BLACK	HAVIT LIGHTING HV9693-1922 C/W HV9761	D
PD02	7W 2700K 240V TRAILING EDGE DIMMABLE EXPOSED FILAMENT A60 ES LED	DECORATIVE 505 DIA LIGHT PENDANT CONFIRM THE POSITION AND DROP LENGTH ON SITE WITH THE ARCHITECT	TAN	BEACON INKA 1 LIGHT DRUM PENDANT IN NATURAL WEAVE SKU 018162	D
LP01	ACCOMMODATION WALL MOUNTED LIGHT SUPPLIED BY SPECIALIST AF SOURCING AND INSTALLED BY THE ELECTRICAL CONTRACTOR.				A
LP02	ACCOMMODATION WALL MOUNTED LIGHT SUPPLIED BY SPECIALIST AF SOURCING AND INSTALLED BY THE ELECTRICAL CONTRACTOR.				A
LP03	ACCOMMODATION CORRIDOR PENDANT LIGHT SUPPLIED BY SPECIALIST AF SOURCING AND INSTALLED BY THE ELECTRICAL CONTRACTOR.				A
LP04	ACCOMMODATION SURFACE MOUNTED DOWN LIGHT SUPPLIED BY SPECIALIST AF SOURCING AND INSTALLED BY THE ELECTRICAL CONTRACTOR.				
LP07	ACCOMMODATION SURFACE MOUNTED OYSTER LIGHT SUPPLIED BY SPECIALIST AF SOURCING AND INSTALLED BY THE ELECTRICAL CONTRACTOR.				A
TRL02	ACCOMMODATION SURFACE MOUNTED TRACK LIGHT AND THE ASSOCIATED TRACK SUPPLIED BY SPECIALIST AF SOURCING AND INSTALLED BY THE ELECTRICAL CONTRACTOR. AS PART OF THE ELECTRICAL SUB CONTRACT PROVIDE EACH TRL02 FITTING WITH A 2700K GU10 (LG016W) LAMP.				A
TRL04	ACCOMMODATION WALL MOUNTED BEDHEAD READING LIGHT SUPPLIED BY SPECIALIST AF SOURCING AND INSTALLED BY THE ELECTRICAL CONTRACTOR.				A
CHANNEL x		CONTROL CHANNEL WITH A NUMERICAL REFERENCE. REFER TO THE POWER AND LIGHTING CONTROL SCHEMATIC / SCHEDULE			A
LIGHTING CONTROL SWITCH PANEL 1 (SP1)		PROGRAMMABLE SWITCH PANEL C/W CENTRAL LCD DISPLAY MOUNTED AT 1000mm AFFL UNLESS NOTED OTHERWISE. CONFIGURE THE SP1 AS PER THE SP1 SCHEMATIC.	WHITE	ZEN CONTROL SSD	A
LIGHTING CONTROL SWITCH PANEL 2 (SP2)		PROGRAMMABLE SWITCH PANEL C/W CENTRAL LCD DISPLAY MOUNTED AT 1000mm AFFL UNLESS NOTED OTHERWISE. CONFIGURE THE SP1 AS PER THE SP1 SCHEMATIC.	WHITE	ZEN CONTROL SSD	A
LIGHTING CONTROL SWITCH PANEL 3 (SP3)		PROGRAMMABLE SWITCH PANEL C/W CENTRAL LCD DISPLAY MOUNTED AT 1000mm AFFL UNLESS NOTED OTHERWISE. CONFIGURE THE SP1 AS PER THE SP1 SCHEMATIC.	WHITE	ZEN CONTROL SSD	A



ELECTRICAL DESIGN GROUP


ELECTRICAL BUILDING SERVICES CONSULTANTS

P.O. Box 15, SHERWOOD Q. 4075

Phone: (07) 3278 4375 Fax: (07) 3716 0222

Web Site: www.edg.net.au Email: brisbane@edg.net.au

C3685a - ALLENSTOWN HOTEL, ROCKHAMPTON					C3685a-0002(D).xls
ELECTRICAL EQUIPMENT SCHEDULE					
REVISION D - 23 OCTOBER 2026					
THE LIGHT FITTING SUPPLIER CONTACT DETAILS MAY BE AVAILABLE ON THE EDG WEBSITE VIA THE FOLLOWING LINK www.edg.net.au/Links/Lighting.htm					
TYPE	LAMPS	DESCRIPTION	COLOUR / ACCESSORY	CATALOGUE No	REV
ONE-WAY LIGHT SWITCH		ONE-WAY LIGHT SWITCH C/W CIRCUIT IDENTIFICATION ON THE FACEPLATE BEHIND THE SURROUND MOUNTED AT 1000mm AFFL UNLESS NOTED OTHERWISE.	WHITE UNLESS NOTED AS BLACK	CLIPSAL ICONIC SERIES	A
PROXIMITY DETECTOR SWITCH (PD)		ADJUSTABLE FLUSH RECESSED 360 DEGREE PIR PRESENCE DETECTOR TO OPERATE THE ASSOCIATED LIGHTS FOR A PRE-SET AMOUNT OF TIME. ADJUST THE TIME AND SENSITIVITY ON SITE AS DIRECTED BY THE ENGINEER. SUBMIT DETAILS OF THE MOVEMENT DETECTOR SWITCH FOR APPROVAL PRIOR TO ORDERING	WHITE	CLIPSAL	A
SINGLE POWER OUTLET		SINGLE POWER OUTLET C/W CIRCUIT IDENTIFICATION ON THE FACEPLATE BEHIND THE SURROUND MOUNT AT 300mm AFFL U.N.O. RATING 10A U.N.O.	WHITE UNLESS NOTED AS BLACK	CLIPSAL ICONIC SERIES	A
AUTO DOOR SINGLE POWER OUTLET (AD)		SINGLE POWER OUTLET C/W CIRCUIT IDENTIFICATION LOCATED CONCEALED WITHIN THE AUTO DOOR HEAD MULLION RATING 10A U.N.O.	WHITE	CLIPSAL ICONIC SERIES	A
DOUBLE POWER OUTLET		DOUBLE POWER OUTLET C/W CIRCUIT IDENTIFICATION ON THE FACEPLATE BEHIND THE SURROUND MOUNT AT 300mm AFFL U.N.O. RATING 10A U.N.O.	WHITE UNLESS NOTED AS BLACK (BK)	CLIPSAL ICONIC SERIES	A
DOUBLE POWER OUTLET WITH USB		DOUBLE POWER OUTLET C/W USB A AND USB C CHARGER, CIRCUIT IDENTIFICATION ON THE FACEPLATE BEHIND THE SURROUND MOUNT ABOVE BENCH	WHITE	CLIPSAL ICONIC SERIES	A
WEATHERPROOF POWER OUTLET (WP)		IP54 WEATHERPROOF SINGLE / DOUBLE POWER OUTLET AS NOTED ON DRAWING C/W COVER FLAP OVER SOCKET. MOUNT AT MINIMUM 1100mm AFFL U.N.O. RATING 10A U.N.O.	-	CLIPSAL WSCF227F	A
OUTSIDE AIR FAN GPO (AC)		OUTSIDE AIR FAN GPO / CONNECTION TYPE AND LOCATION TO BE AS DIRECTED BY THE MECHANICAL SUB CONTRACTOR.			A
TOILET EXHAUST FAN GPO (TE)		TOILET EXHAUST FAN GPO TO BE LOCATED IN THE CEILING SPACE ADJACENT THE TOILET EXHAUST FAN			A
SIGN CONNECTION		COORDINATE THE LOCATION AND CONNECTION WITH THE SIGN CONTRACTOR ENSURING THE GPO / ISOLATORS ARE PROVIDED WITH APPROPRIATE WEATHER PROTECTION AND ARE CONCEALED FROM VIEW.			A
SINGLE-PHASE ISOLATOR		SINGLE-PHASE WEATHERPROOF ISOLATOR. MOUNT AT 1350mm AFFL U.N.O. RATING 20A U.N.O. CONNECT TO EQUIPMENT VIA FLEXIBLE CONDUIT.	-	CLIPSAL WHT20	A



ELECTRICAL DESIGN GROUP

ELECTRICAL BUILDING SERVICES CONSULTANTS

P.O. Box 15, SHERWOOD Q. 4075

Phone: (07) 3278 4375 Fax: (07) 3716 0222

Web Site: www.edg.net.au Email: brisbane@edg.net.au

C3685a - ALLENSTOWN HOTEL, ROCKHAMPTON


C3685a-0002(D).xls

ELECTRICAL EQUIPMENT SCHEDULE

REVISION D - 23 OCTOBER 2026

THE LIGHT FITTING SUPPLIER CONTACT DETAILS MAY BE AVAILABLE ON THE EDG WEBSITE VIA THE FOLLOWING LINK
www.edg.net.au/Links/Lighting.htm

TYPE	LAMPS	DESCRIPTION	COLOUR / ACCESSORY	CATALOGUE No	REV
THREE-PHASE ISOLATOR		THREE-PHASE WEATHERPROOF ISOLATOR. MOUNT AT 1350mm AFFL U.N.O. RATING 20A U.N.O. CONNECT TO EQUIPMENT VIA FLEXIBLE CONDUIT.	-	CLIPSAL WHT35	A
MDB		EXISTING HOTEL MAIN DISTRIBUTION BOARD TO BE MODIFIED AS PER THE NOTES. UPDATE THE LABELLING ACCORDINGLY.			A
DB-G		EXISTING DISTRIBUTION BOARD DB-G. ALL EXISTING CIRCUITS THAT BECOME REDUNDANT ARE TO BE REMOVED.			A
DB-K		EXISTING DISTRIBUTION BOARD DB-K. ALL EXISTING CIRCUITS THAT BECOME REDUNDANT ARE TO BE REMOVED.			A
DB-O		EXISTING DISTRIBUTION BOARD DB-O. ALL EXISTING CIRCUITS THAT BECOME REDUNDANT ARE TO BE REMOVED.			A
DB-B		PROVIDE A NEW DISTRIBUTION BOARD DB-B AS PER THE DB-B SCHEDULE AND NOTES.			A
FIRE INDICATOR PANEL (FIP)		SURFACE MOUNTED WHITE AS 1670.1 COMPLAINT FIRE INDICATOR PANEL INCORPORATING THE EWCIE AND FDCIE. PROVIDE THE FIP WITH A MANUAL CALL POINT AND A SCREW FIXED MECHANICALLY ENGRAVED ZONE PLAN			A
SMOKE DETECTOR		SURFACE MOUNTED AS7240.7 POINT SMOKE DETECTORS WITH A PERFORMANCE OF 6 TO 12 % OBS/M SET AT 7.8 %. BLACK UNLESS NOTED AS (WH) THEN WHITE.			C
CONCEALED SPACE SMOKE DETECTOR		CONCEALED SPACE ADDRESSABLE AS7240.7 POINT SMOKE DETECTORS WITH A PERFORMANCE OF 6 TO 12 % OBS/M SET AT 7.8 %. PROVIDE THE DETECTOR WITH A WHITE REMOTE INDICATOR AND ACCESS BRACKET AS REQUIRED.			A
ASPIRATING SMOKE DETECTOR		ADDRESSABLE ASPIRATING SMOKE DETECTOR AS7240 LOCATED IN AN ACCESSIBLE POSITION IN THE CEILING SPACE TO PROTECT THE LIFT SHAFT IN ACCORDANCE WITH AS1670.1 -2018.			A
THERMAL DETECTOR		SURFACE MOUNTED AS1670.1 TYPE A FIXED TEMPERATURE ADDRESSABLE THERMAL DETECTOR. WHITE UNLESS NOTED AS BLACK			A
THERMAL DETECTOR TYPE B		SURFACE MOUNTED AS1670.1 TYPE B SEALED FIXED TEMPERATURE ADDRESSABLE THERMAL DETECTOR. WHITE UNLESS NOTED AS BLACK			A
THERMAL DETECTOR TYPE D		SURFACE MOUNTED AS1670.1 TYPE D SEALED FIXED TEMPERATURE ADDRESSABLE THERMAL DETECTOR. WHITE UNLESS NOTED AS BLACK			A
THERMAL DETECTOR DUCT PROBE		AS1670.1 FIXED TEMPERATURE DUCT PROBE ADDRESSABLE THERMAL DETECTOR.			A
RECESSED FIRE ALARM SPEAKER		RECESSED 5W TWO-TONE 8-INCH CONE ALERT AND EVACUATION SPEAKER TO AS1670.1 C/W 100V MULTI-TAP TRANSFORMER AND GRILLE BLACK UNLESS NOTED AS (WH) THEN WHITE.			C
SURFACE MOUNTED FIRE ALARM SPEAKER		SURFACE MOUNT 5W TWO-TONE 8-INCH CONE ALERT AND EVACUATION SPEAKER TO AS1670.1 C/W 100V MULTI-TAP TRANSFORMER AND WHITE GRILLE.			B



ELECTRICAL DESIGN GROUP

ELECTRICAL BUILDING SERVICES CONSULTANTS

P.O. Box 15, SHERWOOD Q. 4075

Phone: (07) 3278 4375 Fax: (07) 3716 0222

Web Site: www.edg.net.au Email: brisbane@edg.net.au

C3685a - ALLENSTOWN HOTEL, ROCKHAMPTON

C3685a-0002(D).xls

ELECTRICAL EQUIPMENT SCHEDULE

REVISION D - 23 OCTOBER 2026

THE LIGHT FITTING SUPPLIER CONTACT DETAILS MAY BE AVAILABLE ON THE EDG WEBSITE VIA THE FOLLOWING LINK
www.edg.net.au/Links/Lighting.htm

TYPE	LAMPS	DESCRIPTION	COLOUR / ACCESSORY	CATALOGUE No	REV
FIRE ALARM HORN SPEAKER		SURFACE MOUNTED TWO-TONE 30W ALERT AND EVACUATION HORN SPEAKER TO AS1670.1 C/W 100V MULTI-TAP TRANSFORMER. MOUNT AT HIGH LEVEL.			A
FIRE ALARM VISUAL INDICATOR		WALL MOUNTED FIRE ALARM VISUAL ALARM STROBE LIGHT AS PER AS1670.1			A
FIRE ALARM DOOR INTERFACE		INTERFACE THE FIRE DETECTION SYSTEM TO THE DOOR CONTROL SYSTEM SUCH THAT THE DOOR IS UNLOCKED VIA A FAIL SAFE SIGNAL UPON ALARM.			A
ACCOMMODATIONS LEVEL COMMUNICATION RACK (CR-A)		ONCE THE AV EQUIPMENT HAS BEEN RELOCATED FROM THE EXISTING WALL MOUNTED RACK. PROVIDE A NEW WALL MOUNTED RACK OF EQUAL SIZE TO THE EXISTING TO ACCOMMODATE THE ACCOMMODATION LEVEL COMMUNICATIONS SERVICES. PROVIDE ALL NECESSARY PATCH PANEL AND FOUR CAT 6 TIE CABLE TO THE HOTELS EXISTING COMMUNICATION RACK.			A
ACCOMMODATION LEVEL COMMUNICATIONS OUTLET		ACCOMMODATION RJ45 CAT-6 COMMUNICATIONS OUTLET, CABLED BACK TO A CAT 6 PATCH PANEL IN COMMUNICATIONS RACK CR-A VIA BLUE 4-PAIR CAT-6 UTP CABLE. PERMANENT LABELLING	WHITE UNLESS NOTED AS BLACK	CLIPSAL ICONIC SERIES	A