


C3701a - NORTHS DEVILS RUGBY LEAGUE CLUB - CANTEEN & GAMEDAY OFFICE

C3701a-0002(B).xls

ELECTRICAL EQUIPMENT SCHEDULE

REVISION B - 23 JUNE 2026

| THE LIGHT FITTING SUPPLIER CONTACT DETAILS MAY BE AVAILABLE ON THE EDG WEBSITE VIA THE FOLLOWING LINK www.edg.net.au/Links/Lighting.htm | | | | | |
|---|--------------------------|--|--------------------|--|-----|
| TYPE | LAMPS | DESCRIPTION | COLOUR / ACCESSORY | CATALOGUE No | REV |
| L1 | 40W 4000K LED | 1200 X 300 LAY IN FLAT PLATE LED FITTING C/W REMOTE DRIVER MOUNTED IN A FLUSH RECESSED PLASTER BOARD KIT | WHITE TRIM | GAMMA ILLUMINATION PHANTOM 884501 | A |
| L2 | 1530 LUMEN / M 4000K LED | SURFACE MOUNTED 70 X 70 LINEAR EXTRUSION C/W INTEGRAL DRIVER AND OPTEK DIFFISER. PROVIDE THE FITTING WITH CUSTOM MOUNTING BRACKETS TO ALLOW IT TO BE MOUNTED HORIZONTALLY LOCATE THE FITTINGS 150MM OFF THE WALL | WHITE | KLIK SYSTEMS KALLI 060 BEAM D | A |
| L3 | 1530 LUMEN / M 4000K LED | SURFACE MOUNTED 70 X 70 LINEAR EXTRUSION C/W INTEGRAL DRIVER AND OPTEK DIFFISER. PROVIDE THE FITTING WITH CUSTOM MOUNTING BRACKETS TO ALLOW IT TO BE MOUNTED HORIZONTALLY | WHITE | KLIK SYSTEMS KALLI 060 BEAM D | A |
| L4 | 1530 LUMEN / M 4000K LED | SURFACE MOUNTED 70 X 70 LINEAR EXTRUSION C/W INTEGRAL DRIVER AND OPTEK DIFFISER. PROVIDE THE FITTING WITH CUSTOM MOUNTING BRACKETS TO ALLOW IT TO BE MOUNTED HORIZONTALLY PROVIDE THE FITTING WITH AN INTEGRAL E1 EMERGENCY LIGHT POSITIONED CENTRALLY | WHITE | KLIK SYSTEMS KALLI 060 BEAM D | A |
| L5 | 1530 LUMEN / M 4000K LED | SURFACE MOUNTED 70 X 70 LINEAR EXTRUSION C/W INTEGRAL DRIVER AND OPTEK DIFFISER. THE FITTING IS TO FOLLOW THE RAKE OF THE CEILING PROVIDE THE FITTING WITH AN INTEGRAL E1 EMERGENCY LIGHT POSITIONED CENTRALLY | WHITE | KLIK SYSTEMS KALLI 060 BEAM D | A |
| L6 | 1530 LUMEN / M 4000K LED | SURFACE MOUNTED 70 X 70 LINEAR EXTRUSION C/W INTEGRAL DRIVER AND OPTEK DIFFISER. THE FITTING IS TO FOLLOW THE RAKE OF THE CEILING | WHITE | KLIK SYSTEMS KALLI 060 BEAM D | A |
| L7 | 1530 LUMEN / M 4000K LED | SURFACE MOUNTED 70 X 70 LINEAR EXTRUSION C/W INTEGRAL DRIVER AND OPTEK DIFFISER. PROVIDE THE FITTING WITH CUSTOM MOUNTING BRACKETS TO ALLOW IT TO BE MOUNTED HORIZONTALLY AGAINST THE WALL | WHITE | KLIK SYSTEMS KALLI 060 BEAM D | A |
| L8 | 90W 4000K LED | ADJUSTABLE FLOOD LIGHT C/W INTEGRAL DRIVER PROVIDE THE FITTING WITH A CUSTOM MOUNTING BRACKET TO ALLOW IT TO BE MOUNTD HORIZONTALLY ON THE END OF THE STRUCTURAL BEAM. | SILVER | GAMMA ILLUMINATION ALTUS 1345-4K-90W | A |
| L9 | 90W 4000K LED | ADJUSTABLE FLOOD LIGHT C/W INTEGRAL DRIVER MOUNT THE FITTING ONT EH COLUMN IMMEDIATLLY BELOW THE CEILING | SILVER | GAMMA ILLUMINATION ALTUS 1345-4K-90W | A |
| L10 | 40W 4000K LED | 1200 X 300 LAY IN FLAT PLATE LED FITTING C/W REMOTE DALI DIMABLE DRIVER MOUNTED IN A FLUSH RECESSED PLASTER BOARD KIT | WHITE TRIM | GAMMA ILLUMINATION PHANTOM 884501 DALI | A |
| L11 | 8W 4000K LED | RECESSED 47 DEG BEAM DOWNLIGHT C/W REMOTE DRIVER | WHITE TRIM | GAMMA ILLUMINATION MYLO 1004-WFL-4K-8W | A |




C3701a - NORTHS DEVILS RUGBY LEAGUE CLUB - CANTEEN & GAMEDAY OFFICE

C3701a-0002(B).xls

ELECTRICAL EQUIPMENT SCHEDULE

REVISION B - 23 JUNE 2026

| THE LIGHT FITTING SUPPLIER CONTACT DETAILS MAY BE AVAILABLE ON THE EDG WEBSITE VIA THE FOLLOWING LINK www.edg.net.au/Links/Lighting.htm | | | | | |
|---|---------------|--|--|--|-----|
| TYPE | LAMPS | DESCRIPTION | COLOUR / ACCESSORY | CATALOGUE No | REV |
| L12 | 36W LED 4000K | SURFACE MOUNTED IP66 1200 LONG BATTEN C/W INTEGRAL DRIVER AND OCCUPANCY SENSOR | LIGHT GREY | GAMMA STORM 1558-CCT-36+SENSOR | A |
| L13 | 12W 4000K LED | WALL MOUNTED CAN DOWNLIGHT C/W INTEGRAL DRIVER | SILVER | GAMMA ILLUMINATION PEPPER MAX 2 - 1826-CCT-12W | A |
| E1 | LED | EMERGENCY LIGHT: RECESSED NON-MAINTAINED EMERGENCY LIGHT. AS2293 CLASSIFICATION C0-D80 - C90-D80. | WHITE | CLEVERTRONICS CLIFE-PRO | A |
| EX | LED | EXIT LIGHT: MAINTAINED 24M VIEWING DISTANCE EXIT LIGHT C/W DIFFUSERS & DIRECTIONAL ARROWS AS SHOWN. CEILING OR WALL MOUNT BETWEEN 2100mm & 2700mm AFFL IF THERE IS NO VERTICAL SURFACE TO MOUNT THE FITTING ON WITHIN THIS RANGE CONFIRM THE MOUNTING HEIGHT WITH THE ENGINEER. AS2293 CLASSIFICATION C0-E1.6 - C90-E2. CONFIGURE THE FITTING SUCH THAT IT IS HORIZONTAL AND PROVIDE ALL NECESSARY MOUNTING ACCESSORIES. | WHITE LOGO GREEN BACKGROUND WHITE BODY | CLEVERTRONICS CWELED | A |
| HEAT LAMP (HL01) | | PENDANT HEAT LAMP C/W IR LAMP SUSPENDED AS PER THE ARCHITECTURAL DETAIL. | WHITE | HATCO DL-600(L) | A |
| ONE-WAY LIGHT SWITCH | | ONE-WAY LIGHT SWITCH C/W CIRCUIT IDENTIFICATION ON THE FACEPLATE BEHIND THE SURROUND MOUNTED AT 1000mm AFFL UNLESS NOTED OTHERWISE. | WHITE | CLIPSAL C2000 SERIES 30USM | A |
| DALI LIGHT SWITCH | | MANUAL ROTARY DALI POT DIMMER C/W CIRCUIT IDENTIFICATION ON THE FACEPLATE BEHIND THE SURROUND THE DALI DIMMER IS TO BE MOUNTED REMOTELY WITH THE POSITION CONFIRMED ON SITE. | WHITE | CLIPSAL C2000 SMARTSCAPE DALI-RD20-M ROTARY DIMMER | A |
| TWO-WAY LIGHT SWITCH | | TWO-WAY LIGHT SWITCH C/W CIRCUIT IDENTIFICATION ON THE FACEPLATE BEHIND THE SURROUND MOUNTED AT 1000mm AFFL UNLESS NOTED OTHERWISE. | WHITE | CLIPSAL C2000 SERIES 30USM | A |
| SINGLE POWER OUTLET | | SINGLE POWER OUTLET C/W CIRCUIT IDENTIFICATION ON THE FACEPLATE BEHIND THE SURROUND MOUNT AT 300mm AFFL U.N.O. RATING 10A U.N.O. | WHITE | CLIPSAL C2000 SERIES | A |
| DOUBLE POWER OUTLET | | DOUBLE POWER OUTLET C/W CIRCUIT IDENTIFICATION ON THE FACEPLATE BEHIND THE SURROUND MOUNT AT 300mm AFFL U.N.O. RATING 10A U.N.O. | WHITE | CLIPSAL C2000 SERIES | A |
| WEATHERPROOF POWER OUTLET (WP) | | IP54 WEATHERPROOF SINGLE / DOUBLE POWER OUTLET AS NOTED ON DRAWING C/W COVER FLAP OVER SOCKET. MOUNT AT MINIMUM 1000mm AFFL U.N.O. RATING 10A U.N.O. | - | CLIPSAL WSCF227F | A |



ELECTRICAL DESIGN GROUP

ELECTRICAL BUILDING SERVICES CONSULTANTS

P.O. Box 15, SHERWOOD Q. 4075

Phone: (07) 3278 4375 Fax: (07) 3716 0222

Web Site: www.edg.net.au Email: brisbane@edg.net.au


C3701a - NORTHS DEVILS RUGBY LEAGUE CLUB - CANTEEN & GAMEDAY OFFICE

C3701a-0002(B).xls

ELECTRICAL EQUIPMENT SCHEDULE

REVISION B - 23 JUNE 2026

| THE LIGHT FITTING SUPPLIER CONTACT DETAILS MAY BE AVAILABLE ON THE EDG WEBSITE VIA THE FOLLOWING LINK www.edg.net.au/Links/Lighting.htm | | | | | |
|---|-------|--|---|-----------------------------|-----|
| TYPE | LAMPS | DESCRIPTION | COLOUR / ACCESSORY | CATALOGUE No | REV |
| HAND DRYER CONNECTION (HD) | | SINGLE POWER OUTLET C/W CIRCUIT IDENTIFICATION ON THE FACEPLATE BEHIND THE SURROUND FOR THE HAND DRYER MOUNT THE GPO AS PER THE ARCHITECTURAL DETAIL | WHITE | CLIPSAL C2000 SERIES | A |
| MATV OUTLET | | MATV OUTLET CONNECTED TO A DEDICATED ANTENNA TO PROVIDE THE LOCALLY AVAILABLE FREE TO AIR TV SERVICES | WHITE | CLIPSAL C2000 SERIES | A |
| MATV ANTENNA | | ROOF MOUNTED MATV ANTENNA TO RECEIVE AND DISTRIBUTE THE LOCALLY AVAILABLE FREE TO AIR TV SERVICES | | | A |
| SINGLE-PHASE ISOLATOR | | SINGLE-PHASE WEATHERPROOF ISOLATOR. MOUNT AT 1350mm AFFL U.N.O. RATING 20A U.N.O. CONNECT TO EQUIPMENT VIA FLEXIBLE CONDUIT. | - | CLIPSAL WHT20 | A |
| THREE-PHASE ISOLATOR | | THREE-PHASE WEATHERPROOF ISOLATOR. MOUNT AT 1350mm AFFL U.N.O. RATING 20A U.N.O. CONNECT TO EQUIPMENT VIA FLEXIBLE CONDUIT. | - | CLIPSAL WHT35 | A |
| HAND DRYER CONNECTION (HD) | | 20A ISOLATING SWITCH WALL MOUNTED AT 2400mm AFFL AND CONNECTED TO THE HAND DRYER UNIT AS PER DETAIL. | | CLIPSAL ICONIC SERIES 30USM | A |
| HORN | | 30W SURFACE MOUNTED ADJUSTABLE IP66 MULTI TAP 100V 8 OHM PUBLIC ADDRESS HORN SPEAKER CABLED BACK TO THE ASSOCIATED AMPLIFIER WITHIN THE COMMUNICATIONS RACK VIA 1.5MM MARKED FIG 8 CABLE. | WHITE | AUSTRALIAN MONITOR SH30 | A |
| CAT 6 COMMUNICATIONS OUTLET | | RJ45 CAT-6 COMMUNICATIONS OUTLET, CABLED BACK TO THE COMMUNICATIONS RACK CR-A TERMINATED ONTO FACILITY PATCH PANELS VIA 4-PAIR CAT-6 UTP CABLE. MOUNT UP TO 3 RJ45 OUTLETS PER MULTI-GANG FACEPLATE WITH SEPARATE PERMANENT LABELLING FOR EACH OUTLET. | WHITE UNLESS NOTED OTHERWISE. CEILING MOUNTED OUTLETS TO MATCH CEILING COLOUR | CLIPSAL C2000 SERIES MOLEX | A |
| COMMUNICATIONS RACK CR-A | | WALL MOUNTED 22 RU MINIMUM 600 DEEP COMMUNICATIONS RACK CR-A PROVIDE THE RACK WITH THE REQUIRED CAT 6 PATCH PANELS, CABLE MANAGEMENT, A FIBER OPTIC AND A UNDERGROUND LOOSE TUBE GEL FILLED 12 CORE OS2 OPTICAL FIBRE CABLE FULLY TERMINATED WITH LC CONNECTORS CONNECTING CR-A TO A NEW FIBER OPTIC IN RACK CR-E. | | | A |
| COMMUNICATIONS RACK CR-E | | EXISTING COMMUNICATIONS RACK TO BE UTILISED TO FACILITATE THE TERMINATION OF THE NEW CR-E FIBRE CABLE. | | | A |
| DB-A | | WALL MOUNTED DISTRIBUTION BOARD DB-A REFER TO THE NOTES AND DISTRIBUTION BOARD DB-A SCHEDULE FOR ADDITIONAL INFORMATION AND REQUIREMENTS. PROVIDE A SHOP DRAWING OF THE DB FOR APPROVAL. | | | A |
| DB-7 | | NO LONGER REQUIRED | | | B |
| MSB | | REPLACE THE EXISTING MCCB THAT IS NOT BEING USED WITH A NEW 100 AMP MCCB TO SUPPLY DB-A VIA A NEW UNDERGROUND SUBMAIN. UPDATE THE LABEL TO REFLECT THE NEW USE. REFER TO THE NOTES FOR DETAILS OF THE SUBMAIN TO DB-A. | | | B |



ELECTRICAL DESIGN GROUP

ELECTRICAL BUILDING SERVICES CONSULTANTS

P.O. Box 15, SHERWOOD Q. 4075

Phone: (07) 3278 4375 Fax: (07) 3716 0222

Web Site: www.edg.net.au Email: brisbane@edg.net.au

C3701a - NORTHS DEVILS RUGBY LEAGUE CLUB - CANTEEN & GAMEDAY OFFICE

C3701a-0002(B).xls

ELECTRICAL EQUIPMENT SCHEDULE

REVISION B - 23 JUNE 2026

| THE LIGHT FITTING SUPPLIER CONTACT DETAILS MAY BE AVAILABLE ON THE EDG WEBSITE VIA THE FOLLOWING LINK www.edg.net.au/Links/Lighting.htm | | | | | |
|---|-------|--|--------------------|--------------|-----|
| TYPE | LAMPS | DESCRIPTION | COLOUR / ACCESSORY | CATALOGUE No | REV |
| CCTV CAMERA | | POE IP CCTV CAMERA SURMAFCE MOUNTED TO BE CONNECTED TO A DEDICATED PATCH PANEL IN CR-A VIA A CAT 6 CABLE. | | | A |
| RISER | | PROVIDE A 150 WIDE COMMUNICATIONS CABLE TRAY VERTICALLY FROM THE UNDER GROUND CONDUIT TO THE CEILING SPACE. PROVIDE A CALOUR BOND HAT SECTION OVER THE CABLE TRAY. | | | A |
| SECURITY EQUIPMENT | | WALL MOUNT THE SECURITY EQUIPMENT MOUNT THE ASSOCIATED GPO WITHIN THE SECURITY PANEL | | | A |
| SECURITY PIEZO SIREN | | FLUSH RECESSED PIEZO SIREN SUBMIT DETAILS OF THE PIEZO SIRENS FOR APPROVAL PRIOR TO ORDERING. | | | A |
| SECURITY INTRUDER DETECTOR | | DUAL-TECHNOLOGY MOVEMENT DETECTORS WALL MOUNTED AS PER THE MANUFACTURER'S SPECIFICATION. CONNECT TO THE LOCAL SECURITY EQUIPMENT WITH ONE DETECTOR PER ZONE. TYPE TO MATCH THE EXISTING DETECTORS USED IN THE ADMINISTRATION BUILDING. PROGRAM THE SECURITY SYSTEM AS REQUIRED TO ACCOMMODATE THE NEW DETECTORS AND CHANGES TO THE SATISFACTION OF THE SCHOOL. SUBMIT DETAILS OF THE DETECTORS INCLUDING THE MOUNTING ARRANGEMENTS FOR APPROVAL PRIOR TO ORDERING. | | | A |
| SECURITY KEY PAD (KP) | | LCD KEYPAD MOUNTED AT 1100mm AFFL. TYPE TO MATCH THE EXISTING KEY PAD USED IN THE ADMINISTRATION BUILDING. CONNECT TO THE LOCAL SECURITY EQUIPMENT. MOUNT AT 1400 AFFL UNO. PROGRAM THE SECURITY SYSTEM AS REQUIRED TO ACCOMMODATE THE NEW KEY PANELS AND CHANGES TO THE SATISFACTION OF THE SCHOOL. SUBMIT DETAILS FOR APPROVAL PRIOR TO ORDERING | | | A |
| SIREN STROBE | | SECURITY SATELLITE STROBE SIREN MOUNTED AT HIGH LEVEL TO OPERATE WHEN THE BUILDING GOES INTO ALARM. TYPE TO MATCH THE EXISTING | | | A |
| PIT 1 | | 450 X 450 CLEAR INTERNAL X 700 DEEP PLASTIC POWER PIT C/W A REINFORCED CONCRETE SURROUND AND A CLASS C INFILL LID SUBMIT DETAILS OF THE PIT, LID AND AN INSTALLATION SECTION FOR APPROVAL. | | | A |
| PIT 2 | | 450 X 450 CLEAR INTERNAL X 700 DEEP PLASTIC POWER PIT C/W A REINFORCED CONCRETE SURROUND AND A CLASS C INFILL LID SUBMIT DETAILS OF THE PIT, LID AND AN INSTALLATION SECTION FOR APPROVAL. | | | B |
| PIT 3 | | 450 X 450 CLEAR INTERNAL X 700 DEEP PLASTIC POWER PIT C/W A REINFORCED CONCRETE SURROUND AND A CLASS C INFILL LID SUBMIT DETAILS OF THE PIT, LID AND AN INSTALLATION SECTION FOR APPROVAL. | | | B |
| PIT 4 | | 450 X 450 CLEAR INTERNAL X 700 DEEP PLASTIC COMMUNICATIONS PIT C/W A REINFORCED CONCRETE SURROUND AND A CLASS C INFILL LID SUBMIT DETAILS OF THE PIT, LID AND AN INSTALLATION SECTION FOR APPROVAL. | | | B |
| PIT 5 | | 450 X 450 CLEAR INTERNAL X 700 DEEP PLASTIC COMMUNICATIONS PIT C/W A REINFORCED CONCRETE SURROUND AND A CLASS C INFILL LID SUBMIT DETAILS OF THE PIT, LID AND AN INSTALLATION SECTION FOR APPROVAL. | | | B |