

# ELECTRICAL DESIGN GROUP

ELECTRICAL BUILDING SERVICES CONSULTANTS

P.O. Box 15, SHERWOOD Q. 4075

Phone: (07) 3278 4375 Fax: (07) 3716 0222

Web Site: www.edg.net.au Email: brisbane@edg.net.au


C3701a - NORTHS DEVILS RUGBY LEAGUE CLUB - CANTEEN & GAMEDAY OFFICE

C3701a-0004(A).xls

DISTRIBUTION BOARD DB-A

REVISION A - 23 JUNE 2026

							REV
FAULT CURRENT:		6kA	MAIN SWITCH:		160A NON AUTO LOAD BREAK SWITCH		A
CHASSIS SIZE:		60 POLES	SUPPLIED FROM:		MSB		A
CHASSIS RATING:		250A	SUPPLY CABLE:		1C 70		A
PHASES:		3					A
PROVIDE THE DB WITH AN AS2293 TEST FACILITY PROVIDE THE DB WITH A FULL WIDTH EMPTY DIN RAIL TO ACCOMMODATE FUTURE CONTACTORS AND CONTROLS IN ADDITION TO THE INITIAL CONTROL EQUIPMENT. PROVIDE THE DB WITH SURGE PROTECTION.							A
CIRC	PH	CIRCUIT BREAKER (amps)	CONTROL EQUIPMENT	CABLE SIZE (mm2)	LOCATION	CIRCUIT USE	A
P1	1	20	RCBO	2.5	TICKET OFFICE	SECURITY	A
P2	1	20	RCBO	2.5	TICKET OFFICE	CR-A	A
P3	1	20	RCBO	2.5	TICKET OFFICE	STORE	A
P4	1	20	RCBO	2.5	TICKET OFFICE	MECHANDISING	A
P5	1	20	RCBO	2.5	TICKET OFFICE	AB GPO	A
P6	1	20	RCBO	2.5	TICKET OFFICE	POS	A
P7	1	20	RCBO	2.5	TICKET OFFICE	FIRST AID	A
P8	1	20	RCBO	2.5	TICKET OFFICE	3.6KW HWS	A
P9	1	20	RCBO	2.5	TICKET OFFICE	REF	A
P10	1	20	RCBO	2.5	TICKET OFFICE	AC	A
P11	1	20	RCBO	2.5	CANTEEN	TV	A
P12	1	20	RCBO	2.5	CANTEEN	TV	A
P13	1	20	RCBO	2.5	CANTEEN	HD	A
P14	1	20	RCBO	2.5	CANTEEN	HD	A
P15	1	20	RCBO	2.5	CANTEEN	AMENITY	A
P16	1	20	RCBO	2.5	CANTEEN	GPOs	A
P17	1	20	RCBO	2.5	CANTEEN	ORDER COUNTER	A
P18	1	20	RCBO	2.5	CANTEEN	POS	A
P19	1	20	RCBO	2.5	CANTEEN	PIE WARMER	A
P20	1	20	RCBO	2.5	CANTEEN	PIE WARMER	A
P21	1	20	RCBO	2.5	CANTEEN	ICE MACHINE	A
P22	1	20	RCBO	2.5	CANTEEN	BB GPOs	A
P23	1	20	RCBO	2.5	CANTEEN	REF	A
P24	1	20	RCBO	2.5	CANTEEN	3.6KW HWS	A
P25	3	20	RCBO	2.5	CANTEEN	EXHAUST FAN	A
P26	1	25	RCBO	6.0	CANTEEN	FRYER	A
P27	1	25	RCBO	6.0	CANTEEN	FRYER	A
P28	1	20	RCBO	2.5	CANTEEN	WASHUP GPOs	A
P29	1	20	RCBO	2.5	CANTEEN	COOL ROOM	A
P30	1	20	RCBO	2.5	CANTEEN	COMPRESSOR	A
							A



# ELECTRICAL DESIGN GROUP

ELECTRICAL BUILDING SERVICES CONSULTANTS

P.O. Box 15, SHERWOOD Q. 4075

Phone: (07) 3278 4375 Fax: (07) 3716 0222

Web Site: www.edg.net.au Email: brisbane@edg.net.au

C3701a - NORTHS DEVILS RUGBY LEAGUE CLUB - CANTEEN & GAMEDAY OFFICE

C3701a-0004(A).xls

DISTRIBUTION BOARD DB-A

REVISION A - 23 JUNE 2026

							REV
FAULT CURRENT:		6kA	MAIN SWITCH:		160A NON AUTO LOAD BREAK SWITCH		A
CHASSIS SIZE:		60 POLES	SUPPLIED FROM:		MSB		A
CHASSIS RATING:		250A	SUPPLY CABLE:		1C 70		A
PHASES:		3					A
PROVIDE THE DB WITH AN AS2293 TEST FACILITY PROVIDE THE DB WITH A FULL WIDTH EMPTY DIN RAIL TO ACCOMMODATE FUTURE CONTACTORS AND CONTROLS IN ADDITION TO THE INITIAL CONTROL EQUIPMENT. PROVIDE THE DB WITH SURGE PROTECTION.							A
CIRC	PH	CIRCUIT BREAKER (amps)	CONTROL EQUIPMENT	CABLE SIZE (mm2)	LOCATION	CIRCUIT USE	A
L1	1	20	RCBO PE ON DUSK OFF DAWN	2.5	TICKET OFFICE	SECURITY LIGHTS	A
L2	1	20	RCBO PE ON DUSK TC OFF 10.00 PM	2.5	TICKET OFFICE	SIGN	A
L3	1	20	RCBO PE ON DUSK TC OFF 10.00 PM	2.5	TICKET OFFICE	EXTERNAL LIGHTS	A
L4	1	20	RCBO	2.5	TICKET OFFICE	INTERNAL LIGHTS	A
L5	1	20	RCBO PE ON DUSK TC OFF 10.00 PM	2.5	CANTEEN	SIGN	A
L6	1	20	RCBO	2.5	CANTEEN	INTERNAL LIGHTS	A
L7	1	20	RCBO	2.5	CANTEEN	TERRACE LIGHTS	A
L8	1	20	RCBO PE ON DUSK TC OFF 10.00 PM	2.5	CANTEEN	EXTERNAL LIGHTS	A
							A
							A
							A