



ELECTRICAL DESIGN GROUP

ELECTRICAL BUILDING SERVICES CONSULTANTS

P.O. Box 15, SHERWOOD Q. 4075

Phone: (07) 3278 4375 Fax: (07) 3716 0222

Web Site: www.edg.net.au Email: brisbane@edg.net.au

C3702a - KALLANGUR MEMORIAL BOWLS CLUB

C3702a-0002(C).xls

ELECTRICAL EQUIPMENT SCHEDULE

REVISION C - 23 APRIL 2026

THE LIGHT FITTING SUPPLIER CONTACT DETAILS MAY BE AVAILABLE ON THE EDG WEBSITE VIA THE FOLLOWING LINK
www.edg.net.au/Links/Lighting.htm

TYPE	LAMPS	DESCRIPTION	COLOUR / ACCESSORY	CATALOGUE No	REV
WL01	2 X 8W 27000K GU10 240V LED	WALL MOUNTED IP65 UP DOWN FITTING WITH THE MOUNTING HEIGHT CONFIRMED ON SITE WITH THE ARCHITECT	BLACK	EQUAL TO ORE LIGHTING SHO.1215.MB	A
SL03	15W LED	SURFACE MOUNTED 60 DEG CAN DOWNLIGHT C/W INTEGRAL DRIVER	WHITE	RAPID LED R1141-WH- WH-60-SM	A
RD01	13W LED	RECESSED DOWNLIGHT C/W REMOTE TRAILING EDGE DIMMABLE DRIVER	WHITE	RAPID LED R1051	A
RD02	13W LED	RECESSED DOWNLIGHT C/W REMOTE TRAILING EDGE DIMMABLE DRIVER	WHITE	RAPID LED R1051	A
RD03	RECESSED DOWNLIGHT TO MATCH THE EXISTING ADJACENT RDE FITTING IN APPEARANCE OUTPUT AND CONTROL.				A
RD04	25W 4000K LED	RECESSED DOWNLIGHT C/W REMOTE DALI DIMMABLE DRIVER	WHITE	RAPID R1353-WH- 25W-DALI	A
RD05	NO LONGER REQUIRED				C
RDE	EXISTING RECESSED DOWNLIGHT TO REMAIN				A
SLE	EXISTING SURFACE MOUNTED FITTING TO REMAIN				A
CR01	EXISTING COOL ROOM LIGHT FITTING TO REMAIN				B
SL01	EXISTING SURFACE MOUNTED FITTING TO REMAIN				B
PD10	WARM WHITE LED	REPLACE THE EXISTING POOL TABLE LIGHTS	NATURAL WOOD	FAT SHACK VINTAGE WOODBAY CCT LED LINEAR 1200	A
PD11	NO LONGER REQUIRED				C
RT01	30W 4000K LED	REPLACE THE EXISTING SURFACE MOUNTED BATTEN WITH A RECESSED 300 X 1200 PANEL LIGHT C/W RECESS KIT AND REMOTE DRIVER	WHITE	RAPID LED R3206-TRI- RM	B
RT02	30W 4000K LED	RECESSED 300 X 1200 PANEL LIGHT C/W RECESS KIT AND REMOTE DRIVER	WHITE	RAPID LED R3206-TRI- RM	B
RT03	16W 4000K LED	REPLACE THE EXISTING SURFACE MOUNTED BATTEN WITH A RECESSED 300 X 600 PANEL LIGHT C/W RECESS KIT AND REMOTE DRIVER	WHITE	RAPID LED R3207-TRI- RM	B



ELECTRICAL DESIGN GROUP

ELECTRICAL BUILDING SERVICES CONSULTANTS

P.O. Box 15, SHERWOOD Q. 4075

Phone: (07) 3278 4375 Fax: (07) 3716 0222

Web Site: www.edg.net.au Email: brisbane@edg.net.au

C3702a - KALLANGUR MEMORIAL BOWLS CLUB					C3702a-0002(C).xls
ELECTRICAL EQUIPMENT SCHEDULE					
REVISION C - 23 APRIL 2026					
THE LIGHT FITTING SUPPLIER CONTACT DETAILS MAY BE AVAILABLE ON THE EDG WEBSITE VIA THE FOLLOWING LINK www.edg.net.au/Links/Lighting.htm					
TYPE	LAMPS	DESCRIPTION	COLOUR / ACCESSORY	CATALOGUE No	REV
S1	NO LONGER REQUIRED				C
E1	LED	EMERGENCY LIGHT: RECESSED NON-MAINTAINED EMERGENCY LIGHT. AS2293 CLASSIFICATION C0-D63 - C90-D63.	WHITE	CLEVERTRONICS CLIFE-PRO	A
E2	EXISTING EMERGENCY LIGHT TO BE REMOVED				A
EX	LED	EXIT LIGHT: MAINTAINED 24M VIEWING DISTANCE EXIT LIGHT C/W DIFFUSERS & DIRECTIONAL ARROWS AS SHOWN. CEILING SURFACE MOUNT OR WALL MOUNT BETWEEN 2100mm & 2700mm AFFL IF THERE IS NO VERTICAL SURFACE TO MOUNT THE FITTING ON WITHIN THIS RANGE CONFIRM THE MOUNTING HEIGHT WITH THE ENGINEER. AS2293 CLASSIFICATION C0- D1.25- C90-D2	WHITE	CLEVERTRONICS LUBPRO-SM	A
CHANNEL x		CONTROL CHANNEL WITH A NUMERICAL REFERENCE. REFER TO THE POWER AND LIGHTING CONTROL SCHEMATIC / SCHEDULE			A
EXISTING CEILING FAN (FE)		EXISTING CEILING FAN TO REMAIN AS IS			A
ONE-WAY LIGHT SWITCH		ONE-WAY LIGHT SWITCH C/W CIRCUIT IDENTIFICATION ON THE FACEPLATE BEHIND THE SURROUND MOUNTED AT 1000mm AFFL UNLESS NOTED OTHERWISE.	WHITE	CLIPSAL C2000 SERIES 30USM	A
TWO-WAY LIGHT SWITCH		TWO-WAY LIGHT SWITCH C/W CIRCUIT IDENTIFICATION ON THE FACEPLATE BEHIND THE SURROUND MOUNTED AT 1000mm AFFL UNLESS NOTED OTHERWISE.	WHITE	CLIPSAL C2000 SERIES 30USM	A
TRAILING EDGE DIMMER (TE)		400VA PHASE CUT TRAILING EDGE POT DIMMER	WHITE	CLIPSAL C2000 SERIES	A
DALI POT DIMMER / SWITCH		ONE-WAY DALI LIGHT SWITCH / DIMMER C/W CIRCUIT IDENTIFICATION ON THE FACEPLATE BEHIND THE SURROUND MOUNTED AT 1000mm AFFL UNLESS NOTED OTHERWISE.	WHITE	SMARTSCAPE DALI RD20 CLIPSAL C2000	A
LIGHTING CONTROL SWITCH PANEL (SP1)		ADD TO THE EXISTING LIGHTING CONTROL SWITCH PANEL AS PER THE LIGHTING CONTROL SCHEMATIC			A
SINGLE POWER OUTLET		SINGLE POWER OUTLET C/W CIRCUIT IDENTIFICATION ON THE FACEPLATE BEHIND THE SURROUND MOUNT AT 300mm AFFL U.N.O. RATING 10A U.N.O.	WHITE	CLIPSAL C2000 SERIES	A
DOUBLE POWER OUTLET		DOUBLE POWER OUTLET C/W CIRCUIT IDENTIFICATION ON THE FACEPLATE BEHIND THE SURROUND MOUNT AT 300mm AFFL U.N.O. RATING 10A U.N.O.	WHITE	CLIPSAL C2000 SERIES	A



ELECTRICAL DESIGN GROUP

ELECTRICAL BUILDING SERVICES CONSULTANTS

P.O. Box 15, SHERWOOD Q. 4075

Phone: (07) 3278 4375 Fax: (07) 3716 0222

Web Site: www.edg.net.au Email: brisbane@edg.net.au

C3702a - KALLANGUR MEMORIAL BOWLS CLUB

C3702a-0002(C).xls

ELECTRICAL EQUIPMENT SCHEDULE

REVISION C - 23 APRIL 2026

THE LIGHT FITTING SUPPLIER CONTACT DETAILS MAY BE AVAILABLE ON THE EDG WEBSITE VIA THE FOLLOWING LINK
www.edg.net.au/Links/Lighting.htm

TYPE	LAMPS	DESCRIPTION	COLOUR / ACCESSORY	CATALOGUE No	REV
SINGLE-PHASE ISOLATOR		SINGLE-PHASE WEATHERPROOF ISOLATOR. MOUNT AT 1350mm AFFL U.N.O. RATING 20A U.N.O. CONNECT TO EQUIPMENT VIA FLEXIBLE CONDUIT.	-	CLIPSAL WHT20	A
THREE-PHASE ISOLATOR		THREE-PHASE WEATHERPROOF ISOLATOR. MOUNT AT 1350mm AFFL U.N.O. RATING 20A U.N.O. CONNECT TO EQUIPMENT VIA FLEXIBLE CONDUIT.	-	CLIPSAL WHT35	A
SIGN CONNECTION		COORDINATE THE LOCATION AND CONNECTION WITH THE SIGN CONTRACTOR ENSURING THE GPO / ISOLATORS ARE PROVIDED WITH APPROPRIATE WEATHER PROTECTION AND ARE CONCEALED FROM VIEW.			A
SECURITY EQUIPMENT		SECURITY EQUIPMENT WALL MOUNTED AT HIGH LEVEL. ENSURE THE POWER AND COMMUNICATIONS OUTLETS SUPPLYING THE SECURITY EQUIPMENT ARE MOUNTED WITHIN THE SECURITY EQUIPMENT HOUSINGS SUCH THAT THE OUTLETS AND 240 VOLT FLEXES ARE NOT VISIBLE UNDER NORMAL CONDITIONS.			A
PIEZO SIREN		FLUSH RECESSED WHITE PIEZO SIREN SUBMIT DETAILS OF THE PIEZO SIREN FOR APPROVAL PRIOR TO ORDERING			A
SECURITY STROBE		WALL MOUNTED AT HIGH LEVEL SECURITY SYSTEM SATELLITE STROBE. SUBMIT DETAILS OF THE STROBE INCLUDING ITS MOUNTING POSITION FOR APPROVAL PRIOR TO ORDERING.			A
KEY PAD (KP)		SECURITY ARMING / DISARMING KEY PAD WALL MOUNTED. SUBMIT DETAILS OF THE KEY PAD AND ENCLOSURE FOR APPROVAL PRIOR TO ORDERING.			A
INTRUDER DETECTOR		DUAL-TECHNOLOGY 360 DEG MOVEMENT DETECTORS CEILING RECESSED MOUNTED AS PER THE MANUFACTURER'S SPECIFICATION. CONNECT TO THE SECURITY EQUIPMENT WITH ONE DETECTOR PER ZONE. SUBMIT DETAILS OF THE DETECTORS INCLUDING THE MOUNTING ARRANGEMENTS FOR APPROVAL PRIOR TO ORDERING.			A
DB-A		EXISTING MSB / DISTRIBUTION BOARD DB-A TO BE MODIFIED AS PER THE DB-A SCHEDULE AND RESUPPLIED FROM THE NEW MSB AS PER THE POWER SCHEMATIC / NOTES. REMOVE ALL COMPONENTS MADE REDUNDANT BY THE WORKS AND UPDATE THE CIRCUIT SCHEDULE AT PRACTICAL COMPLETION WITH THE CIRCUIT USE AND LOCATION.			A
DB-B		DISTRIBUTION BOARD DB-B AS PER THE DB-B SCHEDULE AND NOTES. PROVIDE A SHOP DRAWING OF DB-B FOR APPROVAL.			A
MSB		MAIN SWITCHBOARD AS PER THE POWER SCHEMATIC AND NOTES. PROVIDE A SHOP DRAWING OF THE MAIN SWITCHBOARD FOR APPROVAL.			A
REVENUE METER (M1)		NEM CODE COMPLIANT CT RETAIL METER INCLUDING ALL ASSOCIATED COMPONENTS INCLUDING THE METERS AND CTS ETC.			A
REVENUE METER (M2)		NEM CODE COMPLIANT DIRECT WIRED RETAIL METER INCLUDING ALL ASSOCIATED COMPONENTS INCLUDING THE METERS AND FUSED LINKS ETC.			A
SPEAKER		RECESSED 265 DIA DUAL CONE SPEAKER C/W 100V MULTI-TAP TRANSFORMER AND FLUSH GRILLE WIRED TO THE AMPLIFIER MOUNTED IN THE COMMUNICATIONS RACK CR-B	WHITE GRILLE	EQUAL TO BOSCH LBC 3099/41	A



ELECTRICAL DESIGN GROUP

ELECTRICAL BUILDING SERVICES CONSULTANTS

P.O. Box 15, SHERWOOD Q. 4075

Phone: (07) 3278 4375 Fax: (07) 3716 0222

Web Site: www.edg.net.au Email: brisbane@edg.net.au

C3702a - KALLANGUR MEMORIAL BOWLS CLUB					C3702a-0002(C).xls
ELECTRICAL EQUIPMENT SCHEDULE					
REVISION C - 23 APRIL 2026					
THE LIGHT FITTING SUPPLIER CONTACT DETAILS MAY BE AVAILABLE ON THE EDG WEBSITE VIA THE FOLLOWING LINK www.edg.net.au/Links/Lighting.htm					
TYPE	LAMPS	DESCRIPTION	COLOUR / ACCESSORY	CATALOGUE No	REV
MATV		UPGRADE THE EXISTING MATV SYSTEM TO ACCOMMODATE THE ADDITIONAL TV OUTLETS CONNECT THE ADDITIONAL OUTLETS TO THE DISTRIBUTION EQUIPMENT VIA RG6 CABLING.	WHITE	CLIPSAL C2000 SERIES	A
COMMUNICATIONS RACK (CR-A)		NO LONGER REQUIRED			C
COMMUNICATIONS RACK (CR-B)		WALL MOUNTED HINGED 18 RU MINIMUM 600 DEEP 600 WIDE RACK CR-B PROVIDE A SHOP DRAWING OF THE RACK . PROVIDE THE RACK WITH A RACK MOUNTED NBN NTD AND PATCH PANELS TO ACCOMMODATE THE RSL COMMUNICATIONS OUTLETS. MOUNT THE PA AMPLIFIER IN THE TOP OF THE RACK. PROVIDE THE RACK WITH A REAR HORIZONTAL 10 PORT 10 AMP POWER RAIL.		4 CABLING SKU 002.001.4280	A
COMMUNICATIONS OUTLET		RSL RJ45 CAT-6 COMMUNICATIONS OUTLET, CABLED BACK TO CAT 6 PATCH PANELS IN RACK CR-B VIA 4-PAIR CAT-6 UTP CABLE. MOUNT UP TO 3 RJ45 OUTLETS PER MULTI-GANG FACEPLATE WITH SEPARATE PERMANENT LABELLING FOR EACH OUTLET. MOUNT AT 300 AFFL UNLESS NOTED OTHERWISE	WHITE	CLIPSAL C2000 SERIES	A
CAT 6 GAMING OUTLET		NO LONGER REQUIRED			C
GAMING FIBRE (GF)		NO LONGER REQUIRED			C
POWER PIT 1		600 X 600 CLEAR INTERNAL X 1000 DEEP INSITU POWER PIT C/W A REINFORCED CONCRETE SURROUND AND A CLASS C STEEL LID WITH A SLIP RESISTANCE OF R10 SUBMIT DETAILS OF THE PIT, LID AND AN INSTALLATION SECTION FOR APPROVAL. PROVIDE A 100 DIA CONDUIT FROM THE PIT TO THE PROPERTY POLE TO ACCOMMODATE THE CONSUMERS MAINS. INTERCONNECT PIT 1 TO PIT 2 VIA A 100 DIA CONDUIT TO ACCOMMODATE THE CONSUMERS MAINS.			A
POWER PIT 2		600 X 600 CLEAR INTERNAL X 1000 DEEP INSITU POWER PIT C/W A REINFORCED CONCRETE SURROUND AND A CLASS C STEEL LID WITH A SLIP RESISTANCE OF R10 SUBMIT DETAILS OF THE PIT, LID AND AN INSTALLATION SECTION FOR APPROVAL. PROVIDE A 100 DIA CONDUIT FROM THE PIT TO THE MSB TO ACCOMMODATE THE CONSUMERS MAINS. INTERCONNECT PIT 1 TO PIT 2 VIA A 100 DIA CONDUIT TO ACCOMMODATE THE CONSUMERS MAINS.			A