

ELECTRICAL DESIGN GROUP

ELECTRICAL BUILDING SERVICES CONSULTANTS

P.O. Box 15, SHERWOOD Q. 4075

Phone: (07) 3278 4375 Fax: (07) 3716 0222

Web Site: www.edg.net.au Email: brisbane@edg.net.au


C3770a - FEDERAL HOTEL, TOOWOOMBA

C3770a-0004(A).xls

LIGHTING CONTROL SCHEDULE

REVISION A - 14 AUGUST 2026

MISCELLANEOUS EQUIPMENT				REV
ITEM		DESCRIPTION		A
SP1		WALL MOUNTED WHITE ZENCONTROL SSD MOUNTED AT 1000 AFFL CONFIGURE THE CONTROLS AS PER THE NOTES		A
SP2		WALL MOUNTED WHITE ZENCONTROL SSD MOUNTED AT 1000 AFFL CONFIGURE THE CONTROLS AS PER THE NOTES		A
SP3		WALL MOUNTED WHITE ZENCONTROL SSD MOUNTED AT 1000 AFFL CONFIGURE THE CONTROLS AS PER THE NOTES		A
SP4		WALL MOUNTED WHITE ZENCONTROL SSD MOUNTED AT 1000 AFFL CONFIGURE THE CONTROLS AS PER THE NOTES		A
SP5		WALL MOUNTED WHITE ZENCONTROL SSD MOUNTED AT 1000 AFFL CONFIGURE THE CONTROLS AS PER THE NOTES		A
SP6		WALL MOUNTED WHITE ZENCONTROL SSD MOUNTED AT 1000 AFFL CONFIGURE THE CONTROLS AS PER THE NOTES		A
CONTROL MODULE 1				A
TYPE:		ZENCONTROL ZC-CONTROLLER-PRO-3		A
DESCRIPTION		3 LINE DALI APPLICATION CONTROLLER		A
LOCATION		DIN RAIL MOUNTED WITHIN DB-4		A
CHANNEL	CONTROL	CIRCUIT		A
1	DALI DIM	DB-4 - L1 L2 AND L3		A
2	DALI DIM	DB-4 - L4 AND L5		A
3	DALI DIM	DB-4 - L6 AND L7		A
CONTROL MODULE 2				A
TYPE:		ZENCONTROL ZC-PSU		A
DESCRIPTION		DALI POWER SUPPLY		A
LOCATION		DIN RAIL MOUNTED WITHIN DB-4		A
CONTROL MODULE 3				A
TYPE:		ZENCONTROL ZC-PSU		A
DESCRIPTION		DALI POWER SUPPLY		A
LOCATION		DIN RAIL MOUNTED WITHIN DB-4		A
CONTROL MODULE 4				A
TYPE:		ZENCONTROL ZC-PSU		A
DESCRIPTION		DALI POWER SUPPLY		A
LOCATION		DIN RAIL MOUNTED WITHIN DB-4		A
CONTROL MODULE 5				A
TYPE:		LUMILINK LL-D2PH-4C-DIN		A
DESCRIPTION		4 CHANNEL DALI TRAILING EDGE PHASE DIMMER		A
LOCATION		DIN RAIL MOUNTED WITHIN DB-4		A
CHANNEL	CONTROL	CIRCUIT		A
4	TE DIM	DB-4 - L8		A
5	TE DIM			A
6	TE DIM			A
7	TE DIM			A
CONTROL MODULE 6				A



ELECTRICAL DESIGN GROUP

ELECTRICAL BUILDING SERVICES CONSULTANTS

P.O. Box 15, SHERWOOD Q. 4075

Phone: (07) 3278 4375 Fax: (07) 3716 0222

Web Site: www.edg.net.au Email: brisbane@edg.net.au


C3770a - FEDERAL HOTEL, TOOWOOMBA

C3770a-0004(A).xls

LIGHTING CONTROL SCHEDULE

REVISION A - 14 AUGUST 2026

TYPE:		LUMILINK LL-D2PH-4C-DIN			A
DESCRIPTION		4 CHANNEL DALI TRAILING EDGE PHASE DIMMER			A
LOCATION		DIN RAIL MOUNTED WITHIN DB-4			A
CHANNEL	CONTROL	CIRCUIT			A
8	TE DIM	DB-4 - L9			A
9	TE DIM				A
10	TE DIM				A
11	TE DIM				A
CONTROL MODULE 7					A
TYPE:		LUMILINK LL-D2PH-4C-DIN			A
DESCRIPTION		4 CHANNEL DALI TRAILING EDGE PHASE DIMMER			A
LOCATION		DIN RAIL MOUNTED WITHIN DB-4			A
CHANNEL	CONTROL	CIRCUIT			A
12	TE DIM	DB-4 - L10			A
13	TE DIM				A
14	TE DIM				A
15	TE DIM				A
CONTROL MODULE 8					A
TYPE:		ZENCONTROL ZC-CONTROLLER-PRO-3			A
DESCRIPTION		3 LINE DALI APPLICATION CONTROLLER			A
LOCATION		DIN RAIL MOUNTED WITHIN DB-4			A
BUS:		A			A
CHANNEL	CONTROL	CIRCUIT			A
16	DALI DIM	DB-4 - L11 AND L12			A
17	DALI DIM	DB-4 - L13 AND L14			A
18	DALI DIM	DB-A4- L15			A
CONTROL MODULE 9					A
TYPE:		ZENCONTROL ZC-PSU			A
DESCRIPTION		DALI POWER SUPPLY			A
LOCATION		DIN RAIL MOUNTED WITHIN DB-A			A



ELECTRICAL DESIGN GROUP

ELECTRICAL BUILDING SERVICES CONSULTANTS

P.O. Box 15, SHERWOOD Q. 4075

Phone: (07) 3278 4375 Fax: (07) 3716 0222

Web Site: www.edg.net.au Email: brisbane@edg.net.au


C3770a - FEDERAL HOTEL, TOOWOOMBA

C3770a-0004(A).xls

LIGHTING CONTROL SCHEDULE

REVISION A - 14 AUGUST 2026

CONTROL MODULE 10				A	
TYPE:		ZENCONTROL ZC-PSU		A	
DESCRIPTION		DALI POWER SUPPLY		A	
LOCATION		DIN RAIL MOUNTED WITHIN DB-A		A	
CONTROL MODULE 11				A	
TYPE:		ZENCONTROL ZC-PSU		A	
DESCRIPTION		DALI POWER SUPPLY		A	
LOCATION		DIN RAIL MOUNTED WITHIN DB-A		A	
CONTROL MODULE 12				A	
TYPE:		LUMILINK LL-D2PH-4C-DIN		A	
DESCRIPTION		4 CHANNEL DALI TRAILING EDGE PHASE DIMMER			A
LOCATION		DIN RAIL MOUNTED WITHIN DB-4			A
CHANNEL	CONTROL	CIRCUIT			A
19	TE DIM	DB-4 - L16			A
20	TE DIM				A
21	TE DIM				A
22	TE DIM				A



ELECTRICAL DESIGN GROUP

ELECTRICAL BUILDING SERVICES CONSULTANTS

P.O. Box 15, SHERWOOD Q. 4075

Phone: (07) 3278 4375 Fax: (07) 3716 0222

Web Site: www.edg.net.au Email: brisbane@edg.net.au

C3770a - FEDERAL HOTEL, TOOWOOMBA

C3770a-0004(A).xls

LIGHTING CONTROL SCHEDULE

REVISION A - 14 AUGUST 2026

CONTROL MODULE 13				A
TYPE:		LUMILINK LL-D2PH-4C-DIN		A
DESCRIPTION		4 CHANNEL DALI TRAILING EDGE PHASE DIMMER		A
LOCATION		DIN RAIL MOUNTED WITHIN DB-4		A
CHANNEL	CONTROL	CIRCUIT		A
23	TE DIM	DB-4 - L16		A
24	TE DIM			A
25	TE DIM			A
26	TE DIM			A
CONTROL MODULE 14				A
TYPE:		ZENCONTROL 4 CHANNEL DALI RELAY CONTROLLER		A
DESCRIPTION		4 CHANNEL DALI RELAY CONTROLLER		A
LOCATION		DIN RAIL MOUNTED WITHIN DB-4		A
CHANNEL	CONTROL	CIRCUIT		A
27	SWITCH	DB-4- L17		A
28	SWITCH			A
29	SWITCH			A
30	SWITCH			A
CONTROL MODULE 15				A
TYPE:		ZENCONTROL 4 CHANNEL DALI RELAY CONTROLLER		A
DESCRIPTION		4 CHANNEL DALI RELAY CONTROLLER		A
LOCATION		DIN RAIL MOUNTED WITHIN DB-4		A
CHANNEL	CONTROL	CIRCUIT		A
31	SWITCH	DB-4 - L18		A
32	SWITCH			A
33	SWITCH			A
34	SWITCH			A