



ELECTRICAL DESIGN GROUP

ELECTRICAL BUILDING SERVICES CONSULTANTS

P.O. Box 15, SHERWOOD Q. 4075

Phone: 0418 893 338

Web Site: www.edg.net.au Email: brisbane@edg.net.au

C3785a - AVEO ROBINA GARDENS RETIREMENT LIVING

C3785a-0004(A).xls

DISTRIBUTION BOARD DB-A

REVISION A - 11 SEPTEMBER 2026

							REV
IT IS ACCEPTABLE TO UTILISE THE EXISTING SWITCHGEAR IF IT IS IN GOOD CONDITION, HAS APPROPRIATE RATINGS AND COMPLIES WITH THE CURRENT REQUIREMENTS OF AS3000. THE EXISTING LIGHTING CIRCUITS ARE TO BE RELOCATED TO DB-B.							A
CIRC	PH	CIRCUIT BREAKER (amps)	CONTROL EQUIPMENT	CABLE SIZE (mm2)	LOCATION	CIRCUIT USE	
P1	1	20	RCBO	2.5	RECEPTION	GPO	A
P2	1	20	RCBO	2.5	HALL / LOUNGE	GPO	A
P3	1	20	RCBO	2.5	SALES	GPO	A
P4	1	20	RCBO	2.5	HALL	GPO	A
P5	3	20	RCBO	2.5	GYM	3 X 3.6KW HWS	A
P6	1	20	RCBO	2.5	BAR	REF	A
P7	1	20	RCBO	2.5	BAR	GPO	A
P8	1	20	RCBO	2.5	BAR	BILLI	A
P9	1	20	RCBO	2.5	BAR	BILLI	A
P10	1	20	RCBO	2.5	BAR	GLASS WASHER	A
P11	1	20	RCBO	2.5	BAR	REF	A
P12	1	20	RCBO	2.5	BAR	ICE	A
P13	1	20	RCBO	2.5	BAR	POS	A
P14	1	20	RCBO	2.5	BAR	REF	A
P15	1	20	RCBO	2.5	AMENITY	GPO	A
P16	1	20	RCBO	2.5	CINEMA	TV	A
P17	1	20	RCBO	2.5	CINEMA	GPO	A
P18	3	20	RCBO	2.5	NOOK	3 X 3.6KW HWS	A
P19	1	20	RCBO	2.5	NOOK	BILLI	A
P20	1	20	RCBO	2.5	NOOK	BILLI	A
P21	1	20	RCBO	2.5	NOOK	BENCH	A
P22	1	20	RCBO	2.5	NOOK	REF	A
P23	1	20	RCBO	2.5	NOOK	COFFEE	A
P24	1	20	RCBO	2.5	EXTERNAL	BBQ	A
P25	1	20	RCBO	2.5	EXTERNAL	BBQ	A
P26	1	20	RCBO	2.5	LOUNGE	GPO	A
P27	1	20	RCBO	2.5	LOUNGE	TV	A
P28	1	20	RCBO	2.5	KITCHEN	CLEANING	A
P29	1	20	RCBO	2.5	KITCHEN	BENCH GPOS	A
P30	1	32	RCBO	6.0	KITCHEN	OVEN	A
P31	1	20	RCBO	2.5	KITCHEN	BILLI	A
P32	1	20	RCBO	2.5	KITCHEN	BILLI	A
P33	1	20	RCBO	2.5	KITCHEN	REF	A
P34	1	20	RCBO	2.5	KITCHEN	MW / DW	A
P35	1	25	RCBO	4.0	EXTERNAL	CU 1-12	A
P36	1	25	RCBO	4.0	EXTERNAL	CU 1-11	A
P37	1	20	RCBO	2.5	EXTERNAL	CU 1-1	A
P38	1	20	RCBO	2.5	EXTERNAL	CU 1-2	A
P39	1	20	RCBO	2.5	EXTERNAL	CU 1-4	A
P40	1	20	RCBO	2.5	EXTERNAL	CU 1-3	A
P41	1	20	RCBO	2.5	EXTERNAL	CU 1-10	A
P42	1	20	RCBO	2.5	EXTERNAL	CU 1-9	A
P43	1	20	RCBO	2.5	EXTERNAL	CU 1-13	A
P44	1	20	RCBO	2.5	EXTERNAL	CU 1-5	A
P45	1	20	RCBO	2.5	EXTERNAL	CU 1-6	A
P46	1	20	RCBO	2.5	EXTERNAL	CU 1-7	A
P47	1	20	RCBO	2.5	EXTERNAL	CU 1-8	A
P48	1	20	RCBO	2.5	EXTERNAL	CU 1-16	A
P49	1	20	RCBO	2.5	EXTERNAL	CU 1-15	A
P50	1	20	RCBO	2.5	EXTERNAL	CU 1-17	A
P51	1	20	RCBO	2.5	GYM	TOILET EXHAUST	A
P52	3	63	MCB	25.0	RECEPTION OFFICE	DB-B	A

C3785a-0004(A).xls

Pages inc. any attach. 1 of 1